




THE VISION TO CHANGE.

THE INTEGRITY TO SUSTAIN.



THE VISION TO CHANGE.
THE INTEGRITY TO SUSTAIN.

Mount San Antonio College SCE Permanent Load Shifting Program Incentive

Account Number 3-000-2091-22
1100 N. Grand Avenue
Walnut, CA 91789

October 7, 2014

Prepared by:
P2S Engineering, Inc.
5000 East Spring St, Eighth Floor
Long Beach, CA 90815
562.497.2999
p2seng.com

Table of Contents

Executive Summary	2
Project Background	3
Existing Central Plant	5
Existing Central Plant Electric Loads.....	9
Thermal Energy Storage Options.....	10
Estimated Demand Reduction and Energy Use.....	12
Energy Efficiency Information.....	14
Operations and Maintenance	16
Economic Analysis	17
Recommendations.....	18
Appendices	

Executive Summary

Mt San Antonio College has approximately 822,000 SF of buildings connected to the existing central plant and a future 828,000 SF to be added by 2025, for a total square footage of 1,650,000 SF to be connected to the College central plant. The existing central plant has one 500 ton absorption chiller, two 750 ton chillers and a primary variable chilled water system. A satellite plant in Building 2 also supports the chilled water system with two 250 tons chillers, configured in a primary / secondary variable pump system. Mt San Antonio College has reached a point in the operation of the central plant where expansion of the chilled water is required to service the total square footage of the College through 2025 and to maintain redundancy in the chilled water system. The existing central plant has physical capacity to fit another 750 ton chiller and pumps. Our office reviewed the option of adding another 750 ton chiller and the option of adding a chilled water thermal energy storage system. Through a partnership between our office and the College, we are proposing thermal energy storage and the installation of the 750 ton chiller option for the following reasons:

- The energy savings resulting from not running the existing chillers (and a third chiller) during peak demand periods is substantial.
- A significant incentive is available to offset first costs related to the installation of a thermal energy storage system.
- The flexibility in having a redundant source of chilled water in case of chiller failure or maintenance.

Through the analysis presented in this report, P2S Engineering Inc. recommends the installation of the 20,000 ton hour chilled water thermal energy tank at Mt San Antonio College. The College is currently on a fixed rate through SCE and Constellation. It is recommended for the College to change to a TOU-8 rate in 2016 on the contract is up for renewal in order to maximize the energy savings during peak demand periods, an estimated \$323,000 for the first year. Also a 20 year life cycle cost analysis was performed as part of this report and a positive rate of return is expected after 12 years. The proposed 20,000 ton hour capacity in the thermal energy storage tank allows for future connection to the central plant chilled water system of the planned buildings as part of the master plan through 2025. Most importantly, the total tonnage offset during the summer peak operation hours is 2,311 tons. This equates to a \$1,602,913 immediate incentive available once additional buildings currently under constructed are completed in 2016. These incentives will help offset the estimated \$5.24M of first costs for the installation of a thermal energy storage system. It will also continue to save Mt San Antonio College money in maintenance and utility costs throughout the life of the central plant equipment.

Project Background

Mt San Antonio College has undergone extensive growth in facilities and upgrades within the last 10 years resulting in a total central plant connected square footage of 822,000. The College expects further build out of approximately 1,650,000 square feet over the next 10 years. A central plant was provided in 2003 to centralize all the chilled water supply for campus cooling for efficiency and equipment maintenance. Initially the central plant was designed with one (1) 500 ton absorption chiller and two (2) 750 ton centrifugal chillers, with a space for a third 750 ton centrifugal chiller to accommodate the future needs of the College. During the summer of 2014, a satellite central plant in Building 2 was connected to the College central plant chilled water loop with a total capacity of 500 tons to service the shoulder loads of the College.

In anticipation of the future loads resulting in almost double existing College cooling loads, an energy efficiency measure to provide chilled water to the various instructional buildings is required. Through a partnership, our office and the College opted for the thermal energy storage option for the following reasons:

1. The College is currently on a non-TOU rate schedule through SCE and Constellation through 2016. We are recommending herein changing the College rate schedule to TOU once contact is expired.
2. A significant incentive is available from SCE to offset first costs related to the installation of a thermal energy storage system.
3. The following are specific advantages to the College:
 - Efficient operation of the chillers during the night by operating them at higher efficiencies when the night temperatures are cooler.
 - Elimination of additional maintenance costs for added chillers and cooling towers to support the peak chilled water demand.
 - Reduce operating costs by generating chilled water at night when the demand charges are not applicable and the utility rates are lower compared to peak period rates (when TOU is applicable).
 - Help offset the peak demand charges of the College.
 - Help shield the College against future escalation in demand charges.
 - Efficient operation of the central plant at low loads.
 - Provide redundancy should a chiller fail during peak periods.
 - Addition of approximately 3,200 tons of additional chilled water capacity to the existing chiller plant to accommodate the cooling demands of the future buildings.

The following is the current Non-TOU schedule for the entire year at Mt SAC, fixed at \$0.147/kWh:

	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday
8am-12pm*	Mid Peak Energy Rate						
12pm-6 pm*	On-Peak Energy Rate						
6pm-11pm	Mid Peak Energy Rate						
11pm-8am	Off - Peak Energy Rate						

* Except holidays, holidays are considered off peak.

The actual SCE and Constellation College bills for the month of July can be found in Appendix A. These rates were utilized when taking into consideration the existing central plant operation.

The proposed location of the thermal energy storage tank is directly north of the existing central plant. Refer to Appendix B for site plan of College. The main central plant system will be changed from a primary variable to a primary/ secondary distribution system. The Building 2 satellite plant configuration will remain the same. The chillers are proposed to only operate during mid and off peak periods and to charge the tank at night during the summer months. It is expected that during the winter months, the thermal energy storage tank may be able to handle the full load of the College throughout its entire operating day.

The following is the proposed TOU-8 schedule for the summer season, June 1 to October 1.

	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday
8am-12pm*	Mid Peak Energy Rate						
12pm-6 pm*	On-Peak Energy Rate						
6pm-11pm	Mid Peak Energy Rate						
11pm-8am	Off - Peak Energy Rate						

* Except holidays, holidays are considered off peak.

The following is the proposed TOU-8 schedule for the winter season, October 1 to June 1.

	Monday	Tuesday	Wednesday	Thursday	Friday	Saturday	Sunday
8am-9pm*	Mid Peak Energy Rate						
9pm-8am	Off - Peak Energy Rate						

* Except Holidays, holidays are considered off peak.

The actual rate schedule can be found in Appendix A. These rates were utilized when taking into consideration the future central plant with TES operation.

Existing Central Plant

The existing central plant at Mt San Antonio College consists of one (1) 500 ton absorption chiller, two (2) 750 ton chillers, and distribution pumps that operate in a variable primary design via one (1) chilled water pump and one (1) standby pump. The absorption chiller assists in precooling the CHWR temperature before it returns to CH-2 and CH-3. There are two (2) cooling towers with variable speed fans located directly south of the central plant building that distribute condenser water to chillers via three (3) condenser water pumps and one (1) standby pump. This past year, the Building 2 satellite chiller plant was added to the chilled water loop to provide additional cooling to the College. It consists of two (2) 250 ton chillers and operates in a primary / secondary variable configuration design via two (2) chilled water pumps and one (1) standby chilled water pump. There is one (1) cooling tower with two (2) variable speed fans that distribute condenser water to the chillers via one (1) condenser water pump and one (1) standby pump. Both central plants are on an energy management system.

The following is a list of all central plant equipment:

CHILLERS	TONS	KW/TON	COOLING TOWERS	FAN HP	VARIABLE OR CONSTANT
CH-1 (ABS)	500		CT-1	40	VARIABLE
CH-2	750	0.6	CT-2	40	VARIABLE
CH-3	750	0.6	CT-1 (BLDG. 2)	(2) -15	VARIABLE
CH-1 (BLDG 2)	250	0.6			
CH-1 (BLDG 2)	250	0.6			

CHWP	PUMP HP	PUMP HD	VARIABLE OR CONSTANT
CHWP-1	200	228	VARIABLE
CHWP-2	200	228	VARIABLE
CHWP-1 (BLDG. 2)	20	65	CONSTANT
CHWP-2 (BLDG. 2)	20	65	CONSTANT
CHWP-3 (BLDG. 2)	30	100	VARIABLE
CHWP-4 (BLDG. 2)	30	100	VARIABLE
CWP	PUMP HP	PUMP HD	VARIABLE OR CONSTANT
CWP-1	60	30	CONSTANT
CWP-2	60	30	CONSTANT
CWP-3	60	30	CONSTANT
CWP-4	60	30	CONSTANT
CWP-1 (BLDG. 2)	40	15	CONSTANT
CWP-2 (BLDG. 2)	40	15	CONSTANT

There are various HVAC designs in each of the buildings connected to the central plant. Most of the HVAC systems are new or have been renovated to variable air volume systems. A total of approximately 822,000 SF of conditioned area is currently connected to the central plant for chilled water and are on College energy management system. Refer to Appendix C for a list of buildings and the Trace outputs of the typical peak profile day per month for the College.

The College's 2013-2014 academic calendars were incorporated into the study, along with standard schedules of each building. Generally, the College operates from 8am-10pm Monday through Friday. Many classes are off for lunch between noon and 1pm during this period. The existing central plant starts at 7am and is available until 10pm. The electric centrifugal chillers are off between 10pm and 7am; however, the absorption chiller continues to operate through the night.

All of the buildings connected to the central plant were modeled in Trane Trace. This included envelope loads, internal loads such as lighting and power, people, and operating schedules.

The following is HVAC peak block tonnage breakdown per building based on the Trane Trace model for the current buildings connected to the central plant without diversity:

NO.	BUILDING	SQUARE FOOTAGE	PEAK BLOCK TONNAGE
1A	Art Center	16,700	60
1B/C	Art StudioCenter	16,136	74
2B	Fedderson Recital Hall	63,361	193
4	Administration	41,963	113
6	Learning Technology Center	101,784	250
7	Science South	37,226	298
9B	Student Services	51,369	118
11	Science North	18,939	107
12	Building 12	13,000	50
13	Design Technology Center	62,000	162
26	Humianities/Social Sciences	98,230	359
29	Central Plant	148	1
60	Science	62,982	249
61	Math and Science	64,139	211
66	Language Center	43,911	123
67A	Health Careers	31,768	90
67B	Student Health	10,995	33
70-73	Childhood Development	36,012	99
80	Agricultural Science Building	51,100	214
	TOTALS	821,583	2,801

The following is HVAC peak block tonnage breakdown per building based upon the Trane Trace model for the additional buildings to be connected to the central plant by the end of 2016:


NO.	BUILDING	SQUARE FOOTAGE	PEAK BLOCK TONNAGE
9A	Food Services	12,000	52
9B Add	Student Support Services	16,056	53
	Business Technology	87,000	365
	TOTALS	115,056	470

The following is the HVAC peak tonnage breakdown per buildings estimated for the full build out by 2025. The buildings will be divided into 2 phases. 400 SF/ton was utilized for peak load estimation.

BUILDING	SQUARE FOOTAGE	PEAK BLOCK TONNAGE
PHASE 1		
Athletics Phase 1	45,000	240
Library/Campus Center	217,200	543
Classroom Building	101,400	254
Language Lab Expansion	15,000	38
Building 9A Renovation	21,300	53
Continuing Education	24,440	61
Athletics Phase 2	50,000	260
PHASE 2		
Instructional Building	50,000	125
Auditorium Zone	12,000	30
Instructional Building	75,000	188
Instructional Building	100,000	250
TOTALS	711,340	2,042

Trended information from both chiller plants was requested to review actual load profiles and diversity specific to Mt SAC. Per the College trends provide to our office, cooling demands peaked on September 15, 2014 at 3:00 pm at 2,311 tons. Outside air temperature was recorded at 102 deg F. This reflects an 83% diversity on campus during a peak period when compared to the calculated summarized Trane Trace peak block tonnage of the College.

The following is the peak cooling load profile of the peak day (September 15, 2014) at Mt San Antonio College per the trends:



Existing Central Plant Electric Loads

The central plant operation and load profiles were modeled to establish baseline electric load consumption based upon the building HVAC loads as listed previously. Below is the calculated central plant energy consumption supporting the current HVAC loads on campus. Refer to Appendix D for electric loads profiles modeled for the College.

	Total Existing Annual Load	Existing Summer Load (June 1 through October 1)	Existing Winter Load (October 1 through June 1)
On Peak (kWh)	882,211	882,211	0
Mid Peak (kWh)	2,330,606	820,611	1,509,995
Off Peak (kWh)	137,058	30,992	106,066
On Peak Demand (KW)	1,786	1,786	0

Thermal Energy Storage Options

Two options for energy storage were reviewed with the College; water storage and ice storage. The following are reasons why thermal energy water storage was recommended over the ice storage:

- The existing chillers can be utilized for charging the thermal energy storage tank without having to add a glycol chiller to charge an ice storage system.
- Generating low temperature glycol to make ice requires more compressor energy (0.9 kw/ton) than the existing chillers (0.7 kw/ton).
- Additional equipment (besides glycol chiller) is required for an ice storage system such as dedicated pumps, a plate and frame heat exchanger, a glycol loop, etc. This would require additional maintenance budget and expertise.
- There is increased complexity in the control strategy for ice storage as compared to the thermal energy storage tank.
- The College has the footprint available north of the central plant for the placement of thermal energy storage tank.

The thermal energy storage tank is assumed to operate over 6 hours of depletion during peak periods. 2,311 peak tons over 6 hours equates to 13,866 ton hours of required capacity. This is adequate chilled water for the existing buildings connected to central plant during a depletion time frame of over 6 hours. Currently the central plant with an installed capacity of about 2,300 tons (with absorption chiller) struggles to maintain chilled water supply to its buildings during peak periods.

There are still some buildings not connected to central plant and their future connection timeframe is unknown at this time. From our experience, community colleges in general experience about a 65% diversity factor in terms of building usage during peak periods. By the end of 2015, the connected load will include an additional 306 tons (470 tons x 65% diversity) resulting in to an additional 1,836 ton hours 15,702 ton hours required. Considering the additional cooling load requirements through 2025, a capacity of 20,000 ton hours is proposed for Mt San Antonio College. It is assumed that the buildings constructed between 2015 and 2025 will be more efficient, thus the assumption of 400 sf/ton will is conservative.

For the SCE incentive consideration, 2,311 tons will be considered as the total tons offset during the summer. In the past SCE has allowed demonstration of future loads with the year for additional incentive. Since current projects are under construction and expected to be completed by end of 2015, an additional 306 tons will be requested for consideration in the incentive.

The thermal energy storage tank will be located directly north of the central plant. An additional 750 ton water cooled chiller is proposed to be located in the central plant to assist with charging the tank at night and provide chiller redundancy. The existing primary pumps will be utilized as secondary pumps, and new primary pumps will be added. Refer to Appendix B for system schedules, control schematic, and TES concept level site plan.

The proposed typical operation of the central plant is as follows during peak Summer College operating hours (with new CH-4 installed):

	8am	9am	10 am	11 am	12 pm	1pm	2pm	3pm	4pm	5pm	6pm	7pm	8pm	9pm	10 pm
CH-2			X	X								X	X	X	
CH-3			X	X								X	X		
CH-4				X								X			
CH-1 (BLDG 2)	X	X													
CH-2 (BLDG 2)		X													
TES					X	X	X	X	X	X	X				

The proposed typical operation of the central plant is as follows night peak charging period (with new CH-4 installed):

	11pm	12am	1am	2am	3am	4am	5am	6am	7am
CH-2	X	X	X	X	X	X	X	X	X
CH-3	X	X	X	X	X	X	X	X	X
CH-4	X	X	X	X	X	X	X	X	X
CH-1 (BLDG 2)									
CH-2 (BLDG 2)									
TES									

The advantages of the proposed Thermal Energy Storage System are as follows:



1. Efficient operation of the chillers during the night by operating them at higher efficiencies when the night temperatures are cooler.
2. Elimination of additional maintenance costs for added chillers and cooling towers to support the peak chilled water demand.
3. Reduce operating costs by generating chilled water at night when the demand charges are not applicable and the utility rates are lower compared to peak period rates (when TOU-8 is applicable).
4. Help offset the peak demand charges of the College.
5. Help shield the College against future escalation in demand charges.
6. Efficient operation of the central plant at low loads.
7. Provide redundancy should a chiller fail during peak periods.
8. Addition of approximately 3,200 tons of additional chilled water capacity to the existing chiller plant to accommodate the cooling demands of the future buildings.

Estimated Demand Reduction and Energy Use

As stated herein the thermal energy storage tank would deplete between the hours of noon until 6pm during normal College operating hours. Below is an estimate of demand reduction and energy usage of the proposed operation of the central plant with TES.

	TES Annual Load	TES Summer Load (June 1 through October 1)	TES Winter Load (October 1 through June 1)
On Peak (kWh)	89,741	89,741	0
Mid Peak (kWh)	814,969	665,414	149,555
Off Peak (kWh)	2,601,863	926,115	1,675,748
On Peak Demand (KW)	191	191	0

The following is a breakdown of the energy usage savings graphically.



Energy Efficiency Information

The summer on, mid, and off peak periods, winter mid and off peak periods, and demand charges were considered as part of the energy analysis for this College. Appendix D can be referred to for the breakdown in costs for each period, below is the savings as calculated per year.

	Existing Annual Consumption	TES Annual Consumption with TOU Rate	Annual Savings
Summer On Peak (kWh)	\$125,891.52	\$9,438.94	\$116,452.59
Summer Mid Peak (kWh)	\$117,101.16	\$55,708.46	\$61,392.69
Summer Off Peak (kWh)	\$4,422.49	\$54,708.46	(\$49,653.37)
Winter Mid Peak (kWh)	\$215,476.30	\$11,732.60	\$203,743.69
Winter Off Peak (kWh)	\$15,135.66	\$91,009.85	(\$75,874.19)
Summer On Peak Demand (KW)	\$24,488.19	\$3,552.47	\$20,935.72
Summer Mid Peak Demand (KW)	\$24,406.75	\$917.93	\$23,488.82
Summer Facility Related Demand (KW)	\$24,488.19	\$2,347.34	\$22,140.85
Total	\$551,410.26	\$228,783.45	\$322,626.82

The annual operating savings is approximately \$323,000 per year. This is based upon the SCE TOU-8 rate, campus load profiles, and existing and future equipment efficiencies.

If Mt. SAC decided to not change its electrical rate from the existing non-TOU rate in the future once the TES is installed, the following is the savings calculated per year:

	Existing Annual Consumption	TES Annual Consumption with Non-TOU Rate	Annual Savings
Summer On Peak (kWh)	\$125,891.52	\$12,806.01	\$113,085.51
Summer Mid Peak (kWh)	\$117,101.16	\$94,954.59	\$22,146.57
Summer Off Peak (kWh)	\$4,422.49	\$132,156.62	(\$127,734.13)
Winter Mid Peak (kWh)	\$215,476.30	\$21,341.53	\$194,134.77
Winter Off Peak (kWh)	\$15,135.66	\$239,129.18	(\$223,996.51)
Summer On Peak Demand (KW)	\$24,488.19	\$2,614.30	\$21,873.89
Summer Mid Peak Demand (KW)	\$24,406.75	\$2,410.88	\$21,995.87
Summer Facility Related Demand (KW)	\$24,488.19	\$2,614.30	\$21,873.89
Total	\$551,410.26	\$508,027.39	\$43,382.88

It is highly recommended that Mt SAC changed from a non-TOU rate to a TOU as soon as the utility contract is up for renewal in order to maximize utility savings with the installation of the thermal energy storage system.

Operations and Maintenance

Thermal Energy Storage Tank

The maintenance of the tank would meet AWWA D100, the governing code for water storage tanks, including TES. It recommends that inspections are made every 3-5 years. Because the tank has no moving parts, visual inspections are all that are required with touch-up paint work as needed and recoats in accordance with paint manufacturer's recommendations.

Because the TES tanks have insulation on the outside, it is also recommended to visually inspect the insulation for any physical damage. Considering the environment/climate of Walnut, in the case of the Mt San Antonio College tank, there is little reason to suspect that the exterior paint is having any issues as long as the insulation paneling remains intact. The insulation protects the exterior paint from the elements. Visual inspection of the tank interior can be done by using a diver or some form of remote control camera, although this is rarely done. It is our understanding that the cool temperatures of the water inside the tank along with the chemical additives greatly increase the life of the internal coatings.

The concrete itself will theoretically last indefinitely as long as it remains protected. Therefore, the main concern when it comes to inspections revolve around the tank coatings. As long as the paint is in good condition, the concrete is in good condition. As noted above, as long as the insulation is in good condition, the exterior paint should be in good condition.

Chillers and Pumps

Currently the chillers and pumps are maintained by an independent contractor. The campus will continue to maintain the current maintenance plan for the existing chiller, the new chiller, and new pumps. This would not be an added cost to the project once the thermal energy storage tank is constructed, as this maintenance plan is currently in place now.

It is our understanding the chillers are checked quarterly and annually. Pump motors are recommended to be inspected every 6 months. The Mt San Antonio pumps have seal bearings thus lubrication is not required.

The annual operating costs are minimal since the thermal energy storage tank has no moving parts. There is also a chiller and pump maintenance program in place for the existing chiller and pumps, therefore, this maintenance cost would be negligible when considering added costs of maintenance for the thermal energy storage tank installation. However, there is additional maintenance costs related to the additional 750 ton chiller installation, new pumps, and the additional water treatment. The estimated increase in delta costs annually for this maintenance is approximately \$45,000.

Economic Analysis

The installation of the Mt San Antonio thermal energy storage system is estimated to be approximately \$5,235,000. This includes all installation and equipment costs for the tank, the chiller, the pumps, structural, etc. A breakdown of estimated construction costs is included in Appendix E. The calculated incentive for this program is as follows:

Cooling Load Shift (tons)	Conversion Factor (kw/ton)	PLS Incentive per KW	Calculated Incentive
2,617	0.7	\$875	\$1,602,913

Below is a 20 year life cycle cost analysis considering a 3% escalation factor every year on the utility rates and 3% on the maintenance costs on the thermal energy storage tank, new chiller, new pumps, and additional water treatment:

Year	Construction Cost	Incentives	Annual Energy Savings	Delta Maintenance Costs	Year End Costs
1	(\$5,235,000)	\$1,602,913	\$322,627	(\$45,000)	(\$3,354,461)
2	(\$3,354,461)		\$332,306	(\$46,350)	(\$3,068,505)
3	(\$3,068,505)		\$342,275	(\$47,741)	(\$2,773,971)
4	(\$2,773,971)		\$352,543	(\$49,173)	(\$2,470,600)
5	(\$2,470,600)		\$363,119	(\$50,648)	(\$2,158,129)
6	(\$2,158,129)		\$374,013	(\$52,167)	(\$1,836,283)
7	(\$1,836,283)		\$385,233	(\$53,732)	(\$1,504,783)
8	(\$1,504,783)		\$396,790	(\$55,344)	(\$1,163,337)
9	(\$1,163,337)		\$408,694	(\$57,005)	(\$811,647)
10	(\$811,647)		\$420,955	(\$58,715)	(\$449,407)
11	(\$449,407)		\$433,583	(\$60,476)	(\$76,300)
12	(\$76,300)		\$446,591	(\$62,291)	\$308,001
13	\$0		\$459,989	(\$64,159)	\$395,829
14	\$0		\$473,788	(\$66,084)	\$407,704
15	\$0		\$488,002	(\$68,067)	\$419,935
16	\$0		\$502,642	(\$70,109)	\$432,534
17	\$0		\$517,721	(\$72,212)	\$445,510
18	\$0		\$533,253	(\$74,378)	\$458,875
19	\$0		\$549,251	(\$76,609)	\$472,641
20	\$0		\$565,728	(\$78,908)	\$486,820

Recommendations

P2S Engineering Inc. recommends the installation of the 20,000 ton hour chilled water thermal energy tank at Mt San Antonio College for the following reasons:

1. Annual energy savings of approximately 2,300,000 kWh during mid and peak periods resulting in a first year energy savings of \$323,000. This savings would incrementally increase every year.
2. The \$1,602,903 incentive available by SCE to offset first costs related to the installation of a thermal energy storage system, after the 2016 buildings are connected,
3. The 20 year life cycle cost analysis and expected continued energy savings reflecting a positive rate of return after 12 years.
4. The thermal energy storage tank allows for flexibility in the chilled water system when considering maintenance of the existing chillers.
5. The maintenance as related to adding the thermal energy storage system is minimal as compared to expanding the central plant with only adding additional chillers or ice storage system. This is important in a community college setting.
6. The 20,000 ton hour capacity in the thermal energy storage tank allows for future connection to the central plant chilled water system once the remaining buildings are renovated.

Appendix A – Existing and Future Rate Schedules



An EDISON INTERNATIONAL Company

Southern California Edison
Rosemead, California (U 338-E)

Revised Cal. PUC Sheet No. 50338-E
Cancelling Revised Cal. PUC Sheet No. 50250-E

Schedule TOU-8
TIME-OF-USE - GENERAL SERVICE - LARGE

Sheet 10

(Continued)

RATES (Continued)

SERVICE METERED AND DELIVERED AT VOLTAGES FROM 2 KV THROUGH 50 KV

Option B Energy Charge - \$/kWh/Meter/Month	Delivery Service							Generation	
	Trans ¹	Distrbtn ²	NSGC ³	NDC ⁴	PPPC ⁵	DWRBC ⁶	PUCRF ⁷	Total ⁸	URG ⁹
Summer Season - On-Peak (0.00106)	0.00244 (I)	0.00156 (R)	0.00015 (I)	0.01043 (R)	0.00513	0.00024	0.01889 (R)	0.08629 (R)	(0.00463)
Mid-Peak (0.00106)	0.00244 (I)	0.00156 (R)	0.00015 (I)	0.01043 (R)	0.00513	0.00024	0.01889 (R)	0.06483 (R)	(0.00463)
Off-Peak (0.00106)	0.00244 (I)	0.00156 (R)	0.00015 (I)	0.01043 (R)	0.00513	0.00024	0.01889 (R)	0.03950 (R)	(0.00463)
Winter Season - On-Peak N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Mid-Peak (0.00106)	0.00244 (I)	0.00156 (R)	0.00015 (I)	0.01043 (R)	0.00513	0.00024	0.01889 (R)	0.05956 (R)	(0.00463)
Off-Peak (0.00106)	0.00244 (I)	0.00156 (R)	0.00015 (I)	0.01043 (R)	0.00513	0.00024	0.01889 (R)	0.03542 (R)	(0.00463)
Customer Charge - \$/Meter/Month		316.55 (I)						316.55 (I)	
Demand Charge - \$/kW of Billing Demand/Meter/Month									
Facilities Related	2.84	9.47 (I)						12.31 (I)	
Time Related									
Summer Season - On-Peak	0.00						0.00	18.63 (R)	
Mid-Peak	0.00						0.00	5.22 (R)	
Winter Season - Mid-Peak	0.00						0.00	0.00	
Off-Peak	0.00						0.00	0.00	
Power Factor Adjustment - \$/kVAR	0.27						0.27		

* The ongoing Competition Transition Charge (CTC) of \$0.00070 per kWh is recovered in the URG component of Generation. (R)

1 Trans = Transmission and the Transmission Owners Tariff Charge Adjustments (TOTCA) which are FERC approved. The TOTCA represents the Transmission Revenue Balancing Account Adjustment (TRBAA) of \$(0.00072) per kWh, Reliability Services Balancing Account Adjustment (RSBAA) of \$0.00002 per kWh, and Transmission Access Charge Balancing Account Adjustment (TACBAA) of \$(0.00036) per kWh.

2 Distrbtn = Distribution

3 NSGC = New System Generation Charge

4 NDC = Nuclear Decommissioning Charge

5 PPPC = Public Purpose Programs Charge (includes California Alternate Rates for Energy Surcharge where applicable.)

6 DWRBC = Department of Water Resources (DWR) Bond Charge. The DWR Bond Charge is not applicable to exempt Bundled Service and Direct Access Customers, as defined in and pursuant to D.02-10-063, D.02-02-051, and D.02-12-082.

7 PUCRF = The PUC Reimbursement Fee is described in Schedule RF-E.

8 Total = Total Delivery Service rates are applicable to Bundled Service, Direct Access (DA) and Community Choice Aggregation Service (CCA Service) Customers, except DA and CCA Service Customers are not subject to the DWRBC rate component of this Schedule but instead pay the DWRBC as provided by Schedule DA-CRS or Schedule CCA-CRS.

9 Generation = The Generation rates are applicable only to Bundled Service Customers.

10 DWREC = Department of Water Resources (DWR) Energy Credit – For more information on the DWR Energy Credit, see the Billing Calculation Special Condition of this Schedule.

(Continued)

(To be inserted by utility)

Advice 2760-E

Decision 12-07-007

10H12

Issued by
Akbar Jazayeri

Vice President

(To be inserted by Cal. PUC)

Date Filed Jul 23, 2012

Effective Aug 1, 2012

Resolution



Mt. San Antonio College
1100 N. Grand Avenue
Walnut, CA 91789

CNE CUSTOMER ID
CA_6337

STATEMENT NO.
0016809982

PAGE
1 of 4

CNE ACCOUNT ID
1-DUX-979

STATEMENT DATE
08/14/2014

DU DATE
09/14/2014

For questions or comments,
please contact Customer Care
at (888)635-0827
Monday through Friday
7:00 am to 6:00 pm
Central Standard Time,
or email us at
customerscare@constellation.com.

When contacting Constellation,
please reference the
CNE ACCOUNT ID
found at the top of this page.

ACCOUNT BALANCE

PREVIOUS STATEMENT DATE	07/15/2014
PREVIOUS BALANCE	\$95,242.34
PAYMENTS SINCE LAST INVOICE	\$-95,242.34
DEBITS/CREDITS SINCE LAST INVOICE	\$0.00
LATE/FINANCE FEE	\$0.00
CURRENT CHARGES	\$90,844.16
TOTAL AMOUNT DUE	\$90,844.16

RECEIVED AUG 20 2014

**COPY
OF ORIGINAL INVOICE**

plement energy conservation measures with no upfront capital outlay. Efficiency Ide Easy (EME) is a unique solution that lets you include the cost of efficiency upgrades on your electricity bill, and pay for the upgrades over the term of your contract. To learn more, contact us at 1-866-237-7693.

If you are already an EME customer, we thank you for your business.

WIRE TRANSFER INFORMATION:
Constellation NewEnergy, Inc.
ABA-ACH #111000012, ABA-WIRE
#026009593
ACCT #426223690
BANK: Bank of America

REMITTANCE ADDRESS:
Constellation NewEnergy, Inc.
14217 Collections Center Dr.
Chicago IL, 60693

PLEASE RETURN THIS PORTION WITH PAYMENT AND MAKE ALL CHECKS PAYABLE TO Constellation NewEnergy, Inc.

PLS SIGN AND RETURN
TO ACCOUNTS PAYABLE

X APPROVED TO PAY

8/21

X DATE

ENTER AMOUNT ENCLOSED

Write account number on check
and make payable to Constellation
NewEnergy, Inc.

September						
S	M	T	W	T	F	S
		1	2	3	4	5
7	8	9	10	11	12	13
14	15	16	17	18	19	20
21	22	23	24	25	26	27
28	29	30				

Payment Due

CNE CUSTOMER ID CA_6337	STATEMENT NO. 0016809982	DUE DATE 09/14/2014
CNE ACCOUNT ID 1-DUX-979	STATEMENT DATE 08/14/2014	AMOUNT DUE \$90,844.16

Additional charges per the terms of your contract will be applied to the Total Amount Due if payment is not received on or before the due date.

Gary Nellesen
Mt. San Antonio College - 3000209122
1100 N. Grand Avenue
Walnut, CA 91789

00000000000MT SAN ANTONIO COLLEGE000000000001-DUX-979001680998200090844160



Mt. San Antonio College
1100 N. Grand Avenue
Walnut, CA 91789

CNE CUSTOMER ID
CA_6337

STATEMENT NO.
0016809982


PAGE
3 of 4

CNE ACCOUNT ID
1-DUX-979

STATEMENT DATE
08/14/2014

DUE DATE
09/14/2014

SITE NAME	Mt. San Antonio College - 3000209122
SERVICE LOCATION	1100 N Grand Ave Walnut, CA 91789-1341
SCE ACCOUNT ID	3000209122
INVOICE ID	0016809982-0001
kWh	1,376,264.00
SERVICE PERIOD	07/11/2014 to 08/10/2014
PRODUCT	Fixed Price Solutions



METER NO(S). V345N-001221

Contract Charges

Energy Charge Non TOU 1,376,264.00 kWh at 0.0547320 \$/kWh \$75,325.68

Service Charge \$49.00

Subtotal Contract Charges **\$75,374.68**

Market Charges

Capacity Charge \$/kW Day 07/11/2014 - 07/31/2014 (NCP 3,880 kW x 21 Days x Capacity Price) 81,479.96 kW Days at 0.0301459 \$/kW Days \$2,456.29

Capacity Charge \$/kW Day 08/01/2014 - 08/10/2014 (NCP 3,168 kW x 10 Days x Capacity Price) 31,679.96 kW Days at 0.0501659 \$/kW Days \$1,589.25

Basis Charge 1,443,759.69 kWh at 0.0019888 \$/kWh \$2,871.34

Renewable Portfolio Standards Cost Charge 07/11/2014 - 07/31/2014 1,036,544.00 kWh at 0.0050000 \$/kWh \$5,182.72

Renewable Portfolio Standards Cost Charge 08/01/2014 - 08/10/2014 339,720.00 kWh at 0.0050000 \$/kWh \$1,698.60

Ancillary Services Charge 07/11/2014 - 07/31/2014 1,036,544.00 kWh at 0.0009094 \$/kWh \$942.63

Ancillary Services Charge 08/01/2014 - 08/10/2014 339,720.00 kWh at 0.0009700 \$/kWh \$329.53

Subtotal Market Charges **\$15,070.36**

Subtotal Charges from Constellation NewEnergy **\$90,445.04**

Charges from Taxes

ENERGY SURCHARGE 1,376,264.00 kWh at 0.0002900 \$399.12

Subtotal Charges from Taxes **\$399.12**

Total Amount Due To Constellation NewEnergy **\$90,844.16**

Adjustments: Any adjustments that were made to your account within the invoice period. Adjustments may be made for a variety of reasons, including special contract calculations, corrections to prior bills, or settlement of disputed charges.

Administration Fee or Service Charge: The fee or charge set forth for each account per billing cycle.

Ancillary Service Charges: charges regarding ancillary services as set forth in the applicable Independent Service Operator (ISO) Open Access Transmission Tariff (OATT) and for other ISO costs not included in the definition of Capacity Costs, Energy Costs, and Transmission Costs. Generally, these costs are associated with ensuring the reliability of the electrical grid.

Capacity Charge: Charge for fulfilling the capacity requirements for the Account(s) imposed by the ISO or otherwise. Generally, these costs are associated with ensuring there is enough generating capacity available now and in the future to meet customer requirements.

Energy Charge - Non-Time of Use (TOU): Charge per kWh for electricity supplied for all hours of each day.

Kilowatt Hour (kWh): A measure of the quantity of electricity (energy) that you use.

Late Fees or Finance Charges: Additional charges assessed to accounts for late payment of invoices. Payment terms and charge calculations are specified in your contract.

Line Loss Charges: The cost associated with the loss of electricity as it travels over the transmission and distribution wires.

Locational Forward Reserves (LFR): Ancillary service administered by the ISO that facilitates the availability of generating units in the future to provide backup reserve service to ensure system reliability.

Reliability Must Run (RMR): Ancillary service administered by the ISO. Generation resources scheduled to operate out-of-merit order and identified by the ISO as necessary to preserve regional system reliability.

Renewable Portfolio Standards Cost (RPS): NewEnergy's cost of procuring renewable energy to comply with Renewable Portfolio Standards (RPS) requirements, usually established by individual states. Generally, these costs are associated with requirements to support generating units that produce power using renewable fuels such as water (hydro-electric) and solar.

Retail Service Charge: A contracted charge for supplying electricity to an account, based upon total kWh consumption per billing cycle.

Retail Trade Transaction (RTT): The fixed unit Price and Quantity for a specific commodity for a specific delivery point and pattern.

Transmission Service Charge: The charge for Network Transmission Service as identified in the applicable OATT Tariff for the provision of transmission service by the ISO within the Utility's service territory. Generally, these costs are associated with building and maintaining the electric transmission lines.

Disputed Invoices: Should you question any portion of your Constellation NewEnergy invoice, please call 888-635-0827 Monday to Friday 7AM-7PM Central Time, email CNECustomerCare@constellation.com, or write to: Constellation NewEnergy, c/o Customer Care, PO Box 4911 Houston, TX 77210-4911.

If you have a billing dispute that you are not able to resolve with Constellation NewEnergy you may file a complaint with the California Public Utilities Commission (CPUC). The CPUC can be reached by phone at 800-848-5580 or you may visit their website at www.cpuc.ca.gov.

In the event of a service interruption or electric emergency, please contact your utility directly at:

Pacific Gas & Electric	800-743-5002
San Diego Gas & Electric	800-611-7343
Southern California Edison	800-655-4555

DISCLAIMER: General Understanding - This glossary is for informational purposes only. Please refer to your agreement with us for the defined terms that govern the contractual obligations applicable to us supplying you. Not all defined terms set forth above may be applicable to your agreement with Constellation NewEnergy.

PLEASE RETURN THIS PORTION WITH PAYMENT AND MAKE ALL CHECKS PAYABLE TO Constellation NewEnergy, Inc.

If the billing address is incorrect, please fax the new complete
billing address to (877) 243-4968.

REMITTANCE ADDRESS:
Constellation NewEnergy, Inc.
14217 Collections Center Dr.
Chicago, IL 60693

4/11/14 MLL-Bucky



P.O. Box 300
Rosemead, CA
91772-0001
www.sce.com

Go paperless at www.sce.com/ebilling. It's fast, easy and secure.

MT SAN ANTONIO COLLEGE / Page 1 of 10

For billing and service inquiries call 1-800-799-4723,
Mon - Fri 7 a.m. to 7 p.m. and Saturday 8 a.m. to 5 p.m.
For emergency services call 24 hrs a day, 7 days a week


Date bill prepared: Sep 3 '14

Customer account 2-19-986-3549

1100 N GRAND AVE
WALNUT, CA 91789-1341

Your account summary

Amount of your last bill	\$95,697.79
Payment we received on Aug 22 '14 - thank you	-\$95,697.79
Balance forward	\$0.00
Your new charges	\$105,568.23
Total amount you owe by Oct 23 '14	\$105,568.23



Summary of your billing detail

Service account	Service address	Billing period	Your rate	New charges
3-000-2091-22	1100 N GRAND AVE WALNUT, CA	Dec 12 '11 to Jan 11 '12	TOU-8-B-STANDBY (Direct Access)	-\$20.52
Billing adjustment				
3-000-2091-22	1100 N GRAND AVE WALNUT, CA	Jan 11 '12 to Feb 9 '12	TOU-8-B-STANDBY (Direct Access)	-\$52.88
Billing adjustment				
3-000-2091-22	1100 N GRAND AVE WALNUT, CA	Feb 9 '12 to Mar 12 '12	TOU-8-B-STANDBY (Direct Access)	-\$65.35
Billing adjustment				
3-000-2091-22	1100 N GRAND AVE WALNUT, CA	Mar 12 '12 to Apr 9 '12	TOU-8-B-STANDBY (Direct Access)	-\$53.50
Billing adjustment				
3-000-2091-22	1100 N GRAND AVE WALNUT, CA	Apr 9 '12 to May 9 '12	TOU-8-B-STANDBY (Direct Access)	-\$57.78
Billing adjustment				
3-000-2091-22	1100 N GRAND AVE WALNUT, CA	May 9 '12 to Jun 8 '12	TOU-8-B-STANDBY (Direct Access)	-\$66.58
Billing adjustment				
3-000-2091-22	1100 N GRAND AVE WALNUT, CA	Jun 8 '12 to Jul 10 '12	TOU-8-B-STANDBY (Direct Access)	-\$40.83
Billing adjustment				
3-000-2091-22	1100 N GRAND AVE WALNUT, CA	Jul 10 '12 to Aug 8 '12	TOU-8-B-STANDBY (Direct Access)	-\$46.90
Billing adjustment				

(Continued on next page)

(14-574) Tear here

Please return the payment stub below with your payment and make your check payable to Southern California Edison.
If you want to pay in person, call 1-800-747-8908 for locations, or you can pay online at www.sce.com.

Tear here



Customer account 2-19-986-3549
Please write this number on your check. Make your
check payable to Southern California Edison.

Amount due by Oct 23 '14	\$105,568.23
Amount enclosed	\$ []

STMT 09032014 P5

MT SAN ANTONIO COLLEGE
1100 N GRAND AVE
WALNUT, CA 91789-1341

P.O. BOX 300
ROSEMEAD, CA 91772-0001

19 986 3549 00000026 00000000010556823010556823

Go paperless at www.sce.com/ebilling. It's fast, easy and secure.



An EDISON INTERNATIONAL® Company

Go paperless at www.sce.com/ebilling. It's fast, easy and secure.

MT SAN ANTONIO COLLEGE / Page 5 of 10

Service account 3-000-2091-22
Service address 1100 N GRAND AVE
 WALNUT, CA 91789

Rotating outage Group N001

Compare the electricity you are using

For meter V345N-001221 from Jul 11 '14 to Aug 11 '14

Total electricity you used this month in kWh


1,376,264

Your next billing cycle will end on or about Sep 10 '14.

	Electricity (kWh)	Demand (kW)	
Summer Season			
On peak	333,856	4,032	(Jul 30 '14 14:00 to 14:15)
Mid peak	411,936	3,776	(Jul 15 '14 11:15 to 11:30)
Off peak	630,472	3,168	(Jul 30 '14 07:15 to 07:30)
Total	1,376,264		

Reactive usage is 451,128 kVarh
 Maximum demand is 4,032 kW
 Standby demand is 1,430 kW
 Reactive demand is 1,312 kVar

Your daily average electricity usage (kWh)



Usage comparison

	Jul '12	Jul '13	Aug '13	Sep '13	Oct '13	Nov '13	Dec '13	Jan '14	Feb '14	Mar '14	Apr '14	May '14	Jun '14	Jul '14
Total kWh used	1,118,656	1,196,944	1,658,424	1,635,528	1,727,008	1,721,544	1,142,312	1,434,352	1,569,512	1,329,800	1,392,440	1,742,088	1,411,400	1,376,264
Number of days	29	29	32	29	30	33	31	31	30	30	31	30	30	31
Appx. average kWh used/day	38,574	41,273	51,825	56,397	57,566	52,168	36,848	46,269	52,317	44,326	44,917	58,069	47,046	44,395

Details of your new charges

Your rate: TOU-8-S DBP (Direct Access)

Billing period: Jul 11 '14 to Aug 11 '14 (31 days)

Delivery charges

Facilities rel demand	2,602 kW x \$13.71000
Energy-Summer	
On peak	333,856 kWh x \$0.02009
Mid peak	411,936 kWh x \$0.02009
Off peak	630,472 kWh x \$0.02009
Customer charge	
Power factor adj	1,312 kVar x \$0.51000
Standby charges	
Capacity reservation charge	

\$35,673.42

Your Delivery charges include:

- \$11,633.70 transmission charges
- \$39,736.12 distribution charges
- -\$591.79 nuclear decommissioning charges
- \$13,239.66 public purpose programs charge
- \$10,280.69 new system generation charge

Direct Access cost responsibility surcharge *

DA CRS DWR bond	1,376,264 kWh x \$0.00513
PCIA	1,376,264 kWh x \$0.01098
CTC	1,376,264 kWh x -\$0.00135

\$7,060.23

\$15,111.38

-\$1,857.96

Your overall energy charges include:

- \$860.37 franchise fees

(Continued on next page)

(Continued on next page)

Appendix B - Mt San Antonio TES Schedule and Site Plan

PROPOSED BUILDINGS SCHEDULE

RY / CAMPUS CENTER	A
NESS & COMPUTER TECHNOLOGY	B
ETIC CONCESSIONS & RESTROOMS	D
ER & TECHNICAL BLDG. RENOVATION	E
SRoom BUILDING RENOVATION	F2
RATORY BLDG EXPANSION	G
ING STRUCTURE	J
ING 9A RENOVATION	L7-A
O SERVICE	L7-C2
UAGE LAB EXPANSION	L7-C3
ENT SUPPORT SERVICES	L7-C8
RE INSTRUCTIONAL BLDG ZONE	1
TORIUM ZONE	3
RE INSTRUCTIONAL BLDG ZONE	4-6

EXISTING BUILDINGS

CENTER	I A/B
GALLERY/CLASSROOMS	I B/C
FORMING ARTS CENTER	2
ENTER/GYM	3
INISTRATION	4
ARNING TECHNOLOGY CENTER	6
FORMATION KIOSK	6A
URAL SCIENCES	7
PUS CAFE	8
ILIARY SERVICES	9A


Project Title

MT SAC TES INCENTIVE

Mt. San Antonio College
1100 N. Grand Avenue
Walnut, CA 91789

MT. SAC
Mt. San Antonio College

Phone: (909) 594-5611
Web: www.mtsac.edu



Revisions		
Number	Description	Date

Designed	M. AMALFITANO
Drawn	E. ORTIZ
Checked	M. AMALFITANO
Approved	
Date	9/30/2014

Submittal


Scale NO SCALE

Sheet Title

SCHEMATIC DIAGRAM



Sheet Number


M001





COLLEGE LOAD





MARK	MANUFACTURER & MODEL	LOCATION	TYPE	SERVICE	CAPACITY TONS	VSD	NPLV	REFRIGERANT		COMPRESSOR					EVAPORATOR				CONDENSOR				SHIPPING WEIGHT LBS	OPERATING WEIGHT LBS	REMARKS	ANCHORAGE				
								TYPE	CHARGE LBS	VOLTAGE	PHASE	HERTZ	INPUT KW	KW/TON	R/LA/MCA/MOC P	NOM. GPM MAX.	GPM MIN.	EWT °F	LWT °F	PASS	PD PSID	FOULING FACTOR	GPM	EWT °F	LWT °F	PASS	PD PSID	FOULING FACTOR		
(E) CH-2	TRANE CWF-077	CENTRAL PLANT	CENTRIFUGAL	CAMPUS	750	YES	.3913	R-123	1400	480	3	-	-	-	605 / 1200	1800	51.0	41	-	31.6	-	1500	83.0	97.0	-	17.0	-	32421		
(E) CH-3	TRANE CWF-077	CENTRAL PLANT	CENTRIFUGAL	CAMPUS	750	YES	.3913	R-123	1400	480	3	-	-	-	605 / 1200	1800	51.0	41	-	31.6	-	1500	83.0	97.0	-	17.0	-	32421		
(E) CH-1 (BUILDING 2)	SMARDT WA095.2HXX.22N	RM-206	CENTRIFUGAL	BLDG-2 / CAMPUS	250	YES	-	134A	695	480	3	60	146.0	0.586	218/270/350	398 1000 280	44	59	2	1.70	0.00010	750	85	95	2	4.06	0.00025	8030	9930	
(E) CH-2 (BUILDING 2)	SMARDT WA095.2HXX.22N	RM-206	CENTRIFUGAL	BLDG-2 / CAMPUS	250	YES	-	134A	695	480	3	60	146.0	0.586	218/270/350	398 1000 280	44	59	2	1.70	0.00010	750	85	95	2	4.06	0.00025	8030	9930	
CH-4	TRANE CWF-077	CENTRAL PLANT	CENTRIFUGAL	CAMPUS	750	YES	.3913	R-123	1400	480	3	-	-	-	605 / 1200	1800	51.0	41	-	31.6	-	1500	83.0	97.0	-	17.0	-	32421		

THERMAL ENERGY STORAGE TANK											
MARK	MANUFACTURER	LOCATION	TYPE	SERVICE	TANK CAPACITY (TONS/HOURS)	TANK VOLUME (GALLONS)	TANK HEIGHT (FT)	TANK DIAMETER (FT)	EWT (°F)	LWT (°F)	REMARKS
TES-1	DN TANKS	PARKING LOT	PARTIALLY BURIED	CHILLED WATER DISTRIBUTION	20.000	1,600,000	80	45	60	40	

CHILLED WATER PUMPS														
MARK	MANUFACTURER & MODEL	LOCATION	TYPE	SERVICE	DESIGN POINT		MOTOR			OPERATING WEIGHT LBS	REMARKS	ANCHORAGE DETAIL		
					FLOW GPM	HEAD FT HD	HP	V/P/H	RPM					
(E) CHWP-11	VELL & GOSSETT VS CS 10X12X17	CENTRAL PLANT	CENTRIFUGAL	CAMPUS CHILLED WATER	3000	230	200	460 / 3	1770	2800				
(E) CHWP-12	VELL & GOSSETT VS CS 10X12X17	CENTRAL PLANT	CENTRIFUGAL	CAMPUS CHILLED WATER	3000	230	200	460 / 3	1770	2800				
(E) CHWP-1	ARMSTRONG 4300-6X6X13	BUILDING 2	VERTICAL SPLIT COUPLED	CAMPUS CHILLED WATER	560	65	20	460 / 3	1200	680				
(E) CHWP-2	ARMSTRONG 4300-6X6X13	BUILDING 2	VERTICAL SPLIT COUPLED	CAMPUS CHILLED WATER	560	65	20	460 / 3	1200	680				
(E) CHWP-3	ARMSTRONG 4300-6X6X13	BUILDING 2	VERTICAL SPLIT COUPLED	CAMPUS CHILLED WATER	500	100	30	460 / 3	1800	650				
(E) CHWP-4	ARMSTRONG 4300-6X6X13	BUILDING 2	VERTICAL SPLIT COUPLED	CAMPUS CHILLED WATER	500	100	30	460 / 3	1800	650				
CHWP 1	ARMSTRONG 4300 8X8X13	CENTRAL PLANT	CENTRIFUGAL	CAMPUS CHILLED WATER	1800	40	40	460/3	1800	800				
CHWP 2	ARMSTRONG 4300 8X8X13	CENTRAL PLANT	CENTRIFUGAL	CAMPUS CHILLED WATER	1800	40	40	460/3	1800	800				
CHWP 3	ARMSTRONG 4300 8X8X13	CENTRAL PLANT	CENTRIFUGAL	CAMPUS CHILLED WATER	1800	40	40	460/3	1800	800				
CHWP 4	ARMSTRONG 4300 8X8X13	CENTRAL PLANT	CENTRIFUGAL	CAMPUS CHILLED WATER	1800	40	40	460/3	1800	800				
(E) CHWP-13	VELL & GOSSETT VS CS 10X12X17	CENTRAL PLANT	CENTRIFUGAL	CAMPUS CHILLED WATER	3000	230	200	460 / 3	1770	2800				

Appendix C - Mt San Antonio College Load Profile

Building #	BUILDING NAME	BUILDING USE	AREA (SF)	SCHEDULED COMPLETION	ESTIMATED LOAD (TONS)	Calculated TRACE LOAD (TONS)	Calculated SF/ton
Existing							
1A	Art Center	Classrooms	16,700	1971		60.4	276
1 B/C	Art Studio Complex	Classrooms	16,136			73.4	220
2B	Fedderson Recital Hall	Theater/Music Hall	63,361	2003 Expansion		192.6	329
4	Administration	Offices	41,693	1963		113.1	369
6	Learning Technology Center	Offices	101,784	1997		249.4	408
7	Science South	Classrooms/Labs	37,226	-		297.8	125
9B	Student Services	Offices	51,369	2006 Reno.		117.8	436
11	Science North	Classrooms/Labs	18,939	-		107.5	176
12	Building 12 Renovation	Classroom	13,000	2014		49.4	263
13	Design Technology	Classroom	62,000	2012		162.7	381
26	Humanities/Social Sciences	Classrooms	98,320			358.2	274
29	Central Plant	Office	148	2003		1.0	148
60	Science	Labs	62,982	2006		248.8	253
61	Math & Sciences	Classrooms/Labs	64,139	2006		210.7	304
66	Language Center	Classrooms	43,911	2003 Reno.		122.6	358
67A	Health Careers	Classroom	31,768	2003 Reno.		89.9	353
67B	Student Health	Offices	10,995	2003 Reno.		33.0	333
70-73	Early Childhood Education Center	Children Center	36,012	2013		99.0	364
80	Agriculture Science Building	Lab	51,100	2012		213.4	239
Totals						2801	295

2015							
9A	Food Services	Food Service/Dining	12,000	2015		51.8	
9B Add.	Student Support Services	Offices	16,056	2015		53.1	302
	Business and Technology Center	Classroom/Comp. Lab	87,000	2015		365.0	238
Totals						470	296

Phase 2							
	Athletics Phase 1		45,000	2016	240		188
	Library/Campus Center	Library	217,200	2017-2019	543		400
	Classroom Building Renovation	Classroom	101,400	2017-2019	254		399
	Language Lab Expansion	Labs	15,000	2017-2019	38		395
	Building 9A Renovation	Food Service/Dining	21,300	2017-2019	53		402
	Building 40 Continuing Education Remodel	Classroom	24,440	2017-2019	61		401
	Athletics Phase 2	Athletics	50,000	2017-2019	260		192
Totals						1449	399

Phase 3							
	Future Instruction Building Zone	Classroom	50,000	2020	125		400
	Auditorium Zone	Auditorium	12,000	2020	30		400
	Future Instruction Building Zone	Classroom	75,000	2025	188		399
	Future Instruction Building Zone	Classroom	100,000	2025	250		400
Totals						593	400

9/15/2014	CHWS	CHWR	FM4 PInt Raw GPM	FM1 PInt Raw GPM	BTUH	CP TONNAGE	Bldg 2 Tonnage	TOTAL
12:00 AM	40	49.1	453	975	6,497,400	541	181	723
1:00 AM	40	49.4	371.9	1,130.10	7,059,400	588	143	731
2:00AM	40	50.5	242	1,077.80	6,928,950	577	150	728
3:00 AM	40	50.5	203.4	1,059.60	6,630,750	553	134	687
4:00 AM	40	50.6	190.6	1,234.90	7,555,150	630	141	771
5:00 AM	40	52.6	170.5	1,333.60	9,475,830	790	181	971
6:00 AM	40	53.8	187.6	1,525.20	11,818,320	985	325	1,310
7:00 AM	40	52.2	206.4	1,958.20	13,204,060	1,100	181	1,281
8:00 AM	40	52.6	297.8	1,930.00	14,035,140	1,170	167	1,337
9:00 AM	40	53	326.4	2,121.40	15,910,700	1,326	150	1,476
10:00 AM	40	54.1	422	2,125.40	17,959,170	1,497	163	1,660
11:00 AM	42	55.4	407.5	2,314.70	18,238,740	1,520	358	1,878
12:00 PM	44	56.6	418.7	2,433.60	17,969,490	1,497	353	1,850
1:00 PM	46	58.3	501.2	2,518.40	18,570,540	1,548	404	1,951
2:00 PM	48	60.4	583.6	2,522.50	19,257,820	1,605	414	2,019
3:00 PM	50	64.2	552.6	2,633.20	22,619,180	1,885	426	2,311
4:00 PM	48	61	562.5	2,574.80	20,392,450	1,699	423	2,123
5:00 PM	46	59	496.2	2,506.30	19,516,250	1,626	416	2,042
6:00 PM	43	56.3	423.3	2,417.50	18,891,320	1,574	344	1,918
7:00 PM	40	54	422	2,183.80	18,240,600	1,520	292	1,812
8:00 PM	40	54	370.6	1,930.00	16,104,200	1,342	222	1,564
9:00 PM	40	53.6	366.3	1,889.70	15,340,800	1,278	199	1,477
10:00 PM	40	52.4	246	1,766.90	12,479,980	1,040	180	1,220
11:00 PM	45	51.9	16.5	751.4	2,649,255	221	133	354

System Checksums

By P2S Engineering, Inc

AH1

Variable Volume Reheat (30% Min Flow Default)

COOLING COIL PEAK								CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES		
Peaked at Time:		Mo/Hr: 7 / 15		Mo/Hr: 10 / 16		Mo/Hr: Heating Design		Space Peak		Coil Peak Percent		Space Sens		Cooling	Heating			
Outside Air:		OADB/WB/HR: 95 / 71 / 78		OADB: 93		OADB: 30		Space Peak		Coil Peak Percent		Tot Sens Of Total						
	Space Sens. + Lat.	Plenum Sens. + Lat		Net Total	Percent Of Total		Space Sensible	Percent Of Total				Btu/h	(%)					
	Btu/h	Btu/h		Btu/h	(%)		Btu/h	(%)										
Envelope Loads																		
Skylite Solar	0	0		0	0		0	0										
Skylite Cond	0	0		0	0		0	0										
Roof Cond	0	20,321		20,321	2		0	0										
Glass Solar	7,902	0		7,902	1		16,426	6										
Glass/Door Cond	4,493	0		4,493	1		4,370	2										
Wall Cond	8,620	6,651		15,271	2		11,346	4										
Partition/Door	2,484			2,484	0		2,725	1										
Floor	0			0	0		0	0										
Adjacent Floor	0	0		0	0		0	0										
Infiltration	0			0	0		0	0										
<i>Sub Total ==></i>	<i>23,499</i>	<i>26,972</i>		<i>50,471</i>	<i>6</i>		<i>34,868</i>	<i>12</i>										
Internal Loads																		
Lights	21,057	5,264		26,321	3		21,057	7										
People	153,450	0		153,450	18		85,250	30										
Misc	13,471	0		13,471	2		13,471	5										
<i>Sub Total ==></i>	<i>187,978</i>	<i>5,264</i>		<i>193,242</i>	<i>23</i>		<i>119,778</i>	<i>42</i>										
Ceiling Load																		
Ventilation Load	3,691	-3,691		0	0		3,475	1										
Adj Air Trans Heat	0	0		584,952	70		0	0										
Dehumid. Ov Sizing	0			0	0		0	0										
Ov/Undr Sizing	3,318			3,318	0		125,984	44										
Exhaust Heat	-28,545	-28,545		-3														
Sup. Fan Heat				35,320	4													
Ret. Fan Heat	0	0		0	0													
Duct Heat Pkup	0	0		0	0													
Underflr Sup Ht Pkup	0			0	0													
Supply Air Leakage	0	0		0	0													
<i>Grand Total ==></i>	<i>218,486</i>	<i>0</i>		<i>838,759</i>	<i>100.00</i>		<i>284,105</i>	<i>100.00</i>										
COOLING COIL SELECTION								AREAS				HEATING COIL SELECTION						
Total Capacity	ton	MBh	Sens Cap.	Coil Airflow	Enter DB	WB/HR	Leave DB	WB/HR	Gross Total	Glass ft ²	(%)	Capacity MBh	Coil Airflow cfm	Ent °F	Lvg °F			
Main Clg	69.9	838.8	570.2	15,685	95.0	70.5	78.2	52.9	52.8	62.3		Main Htg	-102.7	4,706	52.9	73.4		
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0		Aux Htg	0.0	0	0.0	0.0		
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0		Preheat	-382.5	15,685	30.0	52.9		
<i>Total</i>	<i>69.9</i>	<i>838.8</i>											Reheat	<i>-75.8</i>	<i>4,706</i>	<i>52.9</i>	<i>68.0</i>	
													Humidif	0.0	0	0.0	0.0	
													Opt Vent	0.0	0	0.0	0.0	
													<i>Total</i>	<i>-485.2</i>				

System Checksums

By P2S Engineering, Inc

AH2

Variable Volume Reheat (30% Min Flow Default)

COOLING COIL PEAK								CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES		
Peaked at Time:		Mo/Hr: 7 / 15		Mo/Hr: 8 / 16		Mo/Hr: Heating Design		Space Peak		Coil Peak Percent		Space Sens		Cooling	Heating			
Outside Air:		OADB/WB/HR: 95 / 71 / 78		OADB: 96		OADB: 30		Space Peak		Tot Sens Of Total		Btu/h	Btu/h	SADB	78.8			
	Space Sens. + Lat.	Plenum Sens. + Lat		Net Total	Percent Of Total		Space Sensible	Percent Of Total						Ra Plenum	66.0			
	Btu/h	Btu/h		Btu/h	(%)		Btu/h	(%)						Return	66.0			
Envelope Loads														Ret/OA	37.0			
Skylite Solar	0	0		0	0		0	0						Fn MtrTD	0.0			
Skylite Cond	0	0		0	0		0	0						Fn BldTD	0.0			
Roof Cond	0	25,869		25,869	4		0	0						Fn Frict	0.0			
Glass Solar	18,669	0		18,669	3		26,932	6										
Glass/Door Cond	7,002	0		7,002	1		5,909	1										
Wall Cond	15,462	11,571		27,032	4		19,851	5										
Partition/Door	8,114			8,114	1		9,079	2										
Floor	0			0	0		0	0										
Adjacent Floor	0	0		0	0		0	0										
Infiltration	0			0	0		0	0										
<i>Sub Total ==></i>	<i>49,247</i>	<i>37,440</i>		<i>86,687</i>	<i>13</i>		<i>61,770</i>	<i>14</i>										
Internal Loads																		
Lights	46,802	9,567		56,369	9		46,802	11										
People	183,825	0		183,825	28		102,808	24										
Misc	18,164	0		18,164	3		18,164	4										
<i>Sub Total ==></i>	<i>248,791</i>	<i>9,567</i>		<i>258,358</i>	<i>39</i>		<i>167,774</i>	<i>39</i>										
Ceiling Load	6,374	-6,374		0	0		6,113	1										
Ventilation Load	0	0		234,120	36		0	0										
Adj Air Trans Heat	0			0	0		0	0										
Dehumid. Ov Sizing				0	0													
Ov/Undr Sizing	0			0	0		196,522	45										
Exhaust Heat	-14,032	-14,032		-2														
Sup. Fan Heat				77,766	12													
Ret. Fan Heat	14,139	14,139		2														
Duct Heat Pkup	0	0		0	0													
Underflr Sup Ht Pkup				0	0													
Supply Air Leakage	0	0		0	0													
<i>Grand Total ==></i>	<i>304,412</i>	<i>40,741</i>		<i>657,038</i>	<i>100.00</i>		<i>432,180</i>	<i>100.00</i>										
COOLING COIL SELECTION								AREAS				HEATING COIL SELECTION						
Total Capacity	ton	MBh	Sens Cap.	Coil Airflow	Enter DB	WB/HR	Leave DB	WB/HR	Gross Total	Glass ft ²	(%)	Capacity	Coil Airflow	Ent °F	Lvg °F			
Main Clg	54.8	657.0	494.0	23,860	79.5	62.9	63.4	51.9	51.9	60.1		MBh	cfm					
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	3,250			Main Htg	7,158	51.9	78.8			
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0	0.0		Aux Htg	0.0	0.0	0.0			
<i>Total</i>	<i>54.8</i>	<i>657.0</i>										Preheat	-144.4	6,178	30.0	51.9		

System Checksums

By P2S Engineering, Inc

AH3

Variable Volume Reheat (30% Min Flow Default)

COOLING COIL PEAK						CLG SPACE PEAK						HEATING COIL PEAK						TEMPERATURES		
Peaked at Time:		Mo/Hr: 7 / 15				Mo/Hr: 10 / 15		Mo/Hr: Heating Design				SADB	55.0	72.8	Ra Plenum	73.6	66.0			
Outside Air:	OADB/WB/HR:	95 / 71 / 78	OADB:	94	OADB:	30	SADB	55.0	72.8	Ra Plenum	73.6	66.0	Return	73.6	66.0	Ret/OA	95.0	30.0		
Space Sens. + Lat.	Btu/h	Plenum Sens. + Lat	Btu/h	Net Total	Percent Of Total (%)	Space Sensible	Btu/h	Percent Of Total (%)	Space Peak	Coil Peak	Percent Tot Sens Of Total (%)	Space Sens	Btu/h	Coil Peak	Percent Tot Sens Of Total (%)	Cooling	Heating			
Envelope Loads																				
Skylite Solar	0	0	0	0	0	0	0	0	Skylite Solar	0	0	0.00	Skylite Cond	0	0	0.00				
Skylite Cond	0	0	0	0	0	0	0	0	Skylite Cond	0	0	0.00	Roof Cond	0	-8,270	1.80				
Roof Cond	0	15,654	15,654	2		0	0	0	Roof Cond	0	-8,270	1.80	Glass Solar	0	0	0.00				
Glass Solar	5,655	0	5,655	1		10,269	4		Glass Solar	0	0	0.00	Glass/Door Cond	-6,948	-6,948	1.52				
Glass/Door Cond	3,460	0	3,460	0		3,363	1		Glass/Door Cond	-6,948	-6,948	1.52	Wall Cond	-9,585	-16,397	3.58				
Wall Cond	10,105	7,290	17,394	2		14,220	5		Wall Cond	-9,585	-16,397	3.58	Partition/Door	-402	-402	0.09				
Partition/Door	175		175	0		217	0		Partition/Door	-402	-402	0.09	Floor	0	0	0.00				
Floor	0		0	0		0	0		Floor	0	0	0.00	Adjacent Floor	0	0	0				
Adjacent Floor	0	0	0	0		0	0		Adjacent Floor	0	0	0	Infiltration	0	0	0.00				
Infiltration	0		0	0		0	0		Infiltration	0	0	0.00	Sub Total ==>	-16,935	-32,016	6.98				
Sub Total ==>	19,395	22,944	42,339	5		28,068	10		Sub Total ==>	-16,935	-32,016	6.98								
Internal Loads									Internal Loads											
Lights	25,273	6,182	31,454	4		25,273	9		Lights	0	0	0.00	People	0	0	0.00				
People	207,968	0	207,968	24		115,538	43		People	0	0	0.00	Misc	0	0	0.00				
Misc	27,714	0	27,714	3		27,714	10		Misc	0	0	0.00	Sub Total ==>	0	0	0.00				
Sub Total ==>	260,954	6,182	267,135	31		168,524	62		Sub Total ==>	0	0	0.00								
Ceiling Load	4,535	-4,535	0	0		4,079	2		Ceiling Load	-5,742	0	0.00								
Ventilation Load	0	0	542,759	63		0	0		Ventilation Load	0	-181,226	39.52								
Adj Air Trans Heat	0		0	0		0	0		Adj Air Trans Heat	0	0	0								
Dehumid. Ov Sizing			0	0					Ov/Undr Sizing	0	0	0.00								
Ov/Undr Sizing	434		434	0		69,577	26		Exhaust Heat	9,340	-2.04									
Exhaust Heat	-24,590	-24,590	-24,590	-3					OA Preheat Diff.	-254,679	55.54									
Sup. Fan Heat			33,598	4					RA Preheat Diff.	0	0.00									
Ret. Fan Heat	0	0	0	0					Additional Reheat	0	0.00									
Duct Heat Pkup	0	0	0	0					Underflr Sup Ht Pkup	0	0.00									
Underflr Sup Ht Pkup			0	0					Supply Air Leakage	0	0.00									
Supply Air Leakage	0	0	0	0																
Grand Total ==>	285,318	0	861,674	100.00		270,248	100.00		Grand Total ==>	-22,676	-458,581	100.00								

COOLING COIL SELECTION						AREAS						HEATING COIL SELECTION								
Total Capacity		Sens Cap.		Coil Airflow		Enter DB		WB		HR		Leave DB		WB		HR				
ton		MBh		MBh		cfm		°F		°F		gr/lb		°F		gr/lb				
Main Clg	71.8	861.7	592.3	14,920	95.0	70.5	78.2	52.9	52.1	59.3		Floor	9,253			Main Htg	-94.8	4,476	52.9	72.8
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0		Part	71			Aux Htg	0.0	0	0.0	0.0
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0		Int Door	0			Preheat	-363.8	14,920	30.0	52.9
Total	71.8	861.7										ExFlr	0			Reheat	-72.1	4,476	52.9	68.0
												Roof	5,779	0	0	Humidif	0.0	0	0.0	0.0
												Wall	3,540	234	7	Opt Vent	0.0	0	0.0	0.0
												Ext Door	0	0	0	Total	-458.6			

System Checksums

By P2S Engineering, Inc

Bldg 70

Variable Volume Reheat (30% Min Flow Default)

COOLING COIL PEAK								CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES		
Peaked at Time:		Mo/Hr: 9 / 16		Mo/Hr: 9 / 16		Mo/Hr: 9 / 16		Mo/Hr: Heating Design		Mo/Hr: 28		Space Peak		Coil Peak Percent		Cooling	Heating	
Envelope Loads	Outside Air:	OADB/WB/HR: 96 / 70 / 67		OADB: 96								Space Sens	Sens Of Total	Tot Sens	Of Total	SADB	Ra Plenum	
		Space Sens. + Lat.	Plenum Sens. + Lat			Net Total	Percent Of Total (%)					Btu/h	Btu/h	Btu/h	(%)			
Skylite Solar		0	0			0	0					0	0					
Skylite Cond		0	0			0	0					0	0					
Roof Cond		0	18,583	18,583	10							0	0					
Glass Solar	18,346		0	18,346	10			18,346	14			Glass Solar		0	0	0.00		
Glass/Door Cond	3,271		0	3,271	2			3,271	2			Glass/Door Cond	-6,016	-6,016	5.14			
Wall Cond	4,322	766		5,088	3			4,322	3			Wall Cond	-8,365	-11,165	9.54			
Partition/Door	0			0	0			0	0			Partition/Door	0	0	0.00			
Floor	15,509			15,509	8			15,509	12			Floor	-24,238	-24,238	20.71			
Adjacent Floor	0		0	0	0			0	0			Adjacent Floor	0	0	0			
Infiltration	8,387			8,387	4			7,532	6			Infiltration	-13,456	-13,456	11.50			
Sub Total ==>	49,835		19,349	69,183	37			48,979	36			Sub Total ==>	-52,075	-65,715	56.16			
Internal Loads																		
Lights	21,110	5,278		26,388	14			21,110	16			Lights	0	0	0.00			
People	29,538	0		29,538	16			14,349	11			People	0	0	0.00			
Misc	25,693	0		25,693	14			25,693	19			Misc	0	0	0.00			
Sub Total ==>	76,341	5,278		81,619	43			61,152	45			Sub Total ==>	0	0	0.00			
Ceiling Load																		
Ceiling Load	24,626	-24,626		0	0			24,626	18			Ceiling Load	-13,640	0	0.00			
Ventilation Load	0	0		18,638	10			0	0			Ventilation Load	0	-29,901	25.55			
Adj Air Trans Heat	0			0	0			0	0			Adj Air Trans Heat	0	0	0			
Dehumid. Ov Sizing				0	0							Ov/Undr Sizing	0	0	0.00			
Ov/Undr Sizing	0			0	0			0	0			Exhaust Heat	0	0	0.00			
Exhaust Heat				0	0							OA Preheat Diff.	0	0	0.00			
Sup. Fan Heat				0	0							RA Preheat Diff.	-21,399	18.29				
Ret. Fan Heat	0			0	0							Additional Reheat	0	0.00				
Duct Heat Pkup				0	19,285	10						Underflr Sup Ht Pkup	0	0.00				
Underflr Sup Ht Pkup				0	0							Supply Air Leakage	0	0.00				
Supply Air Leakage				0	0													
Grand Total ==>	150,802	0	188,725	100.00				134,757	100.00			Grand Total ==>	-65,715	-117,015	100.00			
COOLING COIL SELECTION																		
Total Capacity	ton	MBh	Sens Cap.	MBh	Coil Airflow cfm	Enter DB °F	WB °F	HR gr/lb	Leave DB °F	WB °F	HR gr/lb	Gross Total	Glass ft ²	(%)	AREAS			
Main Clg	15.7	188.7	170.8	8,748	75.7	62.3	63.6	58.0	55.0	60.7		Floor	6,782		HEATING COIL SELECTION			
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0		Part	0		Main Htg	-94.6	2,624	58.0
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0		Int Door	0		Aux Htg	0.0	0	61.7
Total	15.7	188.7										ExFlr	6,361		Preheat	-22.4	678	28.0
												Reheat	-28.9		Reheat	-28.9	2,624	58.0
												Humidif	0.0		Humidif	0.0	0	0.0
												Opt Vent	0.0		Opt Vent	0.0	0	0.0
												Total	-117.0					

System Checksums

By P2S Engineering, Inc

Bldg 71

Single Zone Variable Air Volume

COOLING COIL PEAK								CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES		
Peaked at Time:		Mo/Hr: 9 / 16		Mo/Hr: 9 / 16		Mo/Hr: 9 / 16		Mo/Hr: Heating Design		Mo/Hr: 28		Space Peak		Coil Peak Percent		Cooling	Heating	
Outside Air:		OADB/WB/HR: 96 / 70 / 67		OADB: 96								Space Sens		Tot Sens Of Total		SADB	82.4	
	Space Sens. + Lat.	Btu/h	Plenum Sens. + Lat	Btu/h	Net Total	Percent Btu/h	Total Of Total (%)					Btu/h	(%)			Ra Plenum	62.4	
Envelope Loads								Envelope Loads								Return	68.0	
Skylite Solar	0	0		0	0	0	0	Skylite Solar	0	0	0	0	0	0		Ret/OA	33.7	
Skylite Cond	0	0		0	0	0	0	Skylite Cond	0	0	0	0	0	0		Fn MtrTD	0.0	
Roof Cond	0	21,281		21,281	7	0	0	Roof Cond	0	-12,491	6.49	0	0	0		Fn BldTD	0.0	
Glass Solar	26,357	0		26,357	8	26,357	14	Glass Solar	0	0	0	0	0	0		Fn Frict	0.0	
Glass/Door Cond	6,041	0		6,041	2	6,041	3	Glass/Door Cond	-11,111	-11,111	5.77	0	0	0				
Wall Cond	3,970	893		4,863	1	3,970	2	Wall Cond	-7,858	-10,964	5.70	0	0	0				
Partition/Door	0			0	0	0	0	Partition/Door	0	0	0	0	0	0				
Floor	17,984			17,984	6	17,984	10	Floor	-28,106	-28,106	14.60	0	0	0				
Adjacent Floor	0	0		0	0	0	0	Adjacent Floor	0	0	0	0	0	0				
Infiltration	10,777			10,777	3	9,710	5	Infiltration	-17,346	-17,346	9.01	0	0	0				
<i>Sub Total ==></i>	<i>65,128</i>			<i>87,302</i>	<i>27</i>	<i>64,061</i>	<i>34</i>	<i>Sub Total ==></i>	<i>-64,421</i>	<i>-80,018</i>	<i>41.58</i>							
Internal Loads								Internal Loads										
Lights	25,782	6,445		32,227	10	25,782	14	Lights	0	0	0	0	0	0				
People	89,251	0		89,251	28	45,901	24	People	0	0	0	0	0	0				
Misc	23,872	0		23,872	7	23,872	13	Misc	0	0	0	0	0	0				
<i>Sub Total ==></i>	<i>138,905</i>	<i>6,445</i>		<i>145,350</i>	<i>45</i>	<i>95,554</i>	<i>51</i>	<i>Sub Total ==></i>	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>				
Ceiling Load	28,620	-28,620		0	0	28,620	15	Ceiling Load	-15,597	0	0							
Ventilation Load	0	0		69,850	22	0	0	Ventilation Load	0	-112,429	58.42							
Adj Air Trans Heat	0			0	0	0	0	Adj Air Trans Heat	0	0	0							
Dehumid. Ov Sizing				0	0			Ov/Undr Sizing	0	0	0							
Ov/Undr Sizing	0			0	0			Exhaust Heat	0	0	0							
Exhaust Heat				0	0			OA Preheat Diff.	0	0	0							
Sup. Fan Heat				0	0			RA Preheat Diff.	0	0	0							
Ret. Fan Heat	0			0	0			Additional Reheat	0	0	0							
Duct Heat Pkup				0	21,854	7		Underflr Sup Ht Pkup	0	0	0							
Underflr Sup Ht Pkup				0	0			Supply Air Leakage	0	0	0							
Supply Air Leakage	0			0	0													
Grand Total ==>	232,653			0	324,356	100.00		Grand Total ==>	-80,018	-192,447	100.00							
COOLING COIL SELECTION								AREAS				HEATING COIL SELECTION				Engineering CKS		
Total Capacity	ton	MBh	Sens Cap.	Coil Airflow	Enter DB	WB	HR	Gross Total	Glass ft ²	(%)		Capacity	Coil Airflow	Ent	Lvg	Cooling	Heating	
Main Clg	27.0	324.4	273.0	9,913	79.8	63.9	64.5	54.8	52.8	57.0		MBh	cfm	°F	°F	% OA	25.7	85.7
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0		cfm/ft ²	1.13					
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0		cfm/ton	366.76					
Total	27.0	324.4						Floor	8,743							ft²/ton	323.46	
								Part	0							Btu/hr·ft²	37.10	-22.01
								Int Door	0							No. People	182	
								ExFlr	7,376									
								Roof	11,189	0	0							
								Wall	4,922	1,017	21							
								Ext Door	0	0	0					Total	-192.5	

System Checksums

By P2S Engineering, Inc

Bldg 72

Single Zone Variable Air Volume

COOLING COIL PEAK								CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES		
Peaked at Time:		Mo/Hr: 9 / 16		Mo/Hr: 9 / 15		Mo/Hr: Heating Design		Space Peak		Coil Peak Percent		Cooling		Heating				
Outside Air:		OADB/WB/HR: 96 / 70 / 67		OADB: 97		OADB: 28		Space Sens		Tot Sens Of Total		SADB	53.6	94.6				
	Space Sens. + Lat.	Plenum Sens. + Lat		Net Total	Percent Of Total			Space Sensible	Percent Of Total			Ra Plenum	77.4	63.9				
	Btu/h	Btu/h		Btu/h	(%)			Btu/h	(%)			Return	77.4	63.9				
Envelope Loads												Ret/OA	83.6	28.0				
Skylite Solar	0	0		0	0			0	0			Fn MtrTD	0.0	0.0				
Skylite Cond	0	0		0	0			0	0			Fn BldTD	0.0	0.0				
Roof Cond	0	30,050		30,050	9			0	0			Fn Frict	0.0	0.0				
Glass Solar	31,230	0		31,230	9			34,274	17									
Glass/Door Cond	7,302	0		7,302	2			7,184	4									
Wall Cond	4,618	2,740		7,358	2			4,408	2									
Partition/Door	0			0	0			0	0									
Floor	22,262			22,262	6			22,262	11									
Adjacent Floor	0	0		0	0			0	0									
Infiltration	8,214			8,214	2			7,623	4									
<i>Sub Total ==></i>	<i>73,626</i>	<i>32,790</i>		<i>106,416</i>	<i>31</i>			<i>75,752</i>	<i>39</i>									
Internal Loads																		
Lights	29,297	7,324		36,621	11			29,297	15									
People	107,910	0		107,910	31			55,154	28									
Misc	26,354	0		26,354	8			26,354	13									
<i>Sub Total ==></i>	<i>163,561</i>	<i>7,324</i>		<i>170,885</i>	<i>49</i>			<i>110,805</i>	<i>56</i>									
Ceiling Load	10,780	-10,780		0	0			10,059	5									
Ventilation Load	0	0		77,376	22			0	0									
Adj Air Trans Heat	0			0	0			0	0									
Dehumid. Ov Sizing				0	0													
Ov/Undr Sizing	0			0	0			0	0									
Exhaust Heat		-7,560		-7,560	-2													
Sup. Fan Heat				0	0													
Ret. Fan Heat		0		0	0													
Duct Heat Pkup		0		0	0													
Underflr Sup Ht Pkup				0	0													
Supply Air Leakage		0		0	0													
Grand Total ==>	247,966	21,775		347,117	100.00			196,615	100.00									
COOLING COIL SELECTION								AREAS				HEATING COIL SELECTION						
Total Capacity	ton	MBh	Sens Cap.	Coil Airflow	Enter DB	WB/HR	Leave DB	WB/HR	Gross Total	Glass ft ²	(%)	Capacity	Coil Airflow	Ent	Lvg			
Main Clg	28.9	347.1	286.1	8,657	83.6	65.2	64.8	53.6	51.7	54.7		MBh	cfm	°F	°F			
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0		Main Htg	-208.1	2,834	28.0	94.6		
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0		Aux Htg	0.0	0	0.0	0.0		
Total	28.9	347.1										Int Door	0	0	0.0	0.0		
												ExFlr	9,131	0	0.0	0.0		
												Roof	14,091	0	0	0.0		
												Wall	6,303	1,229	20	0.0		
												Ext Door	0	0	0.0	0.0		
												Total	-208.1					

System Checksums

By P2S Engineering, Inc

Bldg 73

Single Zone Variable Air Volume

COOLING COIL PEAK								CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES		
Peaked at Time:		Mo/Hr: 9 / 16		Mo/Hr: 8 / 16		Mo/Hr: Heating Design		Space Peak		Coil Peak Percent		Cooling		Heating				
Outside Air:		OADB/WB/HR: 96 / 70 / 67		OADB: 95		OADB: 28		Space Sens		Tot Sens Of Total		SADB	54.5	96.6				
	Space Sens. + Lat.	Plenum Sens. + Lat		Net Total	Percent Of Total			Space Sens	Percent Of Total			Ra Plenum	84.9	61.5				
	Btu/h	Btu/h		Btu/h	(%)			Btu/h	(%)			Return	74.0	68.0				
Envelope Loads												Ret/OA	79.4	35.9				
Skylite Solar	0	0		0	0			0	0			Fn MtrTD	0.0	0.0				
Skylite Cond	0	0		0	0			0	0			Fn BldTD	0.0	0.0				
Roof Cond	0	27,025		27,025	8			0	0			Fn Frict	0.0	0.0				
Glass Solar	20,573	0		20,573	6			18,287	8									
Glass/Door Cond	6,371	0		6,371	2			6,110	3									
Wall Cond	5,903	1,789		7,692	2			5,999	3									
Partition/Door	0			0	0			0	0									
Floor	22,926			22,926	7			23,782	11									
Adjacent Floor	0	0		0	0			0	0									
Infiltration	8,587			8,587	3			7,429	3									
<i>Sub Total ==></i>	<i>64,360</i>	<i>28,814</i>		<i>93,173</i>	<i>28</i>			<i>61,607</i>	<i>29</i>									
Internal Loads																		
Lights	29,700	7,425		37,124	11			29,700	14									
People	101,034	0		101,034	31			52,713	24									
Misc	31,770	0		31,770	10			31,770	15									
<i>Sub Total ==></i>	<i>162,503</i>	<i>7,425</i>		<i>169,928</i>	<i>52</i>			<i>114,183</i>	<i>53</i>									
Ceiling Load	36,239	-36,239		0	0			39,375	18									
Ventilation Load	0	0		65,833	20			0	0									
Adj Air Trans Heat	0			0	0			0	0									
Dehumid. Ov Sizing				0	0													
Ov/Undr Sizing	0			0	0			0	0									
Exhaust Heat				0	0													
Sup. Fan Heat				0	0													
Ret. Fan Heat	0			0	0													
Duct Heat Pkup				0	0													
Underflr Sup Ht Pkup				0	0													
Supply Air Leakage				0	0													
Grand Total ==>	263,102	0		328,935	100.00			215,165	100.00									
COOLING COIL SELECTION								AREAS				HEATING COIL SELECTION						
Total Capacity	ton	MBh	Sens Cap.	Coil Airflow	Enter DB	WB/HR	Leave DB	WB/HR	Gross Total	Glass ft ²	(%)	Capacity	Coil Airflow	Ent	Lvg			
Main Clg	27.4	328.9	273.3	9,942	79.4	63.7	64.4	54.5	52.5	56.4		MBh	cfm	°F	°F			
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0		Main Htg	-200.5	3,000	35.9	96.6		
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0		Aux Htg	0.0	0	0.0	0.0		
Total	27.4	328.9										Preheat	0.0	0	0.0	0.0		
												Humidif	0.0	0	0.0	0.0		
												Opt Vent	0.0	0	0.0	0.0		
												Total	-200.5					

System Checksums

By P2S Engineering, Inc

66

Bypass VAV with Reheat (30% Min Flow Default)

COOLING COIL PEAK				CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES			
Peaked at Time: Outside Air:		Mo/Hr: 9 / 16 OADB/WB/HR: 96 / 70 / 67		Mo/Hr: 9 / 17 OADB: 95				Mo/Hr: Heating Design OADB: 28				Cooling	Heating		
	Space Sens. + Lat.	Plenum Sens. + Lat	Net Total	Percent Of Total		Space Sensible	Percent Of Total		Space Peak Space Sens	Coil Peak Percent Tot Sens Of Total					
	Btu/h	Btu/h	Btu/h	(%)		Btu/h	(%)		Btu/h	Btu/h	(%)				
Envelope Loads															
Skylite Solar	0	0	0	0		0	0		Skylite Solar	0	0.00				
Skylite Cond	0	0	0	0		0	0		Skylite Cond	0	0.00				
Roof Cond	0	38,882	38,882	3		0	0		Roof Cond	0	-29,086	4.49			
Glass Solar	0	0	0	0		0	0		Glass Solar	0	0.00				
Glass/Door Cond	0	0	0	0		0	0		Glass/Door Cond	0	0.00				
Wall Cond	104,141	24,972	129,113	9		110,242	13		Wall Cond	-98,688	-118,649	18.30			
Partition/Door	0		0	0		0	0		Partition/Door	0	0	0.00			
Floor	54,782		54,782	4		55,753	7		Floor	-85,616	-85,616	13.21			
Adjacent Floor	0	0	0	0		0	0		Adjacent Floor	0	0	0			
Infiltration	45,034		45,034	3		39,896	5		Infiltration	-77,440	-77,440	11.95			
<i>Sub Total ==></i>	<i>203,958</i>	<i>63,854</i>	<i>267,811</i>	<i>18</i>		<i>205,891</i>	<i>24</i>		<i>Sub Total ==></i>	<i>-261,744</i>	<i>-310,792</i>	<i>47.94</i>			
Internal Loads									Internal Loads						
Lights	140,343	35,086	175,428	12		140,343	17		Lights	0	0	0.00			
People	555,889	0	555,889	38		322,881	38		People	0	0	0.00			
Misc	145,868	0	145,868	10		145,868	17		Misc	0	0	0.00			
<i>Sub Total ==></i>	<i>842,100</i>	<i>35,086</i>	<i>877,185</i>	<i>60</i>		<i>609,092</i>	<i>72</i>		<i>Sub Total ==></i>	<i>0</i>	<i>0</i>	<i>0.00</i>			
Ceiling Load	23,996	-23,996	0	0		25,822	3		Ceiling Load	-106,265	0	0.00			
Ventilation Load	0	0	350,258	24		0	0		Ventilation Load	0	-602,296	92.91			
Adj Air Trans Heat	0		0	0		0	0		Adj Air Trans Heat	0	0	0			
Dehumid. Ov Sizing			0	0					Ov/Undr Sizing	142,320	142,320	-21.95			
Ov/Undr Sizing	0		0	0		0	0		Exhaust Heat		122,500	-18.90			
Exhaust Heat		-24,590	-24,590	-2					OA Preheat Diff.		0	0.00			
Sup. Fan Heat			0	0					RA Preheat Diff.		0	0.00			
Ret. Fan Heat	0	0	0	0					Additional Reheat		0	0.00			
Duct Heat Pkup			0	0					Underflr Sup Ht Pkup		0	0.00			
Underflr Sup Ht Pkup			0	0					Supply Air Leakage		0	0.00			
Supply Air Leakage			0	0											
Grand Total ==>	1,070,054	50,353	1,470,665	100.00		840,804	100.00		Grand Total ==>	-225,690	-648,267	100.00			
COOLING COIL SELECTION				AREAS				HEATING COIL SELECTION							
Total Capacity ton	MBh	Sens Cap. MBh	Coil Airflow cfm	Enter DB/WB/HR °F	Leave DB/WB/HR °F	gr/lb	Gross Total	Glass ft ²	(%)	Capacity MBh	Coil Airflow cfm	Ent °F	Lvg °F		
Main Clg	122.6	1,470.7	1,222.9	40,148	82.8	65.3	66.5	55.0	53.1	57.8					
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Main Htg	-398.3	12,045	55.0	85.0
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Aux Htg	0.0	0	0.0	0.0
Total	122.6	1,470.7									Preheat	-250.0	40,148	49.4	55.0
											Reheat	-172.6	12,045	55.0	68.0
											Humidif	0.0	0	0.0	0.0
											Opt Vent	0.0	0	0.0	0.0
											Total	-648.3			

System Checksums

By P2S Engineering, Inc

67a

Bypass VAV with Reheat (30% Min Flow Default)

COOLING COIL PEAK					CLG SPACE PEAK					HEATING COIL PEAK					TEMPERATURES		
Peaked at Time: Outside Air:		Mo/Hr: 9 / 16 OADB/WB/HR: 96 / 70 / 67			Mo/Hr: 8 / 18 OADB: 92			Mo/Hr: Heating Design OADB: 28						Cooling	Heating		
	Space Sens. + Lat.	Plenum Sens. + Lat	Net Total	Percent Of Total		Space Sensible	Percent Of Total		Space Peak Space Sens	Coil Peak Percent Tot Sens Of Total							
	Btu/h	Btu/h	Btu/h	(%)		Btu/h	(%)		Btu/h	Btu/h							
Envelope Loads																	
Skylite Solar	0	0	0	0		0	0		Skylite Solar	0	0	0.00					
Skylite Cond	0	0	0	0		0	0		Skylite Cond	0	0	0.00					
Roof Cond	0	27,337	27,337	3		0	0		Roof Cond	0	-20,280	4.24					
Glass Solar	0	0	0	0		0	0		Glass Solar	0	0	0.00					
Glass/Door Cond	0	0	0	0		0	0		Glass/Door Cond	0	0	0.00					
Wall Cond	101,619	24,129	125,748	12		110,352	18		Wall Cond	-99,686	-119,039	24.91					
Partition/Door	0		0	0		0	0		Partition/Door	0	0	0.00					
Floor	39,795		39,795	4		41,282	7		Floor	-62,194	-62,194	13.02					
Adjacent Floor	0	0	0	0		0	0		Adjacent Floor	0	0	0					
Infiltration	32,628		32,628	3		25,463	4		Infiltration	-56,025	-56,025	11.72					
<i>Sub Total ==></i>	<i>174,042</i>	<i>51,466</i>	<i>225,508</i>	<i>21</i>		<i>177,098</i>	<i>28</i>		<i>Sub Total ==></i>	<i>-217,905</i>	<i>-257,538</i>	<i>53.90</i>					
Internal Loads									Internal Loads								
Lights	102,352	25,588	127,941	12		102,352	16		Lights	0	0	0.00					
People	391,519	0	391,519	36		214,649	34		People	0	0	0.00					
Misc	107,340	0	107,340	10		107,340	17		Misc	0	0	0.00					
<i>Sub Total ==></i>	<i>601,212</i>	<i>25,588</i>	<i>626,800</i>	<i>58</i>		<i>424,341</i>	<i>68</i>		<i>Sub Total ==></i>	<i>0</i>	<i>0</i>	<i>0.00</i>					
Ceiling Load	20,609	-20,609	0	0		23,481	4		Ceiling Load	-89,967	0	0.00					
Ventilation Load	0	0	236,551	22		0	0		Ventilation Load	0	-406,182	85.01					
Adj Air Trans Heat	0		0	0		0	0		Adj Air Trans Heat	0	0	0					
Dehumid. Ov Sizing			0	0					Ov/Undr Sizing	140,130	140,130	-29.33					
Ov/Undr Sizing	0		0	0		0	0		Exhaust Heat		45,762	-9.58					
Exhaust Heat	-9,895	-9,895	-9,895	-1					OA Preheat Diff.		0	0.00					
Sup. Fan Heat			0	0					RA Preheat Diff.		0	0.00					
Ret. Fan Heat	0	0	0	0					Additional Reheat		0	0.00					
Duct Heat Pkup	0	0	0	0					Underflr Sup Ht Pkup		0	0.00					
Underflr Sup Ht Pkup			0	0					Supply Air Leakage		0	0.00					
Supply Air Leakage	0	0	0	0													
<i>Grand Total ==></i>	<i>795,863</i>	<i>46,551</i>	<i>1,078,965</i>	<i>100.00</i>		<i>624,920</i>	<i>100.00</i>		<i>Grand Total ==></i>	<i>-167,742</i>	<i>-477,828</i>	<i>100.00</i>					
COOLING COIL SELECTION					AREAS					HEATING COIL SELECTION							
Total Capacity ton	MBh	Sens Cap. MBh	Coil Airflow cfm	Enter DB/WB/HR °F	Leave DB/WB/HR °F	Gross Total	Glass ft ²	(%)	Capacity MBh	Coil Airflow cfm	Ent °F	Lvg °F					
Main Clg	89.9	1,079.0	891.6	29,840	82.3	65.1	66.4	55.0	53.1	57.7							
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0							
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0							
<i>Total</i>	<i>89.9</i>	<i>1,079.0</i>															

System Checksums

By P2S Engineering, Inc

67b

Bypass VAV with Reheat (30% Min Flow Default)

COOLING COIL PEAK				CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES			
Peaked at Time: Outside Air:		Mo/Hr: 9 / 16 OADB/WB/HR: 96 / 70 / 67		Mo/Hr: 9 / 17 OADB: 95				Mo/Hr: Heating Design OADB: 28				Cooling	Heating		
	Space Sens. + Lat.	Plenum Sens. + Lat	Net Total Btu/h	Percent Of Total (%)	Space Sensible Btu/h	Percent Of Total (%)		Space Peak Space Sens Btu/h	Coil Peak Percent Tot Sens Of Total Btu/h						
Envelope Loads															
Skylite Solar	0	0	0	0	0	0		Skylite Solar	0	0	0.00				
Skylite Cond	0	0	0	0	0	0		Skylite Cond	0	0	0.00				
Roof Cond	0	10,930	10,930	3	0	0		Roof Cond	0	-7,890	4.33				
Glass Solar	0	0	0	0	0	0		Glass Solar	0	0	0.00				
Glass/Door Cond	0	0	0	0	0	0		Glass/Door Cond	0	0	0.00				
Wall Cond	46,325	10,879	57,204	14	48,290	21		Wall Cond	-45,312	-53,784	29.55				
Partition/Door	0		0	0	0	0		Partition/Door	0	0	0.00				
Floor	16,077		16,077	4	16,077	7		Floor	-25,126	-25,126	13.80				
Adjacent Floor	0	0	0	0	0	0		Adjacent Floor	0	0	0				
Infiltration	11,250		11,250	3	10,175	4		Infiltration	-19,390	-19,390	10.65				
<i>Sub Total ==></i>	<i>73,652</i>	<i>21,809</i>	<i>95,461</i>	<i>24</i>	<i>74,542</i>	<i>33</i>		<i>Sub Total ==></i>	<i>-89,828</i>	<i>-106,190</i>	<i>58.34</i>				
Internal Loads								Internal Loads							
Lights	36,325	9,081	45,406	11	36,325	16		Lights	0	0	0.00				
People	138,478	0	138,478	35	74,588	33		People	0	0	0.00				
Misc	34,149	0	34,149	9	34,149	15		Misc	0	0	0.00				
<i>Sub Total ==></i>	<i>208,951</i>	<i>9,081</i>	<i>218,033</i>	<i>55</i>	<i>145,061</i>	<i>63</i>		<i>Sub Total ==></i>	<i>0</i>	<i>0</i>	<i>0.00</i>				
Ceiling Load	8,639	-8,639	0	0	9,099	4		Ceiling Load	-35,139	0	0.00				
Ventilation Load	0	0	84,378	21	0	0		Ventilation Load	0	-145,428	79.90				
Adj Air Trans Heat	0		0	0	0	0		Adj Air Trans Heat	0	0	0				
Dehumid. Ov Sizing			0	0				Ov/Undr Sizing	63,579	63,579	-34.93				
Ov/Undr Sizing	0		0	0	0	0		Exhaust Heat		6,022	-3.31				
Exhaust Heat		-1,419	-1,419	0				OA Preheat Diff.		0	0.00				
Sup. Fan Heat			0	0				RA Preheat Diff.		0	0.00				
Ret. Fan Heat	0	0	0	0				Additional Reheat		0	0.00				
Duct Heat Pkup	0	0	0	0				Underflr Sup Ht Pkup		0	0.00				
Underflr Sup Ht Pkup			0	0				Supply Air Leakage		0	0.00				
Supply Air Leakage	0	0	0	0											
Grand Total ==>	291,242	20,832	396,453	100.00	228,702	100.00		Grand Total ==>	-61,388	-182,018	100.00				
COOLING COIL SELECTION				AREAS				HEATING COIL SELECTION							
Total Capacity	Sens Cap.	Coil Airflow	Enter DB/WB/HR	Gross Total	Glass ft ²	(%)	Capacity	Coil Airflow	Ent	Lvg					
ton	MBh	MBh	cfm °F °F gr/lb				MBh	cfm	°F	°F					
Main Clg	33.0	396.5	329.2	10,921	82.5	65.2	66.5	55.0	53.1	57.8					
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Main Htg	-108.3	3,276	55.0	85.0
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Aux Htg	0.0	0	0.0	0.0
Total	33.0	396.5									Int Door	0			
											ExFlr	6,594			
											Roof	6,594	0	0	
											Wall	7,080	0	0	
											Ext Door	0	0	0	
											Total	-182.0			

System Checksums

By P2S Engineering, Inc

System - 001

Variable Volume Reheat (30% Min Flow Default)

COOLING COIL PEAK								CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES			
Peaked at Time:		Mo/Hr: 9 / 16		Mo/Hr: 9 / 15		Mo/Hr: Heating Design		Space Peak		Coil Peak Percent		Cooling		Heating					
Outside Air:	OADB/WB/HR:	OADB:	96 / 70 / 67	OADB:	97	OADB:	28	Sens. Space	Percent	Tot Sens. Space	Tot Percent	Sens. Space	Percent	Sens. Space	Percent	SADB	57.0	85.0	
Space Sens. + Lat.	Btu/h	Plenum Sens. + Lat	Btu/h	Total Btu/h	% Of Total	Sens. Space	Percent	Sensible	Percent	Btu/h	(%)	Space Peak	Coil Peak Percent	Space Sens.	Percent	Ra Plenum	74.7	65.0	
Envelope Loads																Return	74.7	65.0	
Skylite Solar	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Ret/OA	80.7	31.2		
Skylite Cond	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Fn MtrTD	0.0	0.0		
Roof Cond	0	71,762	71,762	3	3	0	0	0	0	0	0	0	-38,216	2.80	Fn BldTD	0.0	0.0		
Glass Solar	94,387	0	94,387	4	4	93,485	7	Glass Solar	0	0	0	0	0	0.00	Fn Frict	0.0	0.0		
Glass/Door Cond	18,865	0	18,865	1	1	19,065	1	Glass/Door Cond	-34,180	-34,180	2.51	0	0	0.00					
Wall Cond	201,835	90,439	292,274	12	12	208,692	15	Wall Cond	-166,891	-237,163	17.38	0	0	0.00					
Partition/Door	0		0	0	0	0	0	Partition/Door	0	0	0.00	0	0	0.00					
Floor	45,136		45,136	2	2	45,136	3	Floor	-70,541	-70,541	5.17	0	0	0.00					
Adjacent Floor	0	0	0	0	0	0	0	Adjacent Floor	0	0	0	0	0	0.00					
Infiltration	87,307		87,307	3	3	81,958	6	Infiltration	-142,598	-142,598	10.45	0	0	0.00					
<i>Sub Total ==></i>	<i>447,529</i>	<i>162,201</i>	<i>609,730</i>	<i>24</i>	<i>24</i>	<i>448,335</i>	<i>32</i>	<i>Sub Total ==></i>	<i>-414,209</i>	<i>-522,697</i>	<i>38.31</i>	<i>0</i>	<i>0</i>	<i>0.00</i>					
Internal Loads								Internal Loads											
Lights	211,942	52,986	264,928	10	10	211,942	15	Lights	0	0	0.00	0	0	0.00					
People	884,738	0	884,738	35	35	515,401	36	People	0	0	0.00	0	0	0.00					
Misc	220,773	0	220,773	9	9	220,773	16	Misc	0	0	0.00	0	0	0.00					
<i>Sub Total ==></i>	<i>1,317,453</i>	<i>52,986</i>	<i>1,370,439</i>	<i>54</i>	<i>54</i>	<i>948,117</i>	<i>67</i>	<i>Sub Total ==></i>	<i>0</i>	<i>0</i>	<i>0.00</i>	<i>0</i>	<i>0</i>	<i>0.00</i>					
Ceiling Load	14,831	-14,831	0	0	0	17,137	1	Ceiling Load	-60,963	0	0.00	0	0	0.00					
Ventilation Load	0	0	558,767	22	22	0	0	Ventilation Load	0	-912,626	66.89	0	0	0.00					
Adj Air Trans Heat	0		0	0	0	0	0	Adj Air Trans Heat	0	0	0	0	0	0.00					
Dehumid. Ov Sizing			0	0	0	0	0	Ov/Undr Sizing	51,095	51,095	-3.74	0	0	0.00					
Ov/Undr Sizing	0		0	0	0	0	0	Exhaust Heat	41,189	-3.02	0	0	0	0.00					
Exhaust Heat			-10,021	-10,021	0	0	0	OA Preheat Diff.	0	0	0.00	0	0	0.00					
Sup. Fan Heat						0	0	RA Preheat Diff.	-21,355	1.57	0	0	0	0.00					
Ret. Fan Heat			0	0	0	0	0	Additional Reheat	0	0	0.00	0	0	0.00					
Duct Heat Pkup			-165,058			0	0	Underflr Sup Ht Pkup		0	0.00								
Underflr Sup Ht Pkup						0	0	Supply Air Leakage		0	0.00								
Supply Air Leakage						0	0			0	0.00								
Grand Total ==>	1,779,814	25,277	2,528,916	100.00	100.00	1,413,589	100.00	Grand Total ==>	-424,077	-1,364,393	100.00								
COOLING COIL SELECTION								AREAS				HEATING COIL SELECTION				Engineering CKS			
Total Capacity	ton	MBh	Sens Cap.	Coil Airflow	Enter DB	WB/HR	Leave DB	WB/HR	Gross Total	Glass ft ²	(%)	Capacity	Coil Airflow	Ent	Lvg	Cooling	Heating		
Main Clg	210.7	2,528.9	2,104.2	74,874	80.7	64.3	64.9	55.0	52.9	57.1		Main Htg	-748.4	22,632	55.0	85.0			
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0		Aux Htg	0.0	0	0.0	0.0			
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0		Preheat	-616.0	20,700	28.0	55.0			
Total	210.7	2,528.9							ExFlr	23,458			Reheat	-324.3	22,632	55.0	68.0		
									Roof	23,458	0	0	Humidif	0.0	0	0.0	0.0		
									Wall	36,904	3,181	9	Opt Vent	0.0	0	0.0	0.0		
									Ext Door	0	0	0	Total	-1,364.4					

System Checksums

By P2S Engineering, Inc

System - 001

Variable Volume Reheat (30% Min Flow Default)

COOLING COIL PEAK								CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES		
Peaked at Time:		Mo/Hr: 9 / 16		Mo/Hr: 9 / 15		Mo/Hr: Heating Design		Space Peak		Coil Peak Percent		Cooling		Heating				
Outside Air:		OADB/WB/HR: 96 / 70 / 67		OADB: 97		OADB: 28		Space Sens		Tot Sens Of Total		SADB	58.1	85.0				
	Space Sens. + Lat.	Btu/h	Plenum Sens. + Lat	Btu/h	Net Total	Percent Btu/h	(%)	Space Sensible	Percent Of Total	Btu/h	(%)	Ra Plenum	76.9	62.3				
Envelope Loads								Envelope Loads				Return	76.9	62.3				
Skylite Solar	0	0		0	0	0	0	Skylite Solar	0	0	0.00	Ret/OA	89.0	28.0				
Skylite Cond	0	0		0	0	0	0	Skylite Cond	0	0	0.00	Fn MtrTD	0.1	0.0				
Roof Cond	0	78,023		78,023	3	3	0	Roof Cond	0	-38,542	1.91	Fn BldTD	0.2	0.0				
Glass Solar	224,916	0		224,916	8	8	239,777	Glass Solar	0	0	0.00	Fn Frict	0.7	0.0				
Glass/Door Cond	42,963	0		42,963	1	1	42,810	Glass/Door Cond	-80,254	-80,254	3.97							
Wall Cond	168,606	85,965		254,571	9	9	159,283	Wall Cond	-159,155	-233,943	11.57							
Partition/Door	0			0	0	0	0	Partition/Door	0	0	0.00							
Floor	61,384			61,384	2	2	61,384	Floor	-95,934	-95,934	4.75							
Adjacent Floor	0	0		0	0	0	0	Adjacent Floor	0	0	0							
Infiltration	80,041			80,041	3	3	67,829	Infiltration	-118,015	-118,015	5.84							
<i>Sub Total ==></i>	<i>577,909</i>			<i>741,898</i>	<i>25</i>		<i>571,083</i>	<i>Sub Total ==></i>	<i>-453,358</i>	<i>-566,688</i>	<i>28.03</i>							
Internal Loads								Internal Loads										
Lights	220,117	55,029		275,146	9	9	220,117	Lights	0	0	0.00							
People	369,920	0		369,920	12	12	200,107	People	0	0	0.00							
Misc	204,210	0		204,210	7	7	204,210	Misc	0	0	0.00							
<i>Sub Total ==></i>	<i>794,246</i>			<i>849,275</i>	<i>28</i>		<i>624,434</i>	<i>Sub Total ==></i>	<i>0</i>	<i>0</i>	<i>0.00</i>							
Ceiling Load	58,368	-58,368		0	0		58,735	Ceiling Load	-113,330	0	0.00							
Ventilation Load	0	0		1,319,146	44		0	Ventilation Load	0	-945,134	46.75							
Adj Air Trans Heat	0			0	0		0	Adj Air Trans Heat	0	0	0							
Dehumid. Ov Sizing				0	0			Ov/Undr Sizing	165,006	165,006	-8.16							
Ov/Undr Sizing	0			0	0		0	Exhaust Heat	0	0	0.00							
Exhaust Heat		-8,629		-8,629	0			OA Preheat Diff.	-674,907	33.38								
Sup. Fan Heat				84,181	3			RA Preheat Diff.	0	0.00								
Ret. Fan Heat	0	0	0					Additional Reheat	0	0.00								
Duct Heat Pkup		-156,578		0	0			Underflr Sup Ht Pkup	0	0.00								
Underflr Sup Ht Pkup				0	0			Supply Air Leakage	0	0.00								
Supply Air Leakage		0		0	0													
Grand Total ==>	1,430,523			-4,557	2,985,871	100.00		Grand Total ==>	-401,682	-2,021,723	100.00							
COOLING COIL SELECTION								AREAS				HEATING COIL SELECTION						
Total Capacity	ton	MBh	Sens Cap.	Coil Airflow	Enter DB	WB/HR	Leave DB	WB/HR	Gross Total	Glass	(%)	Capacity	Coil Airflow	Ent	Lvg			
Main Clg	248.8	2,985.9	2,571.6	71,028	89.0	66.9	64.5	55.0	53.1	57.9		Main Htg	-708.9	21,437	55.0	85.0		
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0		Aux Htg	0.0	0	0.0	0.0		
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0		Int Door	0					
Total	248.8	2,985.9							ExFlr	25,522			Preheat	-1,312.9	44,115	28.0	55.0	
									Roof	25,522	0	0	Reheat	-307.2	21,437	55.0	68.0	
									Wall	34,048	3,258	10	Humidif	0.0	0	0.0	0.0	
									Ext Door	0	0	0	Opt Vent	0.0	0	0.0	0.0	
												Total	-2,021.7					

System Checksums

By P2S Engineering, Inc

System - 001

Single Zone Variable Air Volume

COOLING COIL PEAK								CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES			
Peaked at Time:		Mo/Hr: 9 / 16		Mo/Hr: 9 / 16		Mo/Hr: 9 / 16		Mo/Hr: Heating Design		Mo/Hr: 28		Space Peak		Coil Peak Percent		Cooling	Heating		
Outside Air:		OADB/WB/HR: 96 / 70 / 67		OADB: 96								Space Sens		Tot Sens Of Total		SADB	99.1		
	Space Sens. + Lat.	Btu/h	Plenum Sens. + Lat	Btu/h	Net Total	Percent Btu/h	Total Of Total (%)					Btu/h	(%)			Ra Plenum	37.7		
Envelope Loads								Envelope Loads								Return	68.0		
Skylite Solar	0	0	0	0	0	0	0	Skylite Solar	0	0	0	0	0	0		Ret/OA	61.7		
Skylite Cond	0	0	0	0	0	0	0	Skylite Cond	0	0	0	0	0	0		Fn MtrTD	0.0		
Roof Cond	0	1,064	1,064	8	8	0	0	Roof Cond	0	-435	5.54	0	0	0		Fn BldTD	0.0		
Glass Solar	1,062	0	1,062	8	8	1,062	9	Glass Solar	0	0	0	0	0	0		Fn Frict	0.0		
Glass/Door Cond	174	0	174	1	1	174	2	Glass/Door Cond	-327	-327	4.17	0	0	0					
Wall Cond	6,315	1,275	7,590	61	61	6,315	56	Wall Cond	-3,984	-4,969	63.37	0	0	0					
Partition/Door	0		0	0	0	0	0	Partition/Door	0	0	0.00	0	0	0					
Floor	0		0	0	0	0	0	Floor	-495	-495	6.31	0	0	0					
Adjacent Floor	0	0	0	0	0	0	0	Adjacent Floor	0	0	0	0	0	0					
Infiltration	200		200	2	2	164	1	Infiltration	-294	-294	3.74	0	0	0					
<i>Sub Total ==></i>	<i>7,752</i>	<i>2,339</i>	<i>10,091</i>	<i>80</i>	<i>80</i>	<i>7,716</i>	<i>69</i>	<i>Sub Total ==></i>	<i>-5,100</i>	<i>-6,520</i>	<i>83.13</i>	<i>0</i>	<i>0</i>	<i>0</i>	<i></i>	<i></i>	<i></i>		
Internal Loads								Internal Loads							AIRFLOWS				
Lights	175	44	218	2	2	175	2	Lights	0	0	0.00	0	0	0	Diffuser	190	190		
People	900	0	900	7	7	500	4	People	0	0	0.00	0	0	0	Terminal	190	190		
Misc	424	0	424	3	3	424	4	Misc	0	0	0.00	0	0	0	Main Fan	190	190		
<i>Sub Total ==></i>	<i>1,499</i>	<i>44</i>	<i>1,543</i>	<i>12</i>	<i>12</i>	<i>1,099</i>	<i>10</i>	<i>Sub Total ==></i>	<i>0</i>	<i>0</i>	<i>0.00</i>	<i>0</i>	<i>0</i>	<i>0</i>	Sec Fan	0	0		
Ceiling Load	2,383	-2,383	0	0	0	2,383	21	Ceiling Load	-1,420	0	0.00	0	0	0	MinStop/Rh	190	190		
Ventilation Load	0	0	902	7	7	0	0	Ventilation Load	0	-1,323	16.87	0	0	0	Return	642	197		
Adj Air Trans Heat	0		0	0	0	0	0	Adj Air Trans Heat	0	0	0	0	0	0	Exhaust	37	37		
Dehumid. Ov Sizing			0	0	0	0	0	Ov/Undr Sizing	0	0	0.00	0	0	0	Auxiliary	0	0		
Ov/Undr Sizing	0		0	0	0	0	0	Exhaust Heat	0	0	0.00	0	0	0	Leakage Dwn	0	0		
Exhaust Heat		0	0	0	0	0	0	OA Preheat Diff.	0	0	0.00	0	0	0	Leakage Ups	0	0		
Sup. Fan Heat			0	0	0	0	0	RA Preheat Diff.	0	0	0.00	0	0	0					
Ret. Fan Heat	0	0	0	0	0	0	0	Additional Reheat	0	0	0.00	0	0	0					
Duct Heat Pkup	0		0	0	0	0	0	Underflr Sup Ht Pkup	0	0	0.00	0	0	0					
Underflr Sup Ht Pkup			0	0	0	0	0	Supply Air Leakage	0	0	0.00	0	0	0					
Supply Air Leakage	0	0	0	0	0	0	0												
Grand Total ==>	11,634	0	12,536	100.00	100.00	11,198	100.00	Grand Total ==>	-6,520	-7,842	100.00								
COOLING COIL SELECTION								AREAS				HEATING COIL SELECTION							
Total Capacity	ton	MBh	Sens Cap.	MBh	Coil Airflow	cfm	Enter DB	°F	WB/HR	Leave DB	°F	Gross Total	Glass ft ²	(%)	Capacity	MBh	Coil Airflow	Ent °F	Lvg °F
Main Clg	1.0	12.5	11.9	635	75.1	61.3	60.0	58.0	54.5	58.6		Floor	148		Main Htg	-7.8	190	61.7	99.1
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0		Part	0		Aux Htg	0.0	0	0.0	0.0
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0		Int Door	0		Preheat	0.0	0	0.0	0.0
Total	1.0	12.5										ExFlr	25		Humidif	0.0	0	0.0	0.0
												Roof	148	0	Opt Vent	0.0	0	0.0	0.0
												Wall	435	16	Total	-7.8			
												Ext Door	0	0					

System Checksums

By P2S Engineering, Inc.

AC-1 (1st North)

Double Duct VAV

COOLING COIL PEAK								CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES				
Peaked at Time:		Mo/Hr: 8 / 17		Mo/Hr: 7 / 18		Mo/Hr: 13 / 1		Cooling		Heating										
Outside Air:		OADB/WB/HR: 92 / 70 / 79		OADB: 91		OADB: 33		SADB		Plenum										
	Space Sens. + Lat.	Plenum Sens. + Lat.	Net Total	Percent Of Total		Space Sensible	Percent Of Total	Space Peak Space Sens	Peak Tot	Coil Peak Tot	Percent Sens Of Total					Cooling	Heating			
	Btu/h	Btu/h	Btu/h	(%)		Btu/h	(%)	Btu/h	Btu/h	Btu/h	(%)					SADB	Plenum			
Envelope Loads																				
Skylite Solar	0	0	0	0.00		0	0.00	Skylite Solar	0	0	0.00					52.7	100.0			
Skylite Cond	0	0	0	0.00		0	0.00	Skylite Cond	0	0	0.00					73.8	67.6			
Roof Cond	0	0	0	0.00		0	0.00	Roof Cond	0	0	0.00					73.8	67.6			
Glass Solar	18,024	0	18,024	3.34		14,588	5.97	Glass Solar	0	0	0.00					83.0	37.2			
Glass Cond	4,197	0	4,197	0.78		4,120	1.69	Glass Cond	-8,561	-8,561	1.78					0.1	0.0			
Wall Cond	45,189	16,889	62,078	11.52		48,656	19.92	Wall Cond	-67,625	-93,092	19.41					0.2	0.0			
Partition	1,787		1,787	0.33		1,967	0.81	Partition	-2,025	-2,025	0.42					0.7	0.0			
Exposed Floor	0		0	0.00		0	0.00	Exposed Floor	0	0	0.00									
Infiltration	0		0	0.00		0	0.00	Infiltration	-2	-2	0.00									
<i>Sub Total ==></i>	<i>69,196</i>	<i>16,889</i>	<i>86,085</i>	<i>15.97</i>		<i>69,331</i>	<i>28.38</i>	<i>Sub Total ==></i>	<i>-78,212</i>	<i>-103,679</i>	<i>21.61</i>									
Internal Loads								Internal Loads												
Lights	44,261	11,065	55,326	10.26		44,261	18.12	Lights	0	0	0.00					6,073	6,073			
People	178,201		178,201	33.06		99,939	40.91	People	0	0	0.00					0	0			
Misc	24,589	0	24,589	4.56		24,589	10.07	Misc	0	0	0.00					11,758	6,902			
<i>Sub Total ==></i>	<i>247,051</i>	<i>11,065</i>	<i>258,116</i>	<i>47.88</i>		<i>168,789</i>	<i>69.09</i>	<i>Sub Total ==></i>	<i>0</i>	<i>0</i>	<i>0.00</i>					<i>0</i>	<i>0</i>			
Ceiling Load	5,909	-5,909	0	0.00		6,174	2.53	Ceiling Load	-7,978	0	0.00									
Ventilation Load	0	0	194,068	36.00		0	0.00	Ventilation Load	0	-241,294	50.30									
Ov/Undr Sizing	0		0	0.00		0	0.00	Ov/Undr Sizing	-136,167	-136,167	28.39									
Exhaust Heat	-11,396		-11,396	-2.11				Exhaust Heat	15,388	15,388	-3.21									
Sup. Fan Heat			12,174	2.26				OA Preheat Diff.	0	0	0.00									
Ret. Fan Heat	0		0	0.00				RA Preheat Diff.	-13,927	-13,927	2.90									
Duct Heat Pkup	0		0	0.00				Additional Reheat	0	0	0.00									
Reheat at Design			0	0.00																
<i>Grand Total ==></i>	<i>322,156</i>	<i>10,649</i>	<i>539,046</i>	<i>100.00</i>		<i>244,293</i>	<i>100.00</i>	<i>Grand Total ==></i>	<i>-222,357</i>	<i>-479,679</i>	<i>100.00</i>									
COOLING COIL SELECTION								AREAS				HEATING COIL SELECTION								
Total Capacity	ton	MBh	Sens Cap.	MBh	Coil Airflow	cfm	Enter DB	°F	WB/HR	Leave DB	°F	Gross Total	Glass ft ²	Lvg (%)	Capacity MBh	Coil Airflow cfm	Ent °F	Lvg °F		
Main Clg	44.9	539.1	394.9	11,739	83.3	66.0	71.5	52.0	50.3	53.5		Floor	10,671		Main Htg	-358.1	6,902	51.7	100.0	
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0		Part	1,206		Aux Htg	0.0	0	0.0	0.0	
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0		ExFlr	0		Preheat	-121.9	6,073	33.0	51.7	
<i>Total</i>	<i>44.9</i>	<i>539.1</i>										Roof	<i>0</i>	<i>0</i>	Reheat	<i>0.0</i>	<i>0</i>	<i>0.0</i>	<i>0.0</i>	
												Wall	<i>6,497</i>	<i>232</i>	<i>4</i>	<i>Humidif</i>	<i>0.0</i>	<i>0</i>	<i>0.0</i>	<i>0.0</i>
												<i>Total</i>				<i>-480.0</i>				

System Checksums

By P2S Engineering, Inc.

AC-2 (2nd North)

Double Duct VAV

COOLING COIL PEAK								CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES			
Peaked at Time:		Mo/Hr: 8 / 17		Mo/Hr: 7 / 18		Mo/Hr: 13 / 1		Cooling		Heating									
Outside Air:		OADB/WB/HR: 92 / 70 / 79		OADB: 91		OADB: 33		SADB		Plenum									
	Space Sens. + Lat. Btu/h	Plenum Sens. + Lat. Btu/h	Net Total Btu/h	Percent Of Total (%)		Space Sensible Btu/h	Percent Of Total (%)	Space Peak Space Sens Btu/h	Peak Tot Sens Btu/h	Percent Of Total (%)									
Envelope Loads																			
Skylite Solar	0	0	0	0.00		0	0.00	Skylite Solar	0	0	0.00								
Skylite Cond	0	0	0	0.00		0	0.00	Skylite Cond	0	0	0.00								
Roof Cond	0	0	0	0.00		0	0.00	Roof Cond	0	0	0.00								
Glass Solar	21,712	0	21,712	3.45		18,782	6.48	Glass Solar	0	0	0.00								
Glass Cond	3,974	0	3,974	0.63		3,901	1.35	Glass Cond	-8,111	-8,111	1.45								
Wall Cond	57,999	21,753	79,753	12.67		63,347	21.84	Wall Cond	-84,930	-116,913	20.89								
Partition	3,241		3,241	0.51		3,568	1.23	Partition	-3,672	-3,672	0.66								
Exposed Floor	0		0	0.00		0	0.00	Exposed Floor	0	0	0.00								
Infiltration	0		0	0.00		0	0.00	Infiltration	-2	-2	0.00								
<i>Sub Total ==></i>	<i>86,927</i>	<i>21,753</i>	<i>108,680</i>	<i>17.26</i>		<i>89,598</i>	<i>30.89</i>	<i>Sub Total ==></i>	<i>-96,715</i>	<i>-128,698</i>	<i>23.00</i>								
Internal Loads								Internal Loads											
Lights	49,648	12,412	62,061	9.86		49,648	17.12	Lights	0	0	0.00								
People	205,938		205,938	32.71		114,761	39.57	People	0	0	0.00								
Misc	28,667	0	28,667	4.55		28,667	9.89	Misc	0	0	0.00								
<i>Sub Total ==></i>	<i>284,254</i>	<i>12,412</i>	<i>296,666</i>	<i>47.12</i>		<i>193,077</i>	<i>66.58</i>	<i>Sub Total ==></i>	<i>0</i>	<i>0</i>	<i>0.00</i>								
Ceiling Load	6,965	-6,965	0	0.00		7,334	2.53	Ceiling Load	-9,732	0	0.00								
Ventilation Load	0	0	223,591	35.52		0	0.00	Ventilation Load	0	-276,859	49.47								
Ov/Undr Sizing	0		0	0.00		0	0.00	Ov/Undr Sizing	-154,464	-154,464	27.60								
Exhaust Heat	-13,699		-13,699	-2.18				Exhaust Heat	19,143	-3.42									
Sup. Fan Heat			14,324	2.28				OA Preheat Diff.	0	0.00									
Ret. Fan Heat	0		0	0.00				RA Preheat Diff.	-18,752	3.35									
Duct Heat Pkup	0		0	0.00				Additional Reheat	0	0.00									
Reheat at Design			0	0.00															
<i>Grand Total ==></i>	<i>378,145</i>	<i>13,502</i>	<i>629,561</i>	<i>100.00</i>		<i>290,009</i>	<i>100.00</i>	<i>Grand Total ==></i>	<i>-260,912</i>	<i>-559,630</i>	<i>100.00</i>								
COOLING COIL SELECTION								AREAS				HEATING COIL SELECTION							
Total Capacity	Sens Cap.	Coil Airflow	Enter DB	WB/HR	Leave DB	WB/HR		Gross Total	Glass			Capacity	Coil	Airflow	Ent	Lvg			
ton	MBh	MBh	cfm	°F	°F	gr/lb		ft ²	(%)			MBh	cfm	°F	°F				
Main Clg	52.5	629.6	461.9	13,812	83.1	65.8	71.2	52.0	50.2	53.4		Main Htg	-420.2	8,099	51.7	100.0			
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0		Aux Htg	0.0	0	0.0	0.0			
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0		Preheat	-139.8	6,968	33.0	51.7			
<i>Total</i>	<i>52.5</i>	<i>629.6</i>						<i>Roof</i>	<i>0</i>	<i>0</i>	<i>0</i>		<i>Reheat</i>	<i>0.0</i>	<i>0</i>	<i>0.0</i>	<i>0.0</i>		
								<i>Wall</i>	<i>8,099</i>	<i>218</i>	<i>3</i>		<i>Humidif</i>	<i>0.0</i>	<i>0</i>	<i>0.0</i>	<i>0.0</i>		
													<i>Opt Vent</i>	<i>0.0</i>	<i>0</i>	<i>0.0</i>	<i>0.0</i>		
													<i>Total</i>	<i>-560.0</i>					

System Checksums

By P2S Engineering, Inc.

AC-3 (3rd North)

Double Duct VAV

COOLING COIL PEAK								CLG SPACE PEAK				HEATING COIL PEAK						TEMPERATURES			
Peaked at Time:		Mo/Hr: 8 / 17		Mo/Hr: 7 / 18		Mo/Hr: 13 / 1		Cooling		Heating											
Outside Air:		OADB/WB/HR: 92 / 70 / 79		OADB: 91		OADB: 33		SADB		Plenum											
	Space Sens. + Lat. Btu/h	Plenum Sens. + Lat. Btu/h	Net Total Btu/h	Percent Of Total (%)		Space Sensible Btu/h	Percent Of Total (%)	Space Peak Space Sens Btu/h	Peak Tot Sens Btu/h	Percent Of Total (%)											
Envelope Loads																					
Skylite Solar	0	0	0	0.00		0	0.00	Skylite Solar	0	0	0.00										
Skylite Cond	0	0	0	0.00		0	0.00	Skylite Cond	0	0	0.00										
Roof Cond	0	106,987	106,987	14.10		0	0.00	Roof Cond	0	-73,983	11.78										
Glass Solar	17,807	0	17,807	2.35		14,869	4.54	Glass Solar	0	0	0.00										
Glass Cond	3,592	0	3,592	0.47		3,526	1.08	Glass Cond	-7,340	-7,340	1.17										
Wall Cond	58,668	17,464	76,132	10.04		64,271	19.63	Wall Cond	-86,009	-113,600	18.08										
Partition	3,241		3,241	0.43		3,568	1.09	Partition	-3,672	-3,672	0.58										
Exposed Floor	0		0	0.00		0	0.00	Exposed Floor	0	0	0.00										
Infiltration	0		0	0.00		0	0.00	Infiltration	-2	-2	0.00										
<i>Sub Total ==></i>	<i>83,308</i>	<i>124,451</i>	<i>207,758</i>	<i>27.39</i>		<i>86,234</i>	<i>26.33</i>	<i>Sub Total ==></i>	<i>-97,022</i>	<i>-198,596</i>	<i>31.61</i>										
Internal Loads								Internal Loads													
Lights	52,076	13,019	65,094	8.58		52,076	15.90	Lights	0	0	0.00										
People	243,450		243,450	32.09		135,250	41.30	People	0	0	0.00										
Misc	25,598	0	25,598	3.37		25,598	7.82	Misc	0	0	0.00										
<i>Sub Total ==></i>	<i>321,123</i>	<i>13,019</i>	<i>334,142</i>	<i>44.05</i>		<i>212,923</i>	<i>65.02</i>	<i>Sub Total ==></i>	<i>0</i>	<i>0</i>	<i>0.00</i>										
Ceiling Load	25,822	-25,822	0	0.00		28,314	8.65	Ceiling Load	-29,067	0	0.00										
Ventilation Load	0	0	259,487	34.21		0	0.00	Ventilation Load	0	-324,979	51.73										
Ov/Undr Sizing	0		0	0.00		0	0.00	Ov/Undr Sizing	-162,285	-162,285	25.83										
Exhaust Heat	-58,854	-58,854	-7.76					Exhaust Heat	66,251	-10.54											
Sup. Fan Heat			16,075	2.12				OA Preheat Diff.	0	0.00											
Ret. Fan Heat	0	0	0.00					RA Preheat Diff.	-8,672	1.38											
Duct Heat Pkup	0	0	0.00					Additional Reheat	0	0.00											
Reheat at Design			0	0.00																	
<i>Grand Total ==></i>	<i>430,253</i>	<i>52,794</i>	<i>758,609</i>	<i>100.00</i>		<i>327,472</i>	<i>100.00</i>	<i>Grand Total ==></i>	<i>-288,375</i>	<i>-628,281</i>	<i>100.00</i>										
COOLING COIL SELECTION								AREAS						HEATING COIL SELECTION							
Total Capacity	ton	MBh	Sens Cap.	MBh	Coil Airflow	cfm	Enter DB/WB/HR	°F	Leave DB/WB/HR	°F	Gr/lb	Gross Total	Glass ft ²	(%)	Capacity MBh	Coil Airflow cfm	Ent °F	Lvg °F			
Main Clg	63.2	758.6	563.6	15,501	85.9	66.8	71.8	52.0	50.2	53.3		Floor	12,162		Main Htg	-464.4	8,952	51.7	100.0		
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0		Part	1,932		Aux Htg	0.0	0	0.0	0.0		
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0		ExFlr	0		Preheat	-164.1	8,179	33.0	51.7		
<i>Total</i>	<i>63.2</i>	<i>758.6</i>										Roof	<i>12,162</i>	<i>0</i>	Reheat	<i>0.0</i>	<i>0</i>	<i>0.0</i>	<i>0.0</i>		
												Wall	<i>8,166</i>	<i>194</i>	Humidif	<i>0.0</i>	<i>0</i>	<i>0.0</i>	<i>0.0</i>		
												<i>Total</i>			Opt Vent	<i>0.0</i>	<i>0</i>	<i>0.0</i>	<i>0.0</i>		

System Checksums

By P2S Engineering, Inc.

AC-4 (Ground South)

Double Duct VAV

COOLING COIL PEAK								CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES			
Peaked at Time:		Mo/Hr: 8 / 15		Mo/Hr: 9 / 19		Mo/Hr: 13 / 2		Cooling		Heating									
Outside Air:		OADB/WB/HR: 94 / 70 / 77		OADB: 85		OADB: 33		SADB		Plenum									
	Space Sens. + Lat.	Plenum Sens. + Lat.	Net Total	Percent Of Total (%)		Space Sensible	Percent Of Total (%)	Space Peak Space Sens	Peak Tot	Coil Peak Tot	Percent Sens Of Total (%)								
	Btu/h	Btu/h	Btu/h			Btu/h		Btu/h	Btu/h	Btu/h									
Envelope Loads																			
Skylite Solar	0	0	0	0.00		0	0.00	Skylite Solar	0	0	0.00								
Skylite Cond	0	0	0	0.00		0	0.00	Skylite Cond	0	0	0.00								
Roof Cond	0	0	0	0.00		0	0.00	Roof Cond	0	0	0.00								
Glass Solar	4,300	0	4,300	0.88		0	0.00	Glass Solar	0	0	0.00								
Glass Cond	1,788	0	1,788	0.36		1,047	0.50	Glass Cond	-3,231	-3,231	0.83								
Wall Cond	17,114	6,259	23,373	4.77		29,725	14.18	Wall Cond	-26,242	-36,162	9.26								
Partition	3,423		3,423	0.70		4,176	1.99	Partition	-8,951	-8,951	2.29								
Exposed Floor	0		0	0.00		0	0.00	Exposed Floor	0	0	0.00								
Infiltration	0		0	0.00		0	0.00	Infiltration	-1	-1	0.00								
<i>Sub Total ==></i>	<i>26,625</i>	<i>6,259</i>	<i>32,883</i>	<i>6.71</i>		<i>34,948</i>	<i>16.67</i>	<i>Sub Total ==></i>	<i>-38,425</i>	<i>-48,345</i>	<i>12.37</i>								
Internal Loads								Internal Loads											
Lights	49,257	12,314	61,572	12.57		49,257	23.49	Lights	0	0	0.00								
People	184,050		184,050	37.58		102,250	48.77	People	0	0	0.00								
Misc	17,065	0	17,065	3.48		17,065	8.14	Misc	0	0	0.00								
<i>Sub Total ==></i>	<i>250,372</i>	<i>12,314</i>	<i>262,687</i>	<i>53.63</i>		<i>168,572</i>	<i>80.41</i>	<i>Sub Total ==></i>	<i>0</i>	<i>0</i>	<i>0.00</i>								
Ceiling Load	4,997	-4,997	0	0.00		6,132	2.92	Ceiling Load	-3,354	0	0.00								
Ventilation Load	0	0	193,144	39.43		0	0.00	Ventilation Load	0	-251,854	64.46								
Ov/Undr Sizing	0		0	0.00		0	0.00	Ov/Undr Sizing	-85,182	-85,182	21.80								
Exhaust Heat	-8,917	-8,917	-1.82					Exhaust Heat	5,985	-1.53									
Sup. Fan Heat			9,993	2.04				OA Preheat Diff.	0	0.00									
Ret. Fan Heat	0	0	0.00					RA Preheat Diff.	-11,324	2.90									
Duct Heat Pkup	0	0	0.00					Additional Reheat	0	0.00									
Reheat at Design			0	0.00															
<i>Grand Total ==></i>	<i>281,994</i>	<i>4,659</i>	<i>489,790</i>	<i>100.00</i>		<i>209,653</i>	<i>100.00</i>	<i>Grand Total ==></i>	<i>-126,961</i>	<i>-390,720</i>	<i>100.00</i>								
COOLING COIL SELECTION								AREAS				HEATING COIL SELECTION							
Total Capacity	ton	MBh	Sens Cap. MBh	Coil Airflow cfm	Enter DB/°F	WB/°F	HR/gr/lb	Leave DB/°F	WB/°F	HR/gr/lb	Gross Total ft ²	Glass (%)	Capacity MBh	Coil Airflow cfm	Ent °F	Lvg °F			
Main Clg	40.8	489.8	364.3	9,636	87.2	67.6	73.7	52.0	50.6	54.6	Floor	12,040	Main Htg	-263.7	6,955	51.7	87.0		
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Part	1,598	Aux Htg	0.0	0	0.0	0.0		
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	ExFlr	0	Preheat	-127.2	6,339	33.0	51.7		
<i>Total</i>	<i>40.8</i>	<i>489.8</i>									Roof	<i>0</i>	Reheat	<i>0.0</i>	<i>0</i>	<i>0.0</i>	<i>0.0</i>		
											Wall	<i>2,505</i>	Humidif	<i>0.0</i>	<i>0</i>	<i>0.0</i>	<i>0.0</i>		
													Opt Vent	<i>0.0</i>	<i>0</i>	<i>0.0</i>	<i>0.0</i>		
													<i>Total</i>	<i>-390.9</i>					

System Checksums

By P2S Engineering, Inc.

AC-5 (1st South)

Double Duct VAV

COOLING COIL PEAK								CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES			
Peaked at Time:		Mo/Hr: 8 / 17		Mo/Hr: 7 / 17		Mo/Hr: 13 / 1		Cooling		Heating									
Outside Air:		OADB/WB/HR: 92 / 70 / 79		OADB: 94		OADB: 33		SADB		Plenum									
	Space Sens. + Lat.	Plenum Sens. + Lat.	Net Total	Percent Of Total (%)	Space Sensible	Percent Of Total (%)	Space Peak Space Sens	Peak Coil	Percent Tot Sens	Of Total (%)	Btu/h	Btu/h	Btu/h	Btu/h	Cooling	Heating			
	Btu/h	Btu/h	Btu/h		Btu/h	(%)	Btu/h	Btu/h	Btu/h	(%)					SADB	Plenum			
Envelope Loads															52.7	100.0			
Skylite Solar	0	0	0	0.00	0	0.00	0	0	0	0.00					73.9	66.5			
Skylite Cond	0	0	0	0.00	0	0.00	0	0	0	0.00					73.9	66.5			
Roof Cond	0	0	0	0.00	0	0.00	0	0	0	0.00					77.3	49.5			
Glass Solar	20,383	0	20,383	6.44	21,920	10.92	Glass Solar	0	0	0.00					0.1	0.0			
Glass Cond	7,187	0	7,187	2.27	8,152	4.06	Glass Cond	-14,626	-14,626	6.63					0.2	0.0			
Wall Cond	45,329	17,338	62,666	19.79	43,875	21.87	Wall Cond	-66,888	-91,997	41.72					0.7	0.0			
Partition	715		715	0.23	738	0.37	Partition	-810	-810	0.37									
Exposed Floor	0		0	0.00	0	0.00	Exposed Floor	0	0	0.00									
Infiltration	0		0	0.00	0	0.00	Infiltration	-4	-4	0.00									
<i>Sub Total ==></i>	<i>73,614</i>	<i>17,338</i>	<i>90,952</i>	<i>28.73</i>	<i>74,685</i>	<i>37.22</i>	<i>Sub Total ==></i>	<i>-82,329</i>	<i>-107,438</i>	<i>48.72</i>									
Internal Loads							Internal Loads												
Lights	36,762	9,191	45,953	14.51	36,762	18.32	Lights	0	0	0.00									
People	50,634		50,634	15.99	28,130	14.02	People	0	0	0.00									
Misc	54,876	0	54,876	17.33	54,876	27.35	Misc	0	0	0.00									
<i>Sub Total ==></i>	<i>142,272</i>	<i>9,191</i>	<i>151,463</i>	<i>47.84</i>	<i>119,768</i>	<i>59.69</i>	<i>Sub Total ==></i>	<i>0</i>	<i>0</i>	<i>0.00</i>									
Ceiling Load	6,377	-6,377	0	0.00	6,207	3.09	Ceiling Load	-11,595	0	0.00									
Ventilation Load	0	0	67,997	21.48	0	0.00	Ventilation Load	0	-71,963	32.63									
Ov/Undr Sizing	0		0	0.00	0	0.00	Ov/Undr Sizing	-20,806	-20,806	9.43									
Exhaust Heat	-3,780	-3,780	-1.19				Exhaust Heat	6,872	6,872	-3.12									
Sup. Fan Heat			9,971	3.15			OA Preheat Diff.	0	0	0.00									
Ret. Fan Heat		0	0	0.00			RA Preheat Diff.	-27,189	-27,189	12.33									
Duct Heat Pkup		0	0	0.00			Additional Reheat	0	0	0.00									
Reheat at Design			0	0.00															
<i>Grand Total ==></i>	<i>222,263</i>	<i>16,372</i>	<i>316,603</i>	<i>100.00</i>	<i>200,661</i>	<i>100.00</i>	<i>Grand Total ==></i>	<i>-114,731</i>	<i>-220,524</i>	<i>100.00</i>									
COOLING COIL SELECTION								AREAS				HEATING COIL SELECTION							
Total Capacity	Sens Cap.	Coil Airflow	Enter DB	WB/HR	Leave DB	WB/HR		Gross Total	Glass ft ²	(%)		Capacity MBh	Coil Airflow cfm	Ent °F	Lvg °F				
ton	MBh	MBh	°F	°F	gr/lb	°F	°F					Main Htg	-184.8	3,561	51.7	100.0			
Main Clg	26.4	316.6	264.3	9,615	77.6	61.6	59.5	10,357				Aux Htg	0.0	0	0.0	0.0			
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	357				Preheat	-36.3	1,811	33.0	51.7			
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0	0	0		Reheat	0.0	0	0.0	0.0			
<i>Total</i>	<i>26.4</i>	<i>316.6</i>						<i>6,662</i>	<i>409</i>	<i>6</i>		Humidif	0.0	0	0.0	0.0			
												Opt Vent	0.0	0	0.0	0.0			
												<i>Total</i>	<i>-221.1</i>						

System Checksums

By P2S Engineering, Inc.

AC-6 (2nd South)

Double Duct VAV

COOLING COIL PEAK								CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES			
Peaked at Time:		Mo/Hr: 8 / 17		Mo/Hr: 7 / 18		Mo/Hr: 13 / 1		Cooling		Heating									
Outside Air:		OADB/WB/HR: 92 / 70 / 79		OADB: 91		OADB: 33		SADB		Plenum									
	Space Sens. + Lat. Btu/h	Plenum Sens. + Lat. Btu/h	Net Total Btu/h	Percent Of Total (%)		Space Sensible Btu/h	Percent Of Total (%)	Space Peak Space Sens Btu/h	Peak Tot Sens Btu/h	Percent Of Total (%)									
Envelope Loads																			
Skylite Solar	0	0	0	0.00		0	0.00	Skylite Solar	0	0	0.00								
Skylite Cond	0	0	0	0.00		0	0.00	Skylite Cond	0	0	0.00								
Roof Cond	0	0	0	0.00		0	0.00	Roof Cond	0	0	0.00								
Glass Solar	23,167	0	23,167	3.84		19,795	6.82	Glass Solar	0	0	0.00								
Glass Cond	5,808	0	5,808	0.96		5,702	1.96	Glass Cond	-11,843	-11,843	2.20								
Wall Cond	61,614	23,395	85,009	14.07		66,441	22.88	Wall Cond	-87,095	-120,162	22.28								
Partition	3,431		3,431	0.57		3,778	1.30	Partition	-3,888	-3,888	0.72								
Exposed Floor	0		0	0.00		0	0.00	Exposed Floor	0	0	0.00								
Infiltration	0		0	0.00		0	0.00	Infiltration	-3	-3	0.00								
<i>Sub Total ==></i>	<i>94,021</i>	<i>23,395</i>	<i>117,416</i>	<i>19.44</i>		<i>95,716</i>	<i>32.96</i>	<i>Sub Total ==></i>	<i>-102,829</i>	<i>-135,896</i>	<i>25.20</i>								
Internal Loads								Internal Loads											
Lights	47,831	11,958	59,788	9.90		47,831	16.47	Lights	0	0	0.00								
People	182,750		182,750	30.26		101,528	34.96	People	0	0	0.00								
Misc	37,767	0	37,767	6.25		37,767	13.01	Misc	0	0	0.00								
<i>Sub Total ==></i>	<i>268,347</i>	<i>11,958</i>	<i>280,304</i>	<i>46.41</i>		<i>187,125</i>	<i>64.44</i>	<i>Sub Total ==></i>	<i>0</i>	<i>0</i>	<i>0.00</i>								
Ceiling Load	7,201	-7,201	0	0.00		7,537	2.60	Ceiling Load	-10,164	0	0.00								
Ventilation Load	0	0	204,511	33.86		0	0.00	Ventilation Load	0	-247,094	45.81								
Ov/Undr Sizing	0		0	0.00		0	0.00	Ov/Undr Sizing	-144,795	-144,795	26.85								
Exhaust Heat	-12,611	-12,611	-2.09					Exhaust Heat	17,800	-3.30									
Sup. Fan Heat			14,393	2.38				OA Preheat Diff.	0	0.00									
Ret. Fan Heat	0	0	0.00					RA Preheat Diff.	-29,361	5.44									
Duct Heat Pkup	0	0	0.00					Additional Reheat	0	0.00									
Reheat at Design			0	0.00															
<i>Grand Total ==></i>	<i>369,568</i>	<i>15,541</i>	<i>604,014</i>	<i>100.00</i>		<i>290,377</i>	<i>100.00</i>	<i>Grand Total ==></i>	<i>-257,787</i>	<i>-539,346</i>	<i>100.00</i>								
COOLING COIL SELECTION								AREAS				HEATING COIL SELECTION							
Total Capacity	Sens Cap.	Coil Airflow	Enter DB	WB/HR	Leave DB	WB/HR	Gross Total	Glass	Capacity	Coil	Airflow	Ent	Lvg						
ton	MBh	MBh	cfm	°F	°F	gr/lb	ft ²	(%)	MBh	cfm	°F	°F							
Main Clg	50.3	604.0	449.6	13,879	82.2	65.2	69.6		52.0	50.2	53.3								
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0		0.0	0.0	0.0								
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0		0.0	0.0	0.0								
<i>Total</i>	<i>50.3</i>	<i>604.0</i>																	
Floor	12,035								Main Htg	-415.2	8,002	51.7	100.0						
Part	2,017								Aux Htg	0.0	0	0.0	0.0						
ExFlr	0								Preheat	-124.8	6,219	33.0	51.7						
Roof	0								Reheat	0.0	0	0.0	0.0						
Wall	8,431								Humidif	0.0	0	0.0	0.0						
									Opt Vent	0.0	0	0.0	0.0						
									<i>Total</i>	<i>-540.0</i>									

System Checksums

By P2S Engineering, Inc.

AC-7 (3rd South)

Double Duct VAV

System Checksums

By P2S Engineering, Inc.

AC-9 (1st Central)

Variable Volume Reheat (30% Min Flow Default)

COOLING COIL PEAK				CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES				
Peaked at Time: Mo/Hr: 8 / 18				Mo/Hr: 7 / 18				Mo/Hr: 13 / 1				Cooling Heating				
Outside Air:	OADB/WB/HR: 89 / 70 / 81			OADB: 91			OADB: 33			SADB	53.0	100.0				
	Space Sens. + Lat. Btu/h	Plenum Sens. + Lat. Btu/h	Net Total Btu/h	Percent Of Total (%)		Space Sensible Btu/h	Percent Of Total (%)		Space Peak Btu/h	Coil Peak Tot Sens Btu/h	Percent Of Total (%)	Plenum	76.6	62.4		
Envelope Loads					Envelope Loads				Envelope Loads			Return	76.6	62.4		
Skylite Solar	0	0	0	0.00	Skylite Solar	0	0.00		Skylite Solar	0	0.00	Ret/OA	80.3	38.3		
Skylite Cond	0	0	0	0.00	Skylite Cond	0	0.00		Skylite Cond	0	0.00	Fn MtrTD	0.1	0.0		
Roof Cond	0	43,490	43,490	11.04	Roof Cond	0	0.00		Roof Cond	-27,627	12.41	Fn BldTD	0.2	0.0		
Glass Solar	9,259	0	9,259	2.35	Glass Solar	8,620	4.16		Glass Solar	0	0.00	Fn Frict	0.7	0.0		
Glass Cond	3,142	0	3,142	0.80	Glass Cond	3,534	1.70		Glass Cond	-7,265	3.26					
Wall Cond	23,607	9,165	32,771	8.32	Wall Cond	23,455	11.31		Wall Cond	-31,346	19.25					
Partition	0		0	0.00	Partition	0	0.00		Partition	0	0.00					
Exposed Floor	0		0	0.00	Exposed Floor	0	0.00		Exposed Floor	0	0.00					
Infiltration	0		0	0.00	Infiltration	0	0.00		Infiltration	-1	0.00					
<i>Sub Total ==></i>	<i>36,008</i>	<i>52,654</i>	<i>88,662</i>	<i>22.50</i>	<i>35,609</i>	<i>17.17</i>		<i>Sub Total ==></i>	<i>-38,612</i>	<i>-77,746</i>	<i>34.92</i>					
Internal Loads				Internal Loads				Internal Loads				AIRFLOWS				
Lights	23,056	5,764	28,820	7.31	Lights	23,056	11.11		Lights	0	0.00	Vent	2,981	2,574		
People	89,420		89,420	22.69	People	49,678	23.95		People	0	0.00	Infil	0	0		
Misc	90,388	0	90,388	22.94	Misc	90,388	43.57		Misc	0	0.00	Supply	10,149	3,140		
<i>Sub Total ==></i>	<i>202,864</i>	<i>5,764</i>	<i>208,628</i>	<i>52.94</i>	<i>163,122</i>	<i>78.64</i>		<i>Sub Total ==></i>	<i>0</i>	<i>0</i>	<i>0.00</i>	MinStop/Rh	3,140	3,140		
Ceiling Load				Ceiling Load				Ceiling Load				Exhaust				
Ventilation Load	8,177	-8,177	0	0.00	Ventilation Load	8,704	4.20		Ceiling Load	-13,479	0		2,981	2,574		
Ov/Undr Sizing	0	0	101,039	25.64	Ov/Undr Sizing	0	0.00		Ventilation Load	0	-102,282		0	0		
Exhaust Heat			0	0.00	Exhaust Heat				Ov/Undr Sizing	-49,052	-49,052		10,149	3,140		
Sup. Fan Heat			-14,776	-14,776	Sup. Fan Heat	10,518	2.67		Exhaust Heat	21,036	-9.45					
Ret. Fan Heat					Ret. Fan Heat	0	0.00		OA Preheat Diff.	-8,289	3.72					
Duct Heat Pkup					Duct Heat Pkup	0	0.00		RA Preheat Diff.	-6,307	2.83					
Reheat at Design					Reheat at Design	0	0.00		Additional Reheat	0	0.00					
<i>Grand Total ==></i>	<i>247,049</i>	<i>35,465</i>	<i>394,072</i>	<i>100.00</i>	<i>207,434</i>	<i>100.00</i>		<i>Grand Total ==></i>	<i>-101,143</i>	<i>-222,641</i>	<i>100.00</i>					
COOLING COIL SELECTION								AREAS			HEATING COIL SELECTION					
Total Capacity	Sens Cap.	Coil Airflow	Enter DB	WB/HR	Leave DB	WB/HR		Gross Total	Glass ft ²	(%)	Capacity MBh	Coil Airflow cfm	Ent °F	Lvg °F		
ton	MBh	MBh	cfm	°F	°F	gr/lb		Floor	5,590		Main Htg	-161.8	3,140	52.0	100.0	
Main Clg	32.8	394.1	308.2	10,143	80.3	63.7	65.1	Part	0		Aux Htg	0.0	0	0.0	0.0	
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	ExFlr	0		Preheat	-60.8	2,981	33.0	52.0	
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	Roof	4,552	0		Humidif	0.0	0	0.0	0.0
<i>Total</i>	<i>32.8</i>	<i>394.1</i>						Wall	<i>3,254</i>	<i>226</i>	<i>7</i>	Opt Vent	0.0	0	0.0	0.0
											<i>Total</i>	<i>-222.6</i>				

System Checksums

By P2S Engineering, Inc.

FC-1

Fan Coil

COOLING COIL PEAK								CLG SPACE PEAK			HEATING COIL PEAK				TEMPERATURES		
Peaked at Time:		Mo/Hr: 9 / 20		Mo/Hr: 9 / 20		Mo/Hr: 13 / 1		Cooling		Heating							
Outside Air:		OADB/WB/HR: 82 / 66 / 76		OADB: 82		OADB: 33		SADB		Plenum							
	Space Sens. + Lat.	Plenum Sens. + Lat.	Net Total Btu/h	Percent Of Total (%)		Space Sensible Btu/h	Percent Of Total (%)	Space Peak Btu/h	Peak Space Sens	Coil Peak Tot Btu/h	Percent Of Total (%)						
Envelope Loads	Btu/h	Btu/h	Btu/h			Btu/h		Btu/h	Btu/h								
Skylite Solar	0	0	0	0.00		0	0.00	Skylite Solar	0	0	0.00						
Skylite Cond	0	0	0	0.00		0	0.00	Skylite Cond	0	0	0.00						
Roof Cond	0	0	0	0.00		0	0.00	Roof Cond	0	0	0.00						
Glass Solar	0	0	0	0.00		0	0.00	Glass Solar	0	0	0.00						
Glass Cond	0	0	0	0.00		0	0.00	Glass Cond	0	0	0.00						
Wall Cond	4,111	867	4,978	68.79		4,111	65.08	Wall Cond	-3,676	-4,507	82.99						
Partition	0		0	0.00		0	0.00	Partition	0	0	0.00						
Exposed Floor	0		0	0.00		0	0.00	Exposed Floor	0	0	0.00						
Infiltration	0		0	0.00		0	0.00	Infiltration	0	0	0.00						
<i>Sub Total ==></i>	<i>4,111</i>	<i>867</i>	<i>4,978</i>	<i>68.79</i>		<i>4,111</i>	<i>65.08</i>	<i>Sub Total ==></i>	<i>-3,676</i>	<i>-4,507</i>	<i>82.99</i>						
Internal Loads								Internal Loads									
Lights	550	138	688	9.50		550	8.71	Lights	0	0	0.00						
People	698		698	9.64		388	6.13	People	0	0	0.00						
Misc	265	0	265	3.66		265	4.19	Misc	0	0	0.00						
<i>Sub Total ==></i>	<i>1,512</i>	<i>138</i>	<i>1,650</i>	<i>22.80</i>		<i>1,202</i>	<i>19.03</i>	<i>Sub Total ==></i>	<i>0</i>	<i>0</i>	<i>0.00</i>						
Ceiling Load	1,004	-1,004	0	0.00		1,004	15.90	Ceiling Load	-831	0	0.00						
Ventilation Load	0	0	608	8.41		0	0.00	Ventilation Load	0	-924	17.01						
Ov/Undr Sizing	0		0	0.00		0	0.00	Ov/Undr Sizing	0	0	0.00						
Exhaust Heat		0	0	0.00				Exhaust Heat		0	0.00						
Sup. Fan Heat			0	0.00				OA Preheat Diff.		0	0.00						
Ret. Fan Heat		0	0	0.00				RA Preheat Diff.		0	0.00						
Duct Heat Pkup		0	0	0.00				Additional Reheat		0	0.00						
Reheat at Design			0	0.00													
<i>Grand Total ==></i>	<i>6,628</i>	<i>0</i>	<i>7,236</i>	<i>100.00</i>		<i>6,318</i>	<i>100.00</i>	<i>Grand Total ==></i>	<i>-4,507</i>	<i>-5,431</i>	<i>100.00</i>						
COOLING COIL SELECTION								AREAS				HEATING COIL SELECTION					
Total Capacity ton	7.2	Sens Cap. MBh	6.6	Coil Airflow cfm	294	Enter DB/°F	72.8	Leave DB/°F	58.7	WB/HR gr/lb	54.2	Capacity MBh	Coil Airflow cfm	Ent. °F	Lvg. °F		
Main Clg	0.6							Floor	155	Gross Total ft ²		Main Htg	-5.4	294	67.1	84.3	
Aux Clg	0.0		0.0		0	0.0	0.0	Part	0	Glass (%)		Aux Htg	0.0	0	0.0	0.0	
Opt Vent	0.0		0.0		0	0.0	0.0	ExFlr	0			Preheat	0.0	0	0.0	0.0	
<i>Total</i>	<i>0.6</i>	<i>7.2</i>						Roof	0	0	0	Humidif	0.0	0	0.0	0.0	
								Wall	<i>344</i>	0	0	Opt Vent	0.0	0	0.0	0.0	
												<i>Total</i>	<i>-5.4</i>				

System Checksums

By P2S Engineering, Inc.

FC-2

Fan Coil

COOLING COIL PEAK								CLG SPACE PEAK			HEATING COIL PEAK				TEMPERATURES		
Peaked at Time: Mo/Hr: 8 / 17								Mo/Hr: 7 / 19			Mo/Hr: 13 / 1				Cooling Heating		
Outside Air:	OADB/WB/HR: 92 / 70 / 79							OADB: 88			OADB: 33				SADB	52.0	72.8
	Space Sens. + Lat.	Plenum Sens. + Lat	Net Total Btu/h	Percent Of Total (%)		Space Sensible Btu/h	Percent Of Total (%)		Space Peak Btu/h	Coil Peak Tot Sens Btu/h	Percent Of Total (%)			Plenum	93.7	55.4	
Envelope Loads	Btu/h	Btu/h	Btu/h	(%)		Btu/h	(%)		Space Sens Btu/h	Coil Peak Tot Sens Btu/h	Percent Of Total (%)			Return	72.0	70.0	
Skylite Solar	0	0	0	0.00		0	0.00		Skylite Solar	0	0	0.00		Ret/OA	77.8	59.1	
Skylite Cond	0	0	0	0.00		0	0.00		Skylite Cond	0	0	0.00		Fn MtrTD	0.0	0.0	
Roof Cond	0	862	862	10.63		0	0.00		Roof Cond	0	-699	20.06		Fn BldTD	0.0	0.0	
Glass Solar	0	0	0	0.00		0	0.00		Glass Solar	0	0	0.00		Fn Frict	0.0	0.0	
Glass Cond	0	0	0	0.00		0	0.00		Glass Cond	0	0	0.00					
Wall Cond	0	0	0	0.00		0	0.00		Wall Cond	0	0	0.00					
Partition	0			0.00		0	0.00		Partition	0	0	0.00					
Exposed Floor	0			0.00		0	0.00		Exposed Floor	0	0	0.00					
Infiltration	0			0.00		0	0.00		Infiltration	0	0	0.00					
<i>Sub Total ==></i>	0	862	862	10.63		0	0.00		<i>Sub Total ==></i>	0	-699	20.07					
Internal Loads									Internal Loads					AIRFLOWS	Cooling	Heating	
Lights	601	150	751	9.26		601	11.80		Lights	0	0	0.00		Vent	70	70	
People	2,102		2,102	25.92		1,168	22.94		People	0	0	0.00		Infil	0	0	
Misc	2,183	0	2,183	26.92		2,183	42.88		Misc	0	0	0.00		Supply	237	237	
<i>Sub Total ==></i>	4,885	150	5,035	62.10		3,951	77.62		<i>Sub Total ==></i>	0	0	0.00		MinStop/Rh	0	0	
Ceiling Load	1,036	-1,036	0	0.00		1,139	22.37		Ceiling Load	-699	0	0.00		Return	237	237	
Ventilation Load	0	0	2,211	27.26		0	0.00		Ventilation Load	0	-2,783	79.93		Exhaust	70	70	
Ov/Undr Sizing	0		0	0.00		0	0.00		Ov/Undr Sizing	0	0	0.00		Rm Exh	0	0	
Exhaust Heat		0	0	0.00		0	0.00		Exhaust Heat	0	0	0.00		Auxiliary	0	0	
Sup. Fan Heat			0	0.00					OA Preheat Diff.	0	0	0.00					
Ret. Fan Heat		0	0	0.00					RA Preheat Diff.	0	0	0.00					
Duct Heat Pkup		0	0	0.00					Additional Reheat	0	0	0.00					
Reheat at Design			0	0.00													
<i>Grand Total ==></i>	5,921	-24	8,108	100.00		5,090	100.00		<i>Grand Total ==></i>	-699	-3,482	100.00		ENGINEERING CKS			
COOLING COIL SELECTION								Areas			HEATING COIL SELECTION				Cooling	Heating	
Total Capacity ton	Sens Cap. MBh	Coil Airflow MBh	Enter DB/°F	WB/°F	H/R gr/lb	Leave DB/°F	WB/°F	Gross Total ft ²	Glass (%)		Capacity MBh	Coil Airflow cfm	Ent °F	Lvg °F	% OA	29.6	29.6
Main Clg	0.7	8.1	6.4	237	77.8	62.6	63.7	52.0	50.4	54.1	Main Htg	-3.5	237	59.1	72.8		
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0	0.0	Aux Htg	0.0	0	0.0	0.0		
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0	0.0	Preheat	0.0	0	0.0	0.0		
<i>Total</i>	0.7	8.1						151	0	0	Humidif	0.0	0	0.0	0.0		
								0	0	0	Opt Vent	0.0	0	0.0	0.0		
										<i>Total</i>	-3.5						

System Checksums

By P2S Engineering, Inc

System - 001

Variable Volume Reheat (30% Min Flow Default)

COOLING COIL PEAK								CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES		
Peaked at Time:		Mo/Hr: 9 / 16		Mo/Hr: 9 / 14		Mo/Hr: Heating Design		Space Peak		Coil Peak Percent		Cooling		Heating				
Outside Air:		OADB/WB/HR: 96 / 70 / 67		OADB: 96		OADB: 28		Space Sens		Tot Sens Of Total		SADB	59.7	86.6				
	Space Sens. + Lat.	Btu/h	Plenum Sens. + Lat	Btu/h	Net Total	Percent Of Total		Space Sensible	Percent Of Total	Btu/h	(%)	Ra Plenum	76.5	66.2				
	Btu/h		Btu/h		Btu/h	(%)		Btu/h		Btu/h	(%)	Return	76.5	66.2				
Envelope Loads												Ret/OA	82.9	28.0				
Skylite Solar	0	0	0	0	0	0		0	0	0	0.00	Fn MtrTD	0.0	0.0				
Skylite Cond	0	0	0	0	0	0		0	0	0	0.00	Fn BldTD	0.0	0.0				
Roof Cond	0	156,424	156,424	8	0	0		0	0	-58,945	4.28	Fn Frict	0.0	0.0				
Glass Solar	142,896	0	142,896	7	182,637	17		Glass Solar	0	0	0.00							
Glass/Door Cond	28,948	0	28,948	1	27,353	2		Glass/Door Cond	-52,609	-52,609	3.82							
Wall Cond	40,178	24,000	64,178	3	33,091	3		Wall Cond	-42,947	-69,144	5.02							
Partition/Door	0		0	0	0	0		Partition/Door	0	0	0.00							
Floor	94,845		94,845	5	94,845	9		Floor	-148,229	-148,229	10.76							
Adjacent Floor	0	0	0	0	0	0		Adjacent Floor	0	0	0							
Infiltration	91,946		91,946	5	82,519	7		Infiltration	-147,421	-147,421	10.70							
<i>Sub Total ==></i>	<i>398,814</i>		<i>180,424</i>	<i>30</i>	<i>420,445</i>	<i>38</i>		<i>Sub Total ==></i>	<i>-391,206</i>	<i>-476,348</i>	<i>34.56</i>							
Internal Loads								Internal Loads										
Lights	237,371	59,343	296,713	15	237,371	21		Lights	0	0	0.00							
People	362,570	0	362,570	19	200,622	18		People	0	0	0.00							
Misc	182,593	0	182,593	9	182,593	17		Misc	0	0	0.00							
<i>Sub Total ==></i>	<i>782,533</i>	<i>59,343</i>	<i>841,876</i>	<i>43</i>	<i>620,585</i>	<i>56</i>		<i>Sub Total ==></i>	<i>0</i>	<i>0</i>	<i>0.00</i>							
Ceiling Load	52,172	-52,172	0	0	63,163	6		Ceiling Load	-39,024	0	0.00							
Ventilation Load	0	0	594,653	30	0	0		Ventilation Load	0	-927,221	67.28							
Adj Air Trans Heat	0		0	0	0	0		Adj Air Trans Heat	0	0	0							
Dehumid. Ov Sizing			0	0				Ov/Undr Sizing	0	0	0.00							
Ov/Undr Sizing	0		0	0	0	0		Exhaust Heat	46,117	-3.35								
Exhaust Heat		-63,268	-63,268	-3				OA Preheat Diff.	-20,776	1.51								
Sup. Fan Heat			0	0				RA Preheat Diff.	0	0.00								
Ret. Fan Heat	0	0	0	0				Additional Reheat	0	0.00								
Duct Heat Pkup	0	0	0	0				Underflr Sup Ht Pkup	0	0.00								
Underflr Sup Ht Pkup			0	0				Supply Air Leakage	0	0.00								
Supply Air Leakage	0	0	0	0														
Grand Total ==>	1,233,519	124,326	1,952,499	100.00	1,104,193	100.00		Grand Total ==>	-430,231	-1,378,228	100.00							
COOLING COIL SELECTION								AREAS				HEATING COIL SELECTION						
Total Capacity	ton	MBh	Sens Cap.	Coil Airflow	Enter DB	WB/HR	Leave DB	WB/HR	Gross Total	Glass ft ²	(%)	Capacity	Coil Airflow	Ent °F	Lvg °F			
			MBh	cfm	°F	°F	gr/lb	°F				MBh	cfm	°F	°F			
Main Clg	162.7	1,952.5	1,720.2	67,432	82.9	64.9	64.6	59.7	66,874	0		Main Htg	-622.4	21,031	59.7	86.6		
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	Part	0		Aux Htg	0.0	0	0.0	0.0		
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	Int Door	0		Preheat	-755.8	21,625	28.0	59.7		
Total	162.7	1,952.5							ExFlr	38,901	0	Reheat	-192.2	21,031	59.7	68.0		
									Roof	38,901	0	Humidif	0.0	0	0.0	0.0		
									Wall	18,004	4,815	Opt Vent	0.0	0	0.0	0.0		
									Ext Door	0	0	Total	-1,378.2					

System Checksums

By P2S Engineering, Inc

AHU-1

Variable Volume Reheat (30% Min Flow Default)

COOLING COIL PEAK								CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES		
Peaked at Time:		Mo/Hr: 8 / 15		Mo/Hr: 9 / 15		Mo/Hr: Heating Design		Space Peak		Coil Peak Percent		Cooling		Heating				
Outside Air:		OADB/WB/HR: 94 / 70 / 75		OADB: 93		OADB: 33		Space Sens		Tot Sens Of Total		Space Sens		Tot Sens Of Total				
	Space Sens. + Lat.	Plenum Sens. + Lat		Net Total	Percent Of Total		Space Sensible	Percent Of Total		Btu/h	(%)		Btu/h	(%)				
	Btu/h	Btu/h		Btu/h			Btu/h											
Envelope Loads																		
Skylite Solar	0	0		0	0		0	0										
Skylite Cond	0	0		0	0		0	0										
Roof Cond	0	23,074		23,074	6		0	0										
Glass Solar	18,014	0		18,014	5		23,534	14										
Glass/Door Cond	6,170	0		6,170	2		5,858	3										
Wall Cond	8,268	357		8,625	2		8,057	5										
Partition/Door	0			0	0		0	0										
Floor	0			0	0		0	0										
Adjacent Floor	0	0		0	0		0	0										
Infiltration	0			0	0		0	0										
<i>Sub Total ==></i>	<i>32,452</i>	<i>23,431</i>		<i>55,883</i>	<i>15</i>		<i>37,449</i>	<i>22</i>										
Internal Loads																		
Lights	24,220	6,055		30,275	8		24,220	14										
People	104,235	0		104,235	28		57,718	34										
Misc	22,884	0		22,884	6		22,884	14										
<i>Sub Total ==></i>	<i>151,339</i>	<i>6,055</i>		<i>157,394</i>	<i>42</i>		<i>104,821</i>	<i>62</i>										
Ceiling Load	29,448	-29,448		0	0		26,926	16										
Ventilation Load	0	0		137,688	37		0	0										
Adj Air Trans Heat	0			0	0		0	0										
Dehumid. Ov Sizing				0	0													
Ov/Undr Sizing	0			0	0		0	0										
Exhaust Heat	-4,289	-4,289		-1														
Sup. Fan Heat				18,317	5													
Ret. Fan Heat	6,869	6,869		2														
Duct Heat Pkup	0	0		0	0													
Underflr Sup Ht Pkup				0	0													
Supply Air Leakage	0	0		0	0													
<i>Grand Total ==></i>	<i>213,238</i>	<i>2,618</i>		<i>371,862</i>	<i>100.00</i>		<i>169,196</i>	<i>100.00</i>										
COOLING COIL SELECTION								AREAS				HEATING COIL SELECTION						
Total Capacity	Sens Cap.	Coil Airflow	Enter DB	WB/HR	Leave DB	WB/HR	Gross Total	Glass	Capacity	Coil Airflow	Ent	Lvg						
ton	MBh	MBh	cfm	°F	°F	gr/lb	ft ²	(%)	MBh	cfm	°F	°F						
Main Clg	31.0	371.9	285.9	7,728	87.1	67.1	70.8	52.8	51.0	54.5								
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0								
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0								
Total	31.0	371.9																

System Checksums

By P2S Engineering, Inc

AHU-2 East

Variable Volume Reheat (30% Min Flow Default)

COOLING COIL PEAK								CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES		
Peaked at Time:		Mo/Hr: 8 / 14		Mo/Hr: 7 / 16		Mo/Hr: Heating Design		Space Peak		Coil Peak Percent		Space Sens		Cooling	Heating			
Outside Air:	OADB/WB/HR:	OADB:	93 / 70 / 77	OADB:	96	OADB:	33	Btu/h	Sens. Of Total	(%)	Btu/h	Tot Sens Of Total	Btu/h	(%)				
Envelope Loads																		
Skylite Solar	0	0	0	0	0	0	0	0	0	0	0	0	0	55.0	84.6			
Skylite Cond	0	0	0	0	0	0	0	0	0	0	0	0	0	87.3	62.3			
Roof Cond	0	3,924	3,924	4	0	0	0	0	0	0	0	-1,788	3.44	75.0	70.0			
Glass Solar	1,098	0	1,098	1	935	2	0	0	0	0	0	0	0	88.5	33.0			
Glass/Door Cond	398	0	398	0	482	1	0	0	0	0	0	-1,023	1.97	0.1	0.0			
Wall Cond	2,180	192	2,372	2	2,401	6	0	0	0	0	0	-4,981	-6,432	0.2	0.0			
Partition/Door	0		0	0	0	0	0	0	0	0	0	0	0	0.5	0.0			
Floor	0		0	0	0	0	0	0	0	0	0	0	0					
Adjacent Floor	0	0	0	0	0	0	0	0	0	0	0	0	0					
Infiltration	0		0	0	0	0	0	0	0	0	0	0	0					
<i>Sub Total ==></i>	<i>3,677</i>	<i>4,116</i>	<i>7,792</i>	<i>8</i>	<i>3,818</i>	<i>9</i>						<i>-6,004</i>	<i>-9,243</i>	<i>17.80</i>				
Internal Loads																		
Lights	4,374	1,094	5,468	6	4,374	10	0	0	0	0	0	0	0					
People	42,750	0	42,750	45	23,750	56	0	0	0	0	0	0	0					
Misc	4,556	0	4,556	5	4,556	11	0	0	0	0	0	0	0					
<i>Sub Total ==></i>	<i>51,680</i>	<i>1,094</i>	<i>52,774</i>	<i>55</i>	<i>32,680</i>	<i>77</i>	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>			
Ceiling Load																		
Ventilation Load	5,209	-5,209	0	0	5,707	14	-3,239	0	0	0	0	0	0					
Adj Air Trans Heat	0	0	33,430	35	0	0	0	0	0	0	0	-23,424	45.12					
Dehumid. Ov Sizing	0		0	0	0	0	0	0	0	0	0	0	0					
Ov/Undr Sizing	0		0	0	0	0	0	0	0	0	0	0	0					
Exhaust Heat	0	0	0	0	0	0	0	0	0	0	0	0	0					
Sup. Fan Heat			1,484	2	0	0	0	0	0	0	0	-19,245	37.07					
Ret. Fan Heat	0	0	0	0	0	0	0	0	0	0	0	0	0					
Duct Heat Pkup	0	0	0	0	0	0	0	0	0	0	0	0	0					
Underflr Sup Ht Pkup	0	0	0	0	0	0	0	0	0	0	0	0	0					
Supply Air Leakage	0	0	0	0	0	0	0	0	0	0	0	0	0					
<i>Grand Total ==></i>	<i>60,566</i>	<i>0</i>	<i>95,481</i>	<i>100.00</i>	<i>42,206</i>	<i>100.00</i>	<i>Grand Total ==></i>					<i>-9,243</i>	<i>-51,912</i>	<i>100.00</i>				
COOLING COIL SELECTION								AREAS				HEATING COIL SELECTION						
Total Capacity	Sens Cap.	Coil Airflow	Enter DB	WB/HR	Leave DB	WB/HR	Gross Total	Glass ft ²	(%)	Capacity MBh	Coil Airflow cfm	Ent °F	Lvg °F					
ton	MBh	MBh	cfm	°F	°F	gr/lb												
Main Clg	8.0	95.5	71.0	1,927	88.5	68.4	75.3	54.3	52.2	56.8								
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Main Htg	-19.2	587	54.3	84.6			
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Aux Htg	0.0	0	0.0	0.0			
<i>Total</i>	<i>8.0</i>	<i>95.5</i>									Preheat	-32.7	1,425	33.0	54.3			
											Humidif	0.0	0	0.0	0.0			
											Opt Vent	0.0	0	0.0	0.0			
											<i>Total</i>	-51.9						

System Checksums

By P2S Engineering, Inc

AHU-3 West

Variable Volume Reheat (30% Min Flow Default)

COOLING COIL PEAK										CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES			
Peaked at Time:		Mo/Hr: 8 / 14		Mo/Hr: 7 / 15		Mo/Hr: 7 / 15		Mo/Hr: Heating Design		Space Peak		Coil Peak Percent		Cooling		Heating					
Outside Air:		OADB/WB/HR: 93 / 70 / 77		OADB: 97				OADB: 33		Space Sens		Tot Sens Of Total		SADB		Ra Plenum					
	Space Sens. + Lat.	Plenum Sens. + Lat		Net Total	Percent Of Total		Space Sensible	Percent Of Total		Btu/h	(%)										
Envelope Loads																					
Skylite Solar	0	0		0	0		0	0													
Skylite Cond	0	0		0	0		0	0													
Roof Cond	0	3,910		3,910	4		0	0													
Glass Solar	1,103	0		1,103	1		988	2													
Glass/Door Cond	398	0		398	0		487	1													
Wall Cond	2,098	154		2,252	3		2,151	5													
Partition/Door	0			0	0		0	0													
Floor	0			0	0		0	0													
Adjacent Floor	0	0		0	0		0	0													
Infiltration	0			0	0		0	0													
<i>Sub Total ==></i>	<i>3,599</i>	<i>4,064</i>		<i>7,663</i>	<i>9</i>		<i>3,625</i>	<i>9</i>													
Internal Loads																					
Lights	4,358	1,089		5,447	6		4,358	11													
People	39,600	0		39,600	44		22,000	55													
Misc	4,539	0		4,539	5		4,539	11													
<i>Sub Total ==></i>	<i>48,497</i>	<i>1,089</i>		<i>49,586</i>	<i>56</i>		<i>30,897</i>	<i>77</i>													
Ceiling Load																					
Ventilation Load	5,153	-5,153		0	0		5,612	14													
Adj Air Trans Heat	0	0		30,667	34		0	0													
Dehumid. Ov Sizing	0			0	0		0	0													
Ov/Undr Sizing	0			0	0		0	0													
Exhaust Heat	0	0		0	0																
Sup. Fan Heat				1,416	2																
Ret. Fan Heat	0	0		0	0																
Duct Heat Pkup	0	0		0	0																
Underflr Sup Ht Pkup	0			0	0																
Supply Air Leakage	0	0		0	0																
<i>Grand Total ==></i>	<i>57,249</i>	<i>0</i>		<i>89,331</i>	<i>100.00</i>		<i>40,134</i>	<i>100.00</i>													
COOLING COIL SELECTION										AREAS				HEATING COIL SELECTION							
Total Capacity	ton	MBh	Sens Cap.	Coil Airflow	Enter DB	WB/HR	Leave DB	WB/HR	Gross Total	Glass	Capacity	Coil Airflow	Ent	Lvg							
Main Clg	7.4	89.3	67.0	1,838	88.1	68.2	75.3	54.3	1,330	ft ²	MBh	cfm	°F	°F							
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0	(%)											
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0												
<i>Total</i>	<i>7.4</i>	<i>89.3</i>																			
									Floor		Main Htg	-18.8	558	54.3	85.5						
									Part		Aux Htg	0.0	0	0.0	0.0						
									Int Door		Preheat	-30.3	1,320	33.0	54.3						
									ExFlr		Humidif	0.0	0	0.0	0.0						
									Roof	0	Opt Vent	0.0	0	0.0	0.0						
									Wall	54	<i>Total</i>	-49.1									
									Ext Door	3											

System Checksums

By P2S ENGINEERING, INC

Bldg 11

Variable Volume Reheat (30% Min Flow Default)

COOLING COIL PEAK								CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES			
Peaked at Time:		Mo/Hr: 8 / 17		Mo/Hr: 7 / 18		Mo/Hr: Heating Design		Space Peak		Coil Peak Percent		Cooling		Heating					
Outside Air:		OADB/WB/HR: 92 / 70 / 79		OADB: 91		OADB: 33		Space Sens		Tot Sens Of Total		Space Sens		Tot Sens Of Total					
	Space Sens. + Lat.	Plenum Sens. + Lat		Net Total	Percent Of Total			Space Sensible	Percent Of Total										
	Btu/h	Btu/h		Btu/h	(%)			Btu/h	(%)										
Envelope Loads																			
Skylite Solar	0	0		0	0			0	0										
Skylite Cond	0	0		0	0			0	0										
Roof Cond	0	129,759		129,759	10			0	0										
Glass Solar	36,365	0		36,365	3			30,970	5										
Glass/Door Cond	19,935	0		19,935	2			20,736	4										
Wall Cond	61,698	15,986		77,683	6			69,439	12										
Partition/Door	7,203			7,203	1			8,520	1										
Floor	0			0	0			0	0										
Adjacent Floor	0	0		0	0			0	0										
Infiltration	0			0	0			0	0										
<i>Sub Total ==></i>	<i>125,201</i>	<i>145,745</i>		<i>270,946</i>	<i>21</i>			<i>129,665</i>	<i>22</i>										
Internal Loads																			
Lights	97,130	24,283		121,413	9			97,130	16										
People	315,714	0		315,714	25			174,048	30										
Misc	137,166	0		137,166	11			137,166	23										
<i>Sub Total ==></i>	<i>550,010</i>	<i>24,283</i>		<i>574,293</i>	<i>45</i>			<i>408,344</i>	<i>69</i>										
Ceiling Load	29,829	-29,829		0	0			32,168	5										
Ventilation Load	0	0		475,386	37			0	0										
Adj Air Trans Heat	0							0	0										
Dehumid. Ov Sizing																			
Ov/Undr Sizing	19,688			19,688	2			19,585	3										
Exhaust Heat	-60,742			-60,742	-5														
Sup. Fan Heat				0	0														
Ret. Fan Heat	0			0	0														
Duct Heat Pkup	0			0	0														
Underflr Sup Ht Pkup				0	0														
Supply Air Leakage	0			0	0														
<i>Grand Total ==></i>	<i>724,729</i>	<i>79,457</i>		<i>1,279,572</i>	<i>100.00</i>			<i>589,762</i>	<i>100.00</i>										
COOLING COIL SELECTION								AREAS				HEATING COIL SELECTION							
Total Capacity	ton	MBh	Sens Cap.	Coil Airflow	Enter DB	WB/HR	Leave DB	WB/HR	Gross Total	Glass ft ²	(%)	Capacity	Coil Airflow	Ent °F	Lvg °F				
Main Clg	106.6	1,279.6	968.1	28,578	84.8	66.3	70.7	53.0	51.1	55.0		MBh	cfm						
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0		Main Htg	-386.9	10,969	53.0	85.9			
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0		Aux Htg	0.0	0	0.0	0.0			
Total	106.6	1,279.6										Preheat	-310.9	14,475	33.0	53.0			
												Reheat	-200.2	10,969	53.0	70.0			
												Humidif	0.0	0	0.0	0.0			
												Opt Vent	0.0	0	0.0	0.0			
												Total	-697.8						

System Checksums

By P2S Engineering, Inc

System - 001

Variable Volume Reheat (30% Min Flow Default)

COOLING COIL PEAK								CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES		
Peaked at Time:		Mo/Hr: 9 / 16		Mo/Hr: 9 / 15		Mo/Hr: Heating Design		Space Peak		Coil Peak Percent		Cooling		Heating				
Outside Air:		OADB/WB/HR: 96 / 70 / 67		OADB: 97		OADB: 28		Space Sens		Tot Sens Of Total		SADB	55.0	95.5				
	Space Sens. + Lat.	Btu/h	Plenum Sens. + Lat	Btu/h	Net Total	Percent Btu/h	(%)	Space Sensible	Percent Of Total	Btu/h	(%)	Ra Plenum	74.7	65.6				
Envelope Loads								Envelope Loads				Return	75.8	65.6				
Skylite Solar	0	0		0	0	0	0	Skylite Solar	0	0	0.00	Ret/OA	79.8	41.3				
Skylite Cond	0	0		0	0	0	0	Skylite Cond	0	0	0.00	Fn MtrTD	0.1	0.0				
Roof Cond	0	45,151		45,151	3	3	0	Roof Cond	0	-39,235	5.09	Fn BldTD	0.2	0.0				
Glass Solar	76,998	0		76,998	5	5	85,715	Glass Solar	0	0	0.00	Fn Frict	0.7	0.0				
Glass/Door Cond	17,522	0		17,522	1	1	17,020	Glass/Door Cond	-34,814	-34,814	4.52							
Wall Cond	81,035	36,966		118,001	8	8	74,950	Wall Cond	-70,659	-101,393	13.16							
Partition/Door	4,647			4,647	0	0	4,647	Partition/Door	-7,262	-7,262	0.94							
Floor	63,635			63,635	5	5	63,635	Floor	-99,452	-99,452	12.90							
Adjacent Floor	0	0		0	0	0	0	Adjacent Floor	0	0	0							
Infiltration	80,123			80,123	6	6	61,831	Infiltration	-107,579	-107,579	13.96							
<i>Sub Total ==></i>	<i>323,958</i>			<i>406,075</i>	<i>29</i>		<i>307,797</i>	<i>Sub Total ==></i>	<i>-319,766</i>	<i>-389,736</i>	<i>50.57</i>							
Internal Loads								Internal Loads										
Lights	175,322	43,831		219,153	16	16	175,322	Lights	0	0	0.00							
People	260,124	0		260,124	18	18	137,166	People	0	0	0.00							
Misc	198,114	0		198,114	14	14	198,114	Misc	0	0	0.00							
<i>Sub Total ==></i>	<i>633,561</i>			<i>677,391</i>	<i>48</i>		<i>510,603</i>	<i>Sub Total ==></i>	<i>0</i>	<i>0</i>	<i>0.00</i>							
Ceiling Load	10,929	-10,929		0	0	0	8,406	Ceiling Load	-39,360	0	0.00							
Ventilation Load	0	0		251,224	18	18	0	Ventilation Load	0	-337,314	43.76							
Adj Air Trans Heat	0			0	0	0	0	Adj Air Trans Heat	0	0	0							
Dehumid. Ov Sizing				0	0	0	0	Ov/Undr Sizing	0	0	0.00							
Ov/Undr Sizing	0			0	0	0	0	Exhaust Heat	19,433	-2.52								
Exhaust Heat		-14,037		-14,037	-1			OA Preheat Diff.	0	0.00								
Sup. Fan Heat				46,722	3			RA Preheat Diff.	-63,123	8.19								
Ret. Fan Heat	46,296	46,296		46,296	3			Additional Reheat	0	0.00								
Duct Heat Pkup	-86,904	0		0	0	0		Underflr Sup Ht Pkup	0	0.00								
Underflr Sup Ht Pkup				0	0	0		Supply Air Leakage	0	0.00								
Supply Air Leakage	0	0		0	0	0												
<i>Grand Total ==></i>	<i>968,447</i>			<i>60,374</i>	<i>1,413,672</i>	<i>100.00</i>		<i>Grand Total ==></i>	<i>-359,126</i>	<i>-770,739</i>	<i>100.00</i>							
COOLING COIL SELECTION								AREAS				HEATING COIL SELECTION						
Total Capacity	ton	MBh	Sens Cap.	Coil Airflow	Enter DB	WB/HR	Leave DB	WB/HR	Gross Total	Glass ft ²	(%)	Capacity	Coil Airflow	Ent °F	Lvg °F			
Main Clg	117.8	1,413.7	1,208.4	39,422	79.8	62.5	57.9	51.9	49.8	50.3		Main Htg	-569.0	11,844	51.9	95.5		
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0		Aux Htg	0.0	0	0.0	0.0		
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0		Preheat	-201.8	7,651	28.0	51.9		
<i>Total</i>	<i>117.8</i>	<i>1,413.7</i>							<i>ExFlr</i>	<i>26,100</i>			<i>Reheat</i>	<i>-209.9</i>	<i>11,844</i>	<i>51.9</i>	<i>68.0</i>	
									<i>Floor</i>	<i>51,369</i>			<i>Humidif</i>	<i>0.0</i>	<i>0</i>	<i>0.0</i>	<i>0.0</i>	
									<i>Part</i>	<i>7,051</i>			<i>Opt Vent</i>	<i>0.0</i>	<i>0</i>	<i>0.0</i>	<i>0.0</i>	
									<i>Int Door</i>	<i>0</i>			<i>Total</i>	<i>-770.7</i>				

System Checksums

By P2S ENGINEERING, INC

Bldg 7 Science

Variable Volume Reheat (30% Min Flow Default)

COOLING COIL PEAK								CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES					
Peaked at Time:		Mo/Hr: 8 / 17		Mo/Hr: 7 / 18		Mo/Hr: OADB: 91		Mo/Hr: Heating Design		Mo/Hr: OADB: 33		Space Peak		Coil Peak Percent		Cooling	Heating				
Envelope Loads	Space Sens. + Lat.	Plenum Sens. + Lat	Net Total	Percent Of Total	Space Sensible	Percent Of Total	Space Sens	Percent Of Total	Space Sens	Percent Of Total	Space Peak Btu/h	Coil Peak Btu/h	Tot Sens Btu/h	% Of Total	SADB	Ra Plenum					
Skylite Solar	0	0	0	0	0	0	0	0	0	0	0	0	0	0.00	54.2	84.7					
Skylite Cond	0	0	0	0	0	0	0	0	0	0	0	0	0	0.00	79.8	64.0					
Roof Cond	0	172,229	172,229	6	0	0	0	0	0	0	0	-78,704	3.89		Return	79.8	64.0				
Glass Solar	144,245	0	144,245	5	127,818	11	Glass Solar	0	0	0	0	0	0	0.00	Ret/OA	90.2	35.5				
Glass/Door Cond	67,760	0	67,760	2	70,204	6	Glass/Door Cond	-134,565	-134,565	6.65					Fn MtrTD	0.0	0.0				
Wall Cond	137,971	47,237	185,208	6	158,307	14	Wall Cond	-163,936	-225,835	11.16					Fn BldTD	0.0	0.0				
Partition/Door	11,039		11,039	0	12,361	1	Partition/Door	-20,365	-20,365	1.01					Fn Frict	0.0	0.0				
Floor	276		276	0	338	0	Floor	-3,817	-3,817	0.19											
Adjacent Floor	0	0	0	0	0	0	Adjacent Floor	0	0	0											
Infiltration	0		0	0	0	0	Infiltration	0	0	0.00											
Sub Total ==>	361,291	219,466	580,757	19	369,029	32	Sub Total ==>	-322,683	-463,286	22.90											
Internal Loads								Internal Loads				Internal Loads				AIRFLOWS					
Lights	162,498	40,624	203,122	7	162,498	14	Lights	0	0	0.00					Cooling	Heating					
People	417,838	0	417,838	14	226,094	19	People	0	0	0.00					Diffuser	61,063	24,916				
Misc	297,445	0	297,445	10	297,445	25	Misc	0	0	0.00					Terminal	61,063	24,916				
Sub Total ==>	877,780	40,624	918,405	30	686,037	59	Sub Total ==>	0	0	0.00					Main Fan	61,063	24,916				
Ceiling Load	92,457	-92,457	0	0	99,789	9	Ceiling Load	-71,172	0	0.00					Sec Fan	0	0				
Ventilation Load	0	0	1,783,052	58	0	0	Ventilation Load	0	-909,833	44.97					Nom Vent	53,036	22,900				
Adj Air Trans Heat	0		0	0	0	0	Adj Air Trans Heat	0	0	0					AHU Vent	53,036	22,900				
Dehumid. Ov Sizing			0	0			Ov/Undr Sizing	0	0	0.00					Infil	0	0				
Ov/Undr Sizing	18,665		18,665	1	14,249	1	Exhaust Heat	56,365	-2.79						MinStop/Rh	24,916	24,916				
Exhaust Heat	-209,582	-209,582	-209,582	-7			OA Preheat Diff.	-685,093	33.86						Return	18,067	10,716				
Sup. Fan Heat			0	0			RA Preheat Diff.	-21,213	1.05						Exhaust	10,039	8,699				
Ret. Fan Heat	0	0	0	0			Additional Reheat	0	0.00						Rm Exh	42,997	14,201				
Duct Heat Pkup	0	0	0	0			Underflr Sup Ht Pkup	0	0.00						Auxiliary	0	0				
Underflr Sup Ht Pkup			0	0			Supply Air Leakage	0	0.00						Leakage Dwn	0	0				
Supply Air Leakage	0	0	0	0											Leakage Ups	0	0				
Grand Total ==>	1,350,194	-41,949	3,091,297	100.00	1,169,103	100.00	Grand Total ==>	-393,855	-2,023,059	100.00					ENGINEERING CKS						
COOLING COIL SELECTION								AREAS				HEATING COIL SELECTION				TEMPERATURES					
Total Capacity	ton	MBh	Sens Cap.	MBh	Coil Airflow	cfm	Enter DB/WB/HR	°F	°F	gr/lb	Leave DB/WB/HR	°F	°F	gr/lb	Gross Total	Glass ft ²	(%)	Capacity MBh	Coil Airflow cfm	Ent °F	Lvg °F
Main Clg	257.6	3,091.3	2,236.2	60,507	90.2	69.1	77.0	54.2	52.6	58.8	Floor	37,226			Main Htg	-817.4	24,916	54.2	84.7		
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Part	1,551			Aux Htg	0.0	0	0.0	0.0		
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Int Door	0			Preheat	-1,205.7	53,036	33.0	54.2		
Total	257.6	3,091.3									ExFlr	1,006			Reheat	-423.5	24,916	54.2	70.0		
											Roof	22,709	0	0	Humidif	0.0	0	0.0	0.0		
											Wall	16,624	3,188	19	Opt Vent	0.0	0	0.0	0.0		
											Ext Door	0	0	0	Total	-2,023.1					

System Checksums

By P2S Engineering, Inc

bldg 6

Variable Volume Reheat (30% Min Flow Default)

COOLING COIL PEAK								CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES		
Peaked at Time:		Mo/Hr: 8 / 16		Mo/Hr: 7 / 16		Mo/Hr: Heating Design		Space Peak		Coil Peak Percent		Cooling		Heating				
Outside Air:		OADB/WB/HR: 95 / 69 / 66		OADB: 95		OADB: 28		Space Sens		Tot Sens Of Total		SADB	60.4	84.1				
	Space Sens. + Lat.	Btu/h	Plenum Sens. + Lat	Btu/h	Net Total	Percent Of Total	Btu/h	Space Sensible	Percent Of Total	Btu/h	(%)	Ra Plenum	76.2	63.8				
Envelope Loads												Return	77.7	63.8				
Skylite Solar	0	0			0	0		0	0			Ret/OA	81.7	36.8				
Skylite Cond	0	0			0	0		0	0			Fn MtrTD	0.1	0.0				
Roof Cond	0	330,874		330,874	11			0	0			Fn BldTD	0.3	0.0				
Glass Solar	122,611	0		122,611	4			130,490	9			Fn Frict	1.0	0.0				
Glass/Door Cond	26,299	0		26,299	1			26,214	2									
Wall Cond	78,531	39,654		118,185	4			78,860	5									
Partition/Door	0			0	0			0	0									
Floor	0			0	0			0	0									
Adjacent Floor	0	0		0	0			0	0									
Infiltration	153,813			153,813	5			140,715	9									
<i>Sub Total ==></i>	<i>381,254</i>			<i>751,782</i>	<i>25</i>			<i>376,279</i>	<i>25</i>									
Internal Loads																		
Lights	350,168	87,542		437,710	15			350,168	23									
People	550,559	0		550,559	18			291,472	19									
Misc	406,445	0		406,445	14			406,445	27									
<i>Sub Total ==></i>	<i>1,307,172</i>	<i>87,542</i>		<i>1,394,714</i>	<i>47</i>			<i>1,048,085</i>	<i>70</i>									
Ceiling Load	72,349	-72,349		0	0			77,164	5									
Ventilation Load	0	0		581,825	19			0	0									
Adj Air Trans Heat	0			0	0			0	0									
Dehumid. Ov Sizing				0	0													
Ov/Undr Sizing	0			0	0			0	0									
Exhaust Heat		-24,248		-24,248	-1													
Sup. Fan Heat				157,356	5													
Ret. Fan Heat	130,967	130,967		4														
Duct Heat Pkup		-218,420		0	0													
Underflr Sup Ht Pkup				0	0													
Supply Air Leakage		0		0	0													
Grand Total ==>	1,760,775	274,021		2,992,396	100.00			1,501,528	100.00									
COOLING COIL SELECTION								AREAS				HEATING COIL SELECTION						
Total Capacity	ton	MBh	Sens Cap.	Coil Airflow	Enter DB	WB/HR	Leave DB	WB/HR	Gross Total	Glass ft ²	(%)	Capacity	Coil Airflow	Ent °F	Lvg °F			
Main Clg	249.4	2,992.4	2,673.8	99,081	81.7	64.4	64.0	56.9	54.4	59.9		MBh	cfm					
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0		Main Htg	-896.5	29,969	56.9	84.1		
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0		Aux Htg	0.0	0	0.0	0.0		
Total	249.4	2,992.4										Preheat	-720.1	22,587	28.0	56.9		
												Reheat	-365.9	29,969	56.9	68.0		
												Humidif	0.0	0	0.0	0.0		
												Opt Vent	0.0	0	0.0	0.0		
												Total	-1,616.6					

System Checksums

By P2S Engineering, Inc

System - 001

Double Duct

COOLING COIL PEAK								CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES			
Peaked at Time:		Mo/Hr: 8 / 17		Mo/Hr: 8 / 18		Mo/Hr: Heating Design		Space Peak		Coil Peak Percent		Cooling		Heating					
Outside Air:		OADB/WB/HR: 94 / 69 / 65		OADB: 92		OADB: 28		Space Sens		Tot Sens Of Total		Space Sens		Tot Sens Of Total					
	Space Sens. + Lat.	Plenum Sens. + Lat		Net Total	Percent Of Total			Btu/h	Btu/h	(%)		Btu/h	Btu/h	(%)					
Envelope Loads																			
Skylite Solar	0	0		0	0			0	0			Skylite Solar	0	0	0.00				
Skylite Cond	0	0		0	0			0	0			Skylite Cond	0	0	0.00				
Roof Cond	0	190,736		190,736	14			0	0			Roof Cond	0	-121,805	15.09				
Glass Solar	70,747	0		70,747	5			72,365	9			Glass Solar	0	0	0.00				
Glass/Door Cond	16,127	0		16,127	1			15,334	2			Glass/Door Cond	-32,623	-32,623	4.04				
Wall Cond	103,700	57,548		161,249	12			108,559	13			Wall Cond	-112,912	-179,402	22.23				
Partition/Door	3,779			3,779	0			3,779	0			Partition/Door	-5,694	-5,694	0.71				
Floor	60,955			60,955	4			60,955	8			Floor	-91,831	-91,831	11.38				
Adjacent Floor	0	0		0	0			0	0			Adjacent Floor	0	0	0				
Infiltration	44,338			44,338	3			37,596	5			Infiltration	-82,720	-82,720	10.25				
<i>Sub Total ==></i>	<i>299,646</i>	<i>248,285</i>		<i>547,931</i>	<i>40</i>			<i>298,589</i>	<i>37</i>			<i>Sub Total ==></i>	<i>-325,780</i>	<i>-514,075</i>	<i>63.71</i>				
Internal Loads												Internal Loads							
Lights	133,191	33,298		166,489	12			133,191	16			Lights	0	0	0.00				
People	237,510	0		237,510	18			123,205	15			People	0	0	0.00				
Misc	189,257	0		189,257	14			189,257	23			Misc	0	0	0.00				
<i>Sub Total ==></i>	<i>559,957</i>	<i>33,298</i>		<i>593,255</i>	<i>44</i>			<i>445,653</i>	<i>55</i>			<i>Sub Total ==></i>	<i>0</i>	<i>0</i>	<i>0.00</i>				
Ceiling Load	66,353	-66,353		0	0			67,404	8			Ceiling Load	-44,371	0	0.00				
Ventilation Load	0	0		160,699	12			0	0			Ventilation Load	0	-299,807	37.15				
Adj Air Trans Heat	0			0	0			0	0			Adj Air Trans Heat	0	0	0				
Dehumid. Ov Sizing				0	0							Ov/Undr Sizing	-8	-8	0.00				
Ov/Undr Sizing	934			934	0			0	0			Exhaust Heat	6,946	-0.86					
Exhaust Heat		-10,387		-10,387	-1							OA Preheat Diff.	0	0.00					
Sup. Fan Heat				64,757	5							RA Preheat Diff.	0	0.00					
Ret. Fan Heat	0			0	0							Additional Reheat	0	0.00					
Duct Heat Pkup	0			0	0							Underflr Sup Ht Pkup	0	0.00					
Underflr Sup Ht Pkup				0	0							Supply Air Leakage	0	0.00					
Supply Air Leakage	0			0	0														
<i>Grand Total ==></i>	<i>926,891</i>	<i>204,843</i>		<i>1,357,190</i>	<i>100.00</i>			<i>811,646</i>	<i>100.00</i>			<i>Grand Total ==></i>	<i>-370,158</i>	<i>-806,944</i>	<i>100.00</i>				
COOLING COIL SELECTION								AREAS				HEATING COIL SELECTION							
Total Capacity	ton	MBh	Sens Cap.	Coil Airflow	Enter DB	WB	HR	Gross Total	Glass ft ²	(%)		Capacity	Coil Airflow	Ent	Lvg				
Main Clg	113.1	1,357.2	1,230.8	43,711	81.4	64.2	63.7	55.8	53.9	59.4	Main Htg	-806.9	43,801	59.0	75.7				
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Aux Htg	0.0	0	0.0	0.0				
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0	Preheat	0.0	0	0.0	0.0				
<i>Total</i>	<i>113.1</i>	<i>1,357.2</i>						<i>ExFlr</i>	<i>22,614</i>			<i>Humidif</i>	<i>0.0</i>	<i>0</i>	<i>0.0</i>	<i>0.0</i>			
								<i>Roof</i>	<i>22,614</i>	<i>0</i>	<i>0</i>	<i>Opt Vent</i>	<i>0.0</i>	<i>0</i>	<i>0.0</i>	<i>0.0</i>			
								<i>Wall</i>	<i>15,054</i>	<i>1,314</i>	<i>9</i>	<i>Total</i>	<i>-806.9</i>						
								<i>Ext Door</i>	<i>0</i>	<i>0</i>	<i>0</i>								

System Checksums

By P2S Engineering, Inc

Recital Hall

Variable Volume Reheat (30% Min Flow Default)

COOLING COIL PEAK								CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES		
Peaked at Time:		Mo/Hr: 8 / 17		Mo/Hr: 9 / 16		Mo/Hr: Heating Design		Space Peak		Coil Peak Percent		Cooling		Heating				
Outside Air:		OADB/WB/HR: 92 / 70 / 79		OADB: 93		OADB: 28		Space Sens		Tot Sens Of Total		Space Sens		Tot Sens Of Total				
	Space Sens. + Lat.	Btu/h	Plenum Sens. + Lat	Btu/h	Net Total	Percent Btu/h	(%)	Space Sensible	Percent Of Total	Btu/h	(%)							
Envelope Loads												Envelope Loads						
Skylite Solar	0	0		0	0			0	0			Skylite Solar	0	0	0.00			
Skylite Cond	0	0		0	0			0	0			Skylite Cond	0	0	0.00			
Roof Cond	0	134,426		134,426	16			0	0			Roof Cond	0	-95,851	19.66			
Glass Solar	47,395	0		47,395	5			57,196	13			Glass Solar	0	0	0.00			
Glass/Door Cond	19,374	0		19,374	2			19,536	4			Glass/Door Cond	-49,134	-49,134	10.08			
Wall Cond	19,446	4,797		24,244	3			17,853	4			Wall Cond	-24,155	-30,033	6.16			
Partition/Door	0			0	0			0	0			Partition/Door	0	0	0.00			
Floor	0			0	0			0	0			Floor	-31,181	-31,181	6.39			
Adjacent Floor	0	0		0	0			0	0			Adjacent Floor	0	0	0			
Infiltration	0			0	0			0	0			Infiltration	0	0	0.00			
<i>Sub Total ==></i>	<i>86,216</i>	<i>139,224</i>		<i>225,439</i>	<i>26</i>			<i>94,585</i>	<i>21</i>			<i>Sub Total ==></i>	<i>-104,469</i>	<i>-206,198</i>	<i>42.28</i>			
Internal Loads												Internal Loads						
Lights	112,464	28,116		140,579	16			112,464	26			Lights	0	0	0.00			
People	225,000	0		225,000	26			125,000	28			People	0	0	0.00			
Misc	78,100	0		78,100	9			78,100	18			Misc	0	0	0.00			
<i>Sub Total ==></i>	<i>415,563</i>	<i>28,116</i>		<i>443,679</i>	<i>51</i>			<i>315,563</i>	<i>72</i>			<i>Sub Total ==></i>	<i>0</i>	<i>0</i>	<i>0.00</i>			
Ceiling Load	36,716	-36,716		0	0			30,479	7			Ceiling Load	-49,086	0	0.00			
Ventilation Load	0	0		234,769	27			0	0			Ventilation Load	0	-326,601	66.97			
Adj Air Trans Heat	0			0	0			0	0			Adj Air Trans Heat	0	0	0			
Dehumid. Ov Sizing				0	0							Ov/Undr Sizing	0	0	0.00			
Ov/Undr Sizing	0			0	0			0	0			Exhaust Heat	52,644	-10.80				
Exhaust Heat		-40,782		-40,782	-5							OA Preheat Diff.	-7,490	1.54				
Sup. Fan Heat				0	0							RA Preheat Diff.	0	0.00				
Ret. Fan Heat		0		0	0							Additional Reheat	0	0.00				
Duct Heat Pkup		0		0	0							Underflr Sup Ht Pkup	0	0.00				
Underflr Sup Ht Pkup				0	0							Supply Air Leakage	0	0.00				
Supply Air Leakage		0		0	0													
<i>Grand Total ==></i>	<i>538,495</i>	<i>89,842</i>		<i>863,106</i>	<i>100.00</i>			<i>440,627</i>	<i>100.00</i>			<i>Grand Total ==></i>	<i>-153,555</i>	<i>-487,646</i>	<i>100.00</i>			
COOLING COIL SELECTION								AREAS				HEATING COIL SELECTION						
Total Capacity	ton	MBh	Sens Cap.	Coil Airflow	Enter DB	WB/HR	Leave DB	WB/HR	Gross Total	Glass ft ²	(%)	Capacity	Coil Airflow	Ent °F	Lvg °F			
Main Clg	71.9	863.1	686.7	24,021	81.6	64.9	68.9	55.0	52.7	58.1		Main Htg	-270.2	7,242	55.0	89.8		
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0		Aux Htg	0.0	0	0.0	0.0		
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0		Int Door	0					
Total	71.9	863.1							ExFlr	928			Preheat	-217.5	7,500	28.0	55.0	
									Roof	22,883	0	0	Reheat	-116.6	7,242	55.0	70.0	
									Wall	17,632	1,141	6	Humidif	0.0	0	0.0	0.0	
									Ext Door	0	0	0	Opt Vent	0.0	0	0.0	0.0	
												Total	-487.7					

System Checksums

By P2S Engineering, Inc

Studio

Variable Volume Reheat (30% Min Flow Default)

COOLING COIL PEAK								CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES		
Peaked at Time:		Mo/Hr: 8 / 17		Mo/Hr: 7 / 17		Mo/Hr: Heating Design		Space Peak		Coil Peak Percent		Cooling		Heating				
Outside Air:		OADB/WB/HR: 92 / 70 / 79		OADB: 94		OADB: 28		Space Sens		Tot Sens Of Total		Space Sens		Tot Sens Of Total				
	Space Sens. + Lat.	Btu/h	Plenum Sens. + Lat	Btu/h	Net Total	Percent Of Total	Btu/h	Space Sensible	Percent Of Total	Btu/h	(%)	Btu/h	Btu/h	(%)				
Envelope Loads																		
Skylite Solar	0	0		0	0	0		0	0		0		0.00					
Skylite Cond	0	0		0	0	0		0	0		0		0.00					
Roof Cond	0	236,829		236,829	15			0	0		0		-169,131	20.45				
Glass Solar	32,144	0		32,144	2			29,909	4		0		0.00					
Glass/Door Cond	13,839	0		13,839	1			15,606	2		0		-35,063	4.24				
Wall Cond	27,027	6,394		33,421	2			27,075	4		0		-32,719	4.88				
Partition/Door	0			0	0			0	0		0		0.00					
Floor	0			0	0			0	0		0		-42,806	5.17				
Adjacent Floor	0	0		0	0			0	0		0		0.00					
Infiltration	0			0	0			0	0		0		0.00					
<i>Sub Total ==></i>	<i>73,010</i>	<i>243,223</i>		<i>316,233</i>	<i>21</i>			<i>72,591</i>	<i>10</i>				<i>-110,588</i>	<i>-287,352</i>	<i>34.74</i>			
Internal Loads																		
Lights	198,938	49,735		248,673	16			198,938	27		0		0.00					
People	450,000	0		450,000	29			250,000	34		0		0.00					
Misc	138,151	0		138,151	9			138,151	19		0		0.00					
<i>Sub Total ==></i>	<i>787,089</i>	<i>49,735</i>		<i>836,824</i>	<i>55</i>			<i>587,089</i>	<i>80</i>		<i>0</i>		<i>0.00</i>					
Ceiling Load	67,542	-67,542		0	0			71,670	10				-88,104	0	0.00			
Ventilation Load	0	0		460,314	30			0	0				0	-542,080	65.53			
Adj Air Trans Heat	0			0	0			0	0				0	0	0			
Dehumid. Ov Sizing				0	0													
Ov/Undr Sizing	0			0	0			0	0									
Exhaust Heat		-84,823		-84,823	-6													
Sup. Fan Heat				0	0													
Ret. Fan Heat		0		0	0													
Duct Heat Pkup		0		0	0													
Underflr Sup Ht Pkup				0	0													
Supply Air Leakage		0		0	0													
<i>Grand Total ==></i>	<i>927,641</i>	<i>140,593</i>		<i>1,528,549</i>	<i>100.00</i>			<i>731,350</i>	<i>100.00</i>				<i>-198,692</i>	<i>-827,187</i>	<i>100.00</i>			
COOLING COIL SELECTION								AREAS				HEATING COIL SELECTION						
Total Capacity	ton	MBh	Sens Cap.	Coil Airflow	Enter DB	WB/HR	Leave DB	WB/HR	Gross Total	Glass ft ²	(%)	Capacity	Coil Airflow	Ent °F	Lvg °F			
Main Clg	127.4	1,528.6	1,184.9	39,860	82.7	65.5	70.4	55.0	52.7	57.7		Main Htg	-392.3	12,019	55.0	85.4		
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0		Aux Htg	0.0	0	0.0	0.0		
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0		Preheat	-434.9	15,000	28.0	55.0		
Total	127.4	1,528.6							1,274			Reheat	-193.6	12,019	55.0	70.0		
									40,478	0	0	Humidif	0.0	0	0.0	0.0		
									22,950	814	4	Opt Vent	0.0	0	0.0	0.0		
									Ext Door	0	0	Total	-827.2					

System Checksums

By P2S Engineering, Inc

System - 001

Fan Coil

COOLING COIL PEAK								CLG SPACE PEAK								HEATING COIL PEAK								TEMPERATURES								
Peaked at Time:				Mo/Hr: 9 / 15				Mo/Hr: Sum of OADB: Peaks				Mo/Hr: Heating Design				Space Peak		Coil Peak Percent				Space Sens		Tot Sens Of Total				Cooling		Heating		
Outside Air:		OADB/WB/HR: 97 / 69 / 63										OADB: 28				Space Sens		Tot Sens Of Total				SADB		Ra Plenum		81.5		62.9				
	Space Sens. + Lat.	Btu/h	Plenum Sens. + Lat	Btu/h	Net Total	Percent (%)	Total Btu/h	Sensible	Percent (%)	Btu/h	Total (%)					Space Peak	Btu/h	Coil Peak Percent (%)														
Envelope Loads																Envelope Loads																
Skylite Solar	0	0			0	0		0	0	0	0					Skylite Solar	0	0	0.00													
Skylite Cond	0	0			0	0		0	0	0	0					Skylite Cond	0	0	0.00													
Roof Cond	0	90,027			90,027	10		0	0	0	0					Roof Cond	0	-47,229	6.49													
Glass Solar	43,584	0			43,584	5		60,972	15							Glass Solar	0	0	0.00													
Glass/Door Cond	24,102	0			24,102	3		21,207	5							Glass/Door Cond	-45,746	-45,746	6.29													
Wall Cond	87,571	49,216			136,787	16		86,523	22							Wall Cond	-70,812	-111,754	15.36													
Partition/Door	0				0	0		0	0	0	0					Partition/Door	0	0	0.00													
Floor	0				0	0		0	0	0	0					Floor	-38,894	-38,894	5.35													
Adjacent Floor	0	0			0	0		0	0	0	0					Adjacent Floor	0	0	0													
Infiltration	30,523				30,523	3		22,186	6							Infiltration	-42,685	-42,685	5.87													
<i>Sub Total ==></i>	<i>185,781</i>	<i>139,243</i>			<i>325,024</i>	<i>37</i>		<i>190,887</i>	<i>48</i>							<i>Sub Total ==></i>	<i>-198,137</i>	<i>-286,308</i>	<i>39.35</i>													
Internal Loads																Internal Loads																
Lights	59,478	14,869			74,347	8		59,478	15							Lights	0	0	0.00													
People	90,182	0			90,182	10		47,870	12							People	0	0	0.00													
Misc	56,174	0			56,174	6		56,174	14							Misc	0	0	0.00													
<i>Sub Total ==></i>	<i>205,834</i>	<i>14,869</i>			<i>220,703</i>	<i>25</i>		<i>163,522</i>	<i>41</i>							<i>Sub Total ==></i>	<i>0</i>	<i>0</i>	<i>0.00</i>													
Ceiling Load	38,497	-38,497			0	0		41,042	10							Ceiling Load	-26,141	0	0.00													
Ventilation Load	0	0			325,361	37		0	0							Ventilation Load	0	-455,001	62.54													
Adj Air Trans Heat	0				0	0		0	0							Adj Air Trans Heat	0	0	0													
Dehumid. Ov Sizing					0	0										Ov/Undr Sizing	0	0	0.00													
Ov/Undr Sizing	0				0	0		0	0							Exhaust Heat		13,768	-1.89													
Exhaust Heat					-20,277	-20,277		-2								OA Preheat Diff.		0	0.00													
Sup. Fan Heat								29,990	3							RA Preheat Diff.		0	0.00													
Ret. Fan Heat					0	0										Additional Reheat		0	0.00													
Duct Heat Pkup					-41,629	0										Underflr Sup Ht Pkup		0	0.00													
Underflr Sup Ht Pkup																Supply Air Leakage		0	0.00													
Supply Air Leakage					0	0																										
<i>Grand Total ==></i>	<i>430,112</i>	<i>53,710</i>			<i>880,802</i>	<i>100.00</i>		<i>395,451</i>	<i>100.00</i>						<i>Grand Total ==></i>	<i>-224,278</i>	<i>-727,541</i>	<i>100.00</i>														
COOLING COIL SELECTION								AREAS								HEATING COIL SELECTION																
Total Capacity	ton	MBh	Sens Cap.	MBh	Coil Airflow	cfm	Enter DB	°F	WB	°F	Leave DB	°F	WB	°F	Leave gr/lb	Gross Total	Glass ft ²	(%)	Capacity MBh	Coil Airflow cfm	Ent °F	Lvg °F										
Main Clg	73.4	880.8		768.7	18,884	91.4	66.5		58.5		53.0	50.8		52.2		Floor	16,136			-727.5	18,884	43.8	78.8									
Aux Clg	0.0	0.0		0.0	0	0.0	0.0		0.0		0.0	0.0		0.0		Part	0			0.0	0	0.0	0.0									
Opt Vent	0.0	0.0		0.0	0	0.0	0.0		0.0		0.0	0.0		0.0		Int Door	0			-161.1	18,884	43.8	51.6									
Total	73.4	880.8														ExFlr	1,332															
																Roof	16,922	0	0													
																Wall	23,800	1,155	5													
																Ext Door	0	0	0													

System Checksums

By P2S Engineering, Inc

System - 001

Variable Volume Reheat (30% Min Flow Default)

COOLING COIL PEAK								CLG SPACE PEAK				HEATING COIL PEAK				TEMPERATURES			
Peaked at Time:		Mo/Hr: 9 / 16		Mo/Hr: 9 / 16		Mo/Hr: Heating Design		Space Peak		Coil Peak Percent		Cooling		Heating					
Outside Air:	OADB/WB/HR:	OADB:	96 / 70 / 67	OADB:	96	OADB:	28	Sens. Space	Percent	Tot Sens. Space	Tot Percent	Sens. Space	Percent	Sens. Space	Percent	SADB	54.0	113.1	
Space Sens. + Lat.	Btu/h	Plenum Sens. + Lat	Btu/h	Net Total	Percent	Total Btu/h	(%)	Sensible	Percent	Space Btu/h	(%)	Sensible	Percent	Space Btu/h	(%)	Ra Plenum	78.6	58.9	
Envelope Loads																Return	78.6	58.9	
Skylite Solar	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Ret/OA	82.2	37.8		
Skylite Cond	0	0	0	0	0	0	0	0	0	0	0	0	0	0	Fn MtrTD	0.0	0.0		
Roof Cond	0	36,408	36,408	5	5	0	0	0	0	0	0	0	0	0	Fn BldTD	0.0	0.0		
Glass Solar	32,396	0	32,396	4	4	32,396	8	0	0	0	0	0	0	0	Fn Frict	0.0	0.0		
Glass/Door Cond	24,889	0	24,889	3	3	24,889	6	0	0	0	0	0	0	0					
Wall Cond	97,470	54,053	151,523	21	21	97,470	23	0	0	0	0	0	0	0					
Partition/Door	0		0	0	0	0	0	0	0	0	0	0	0	0					
Floor	40,716		40,716	6	6	40,716	9	0	0	0	0	0	0	0					
Adjacent Floor	0	0	0	0	0	0	0	0	0	0	0	0	0	0					
Infiltration	26,248		26,248	4	4	23,698	5	0	0	0	0	0	0	0					
<i>Sub Total ==></i>	<i>221,719</i>	<i>90,461</i>	<i>312,180</i>	<i>43</i>	<i>43</i>	<i>219,169</i>	<i>51</i>	<i>219,169</i>	<i>51</i>	<i>219,169</i>	<i>51</i>	<i>219,169</i>	<i>51</i>	<i>219,169</i>	<i>51</i>	<i>Sub Total ==></i>	<i>243,857</i>	<i>310,726</i>	<i>62.46</i>
Internal Loads																			
Lights	50,157	12,539	62,697	9	9	50,157	12	0	0	0	0	0	0	0					
People	188,710	0	188,710	26	26	86,506	20	0	0	0	0	0	0	0					
Misc	51,297	0	51,297	7	7	51,297	12	0	0	0	0	0	0	0					
<i>Sub Total ==></i>	<i>290,165</i>	<i>12,539</i>	<i>302,704</i>	<i>42</i>	<i>42</i>	<i>187,961</i>	<i>44</i>	<i>187,961</i>	<i>44</i>	<i>187,961</i>	<i>44</i>	<i>187,961</i>	<i>44</i>	<i>187,961</i>	<i>44</i>	<i>Sub Total ==></i>	<i>0</i>	<i>0</i>	<i>0.00</i>
Ceiling Load	24,249	-24,249	0	0	0	24,249	6	24,249	6	Ceiling Load	-48,112	0	0	0	0	Cooling	19,599	5,880	
Ventilation Load	0	0	109,558	15	15	0	0	0	0	Ventilation Load	0	-176,710	35.52	0		Terminal	19,599	5,880	
Adj Air Trans Heat	0		0	0	0	0	0	0	0	Adj Air Trans Heat	0	0	0	0		Main Fan	19,599	5,880	
Dehumid. Ov Sizing			0	0	0	0	0	0	0	Ov/Undr Sizing	0	0	0	0		Sec Fan	0	0	
Ov/Undr Sizing	0		0	0	0	0	0	0	0	Exhaust Heat	0	0	0	0		Nom Vent	4,008	4,008	
Exhaust Heat			0	0	0	0	0	0	0	OA Preheat Diff.	0	0	0	0		AHU Vent	4,008	4,008	
Sup. Fan Heat			0	0	0	0	0	0	0	RA Preheat Diff.	-10,061	2.02	0	0.00		Infil	960	960	
Ret. Fan Heat	0		0	0	0	0	0	0	0	Additional Reheat	0	0	0	0.00		MinStop/Rh	5,880	5,880	
Duct Heat Pkup	0		0	0	0	0	0	0	0							Return	15,591	1,872	
Underflr Sup Ht Pkup			0	0	0	0	0	0	0	Underflr Sup Ht Pkup	0	0	0	0.00		Exhaust	0	0	
Supply Air Leakage	0		0	0	0	0	0	0	0	Supply Air Leakage	0	0	0	0.00		Rm Exh	4,968	4,968	
<i>Grand Total ==></i>	<i>536,133</i>	<i>78,751</i>	<i>724,442</i>	<i>100.00</i>	<i>100.00</i>	<i>431,378</i>	<i>100.00</i>	<i>431,378</i>	<i>100.00</i>	<i>Grand Total ==></i>	<i>-291,969</i>	<i>-497,496</i>	<i>100.00</i>	<i>100.00</i>	<i>Sub Total ==></i>	<i>0</i>	<i>0</i>	<i>0.00</i>	
COOLING COIL SELECTION																			
Total Capacity	ton	MBh	Sens Cap.	MBh	Coil Airflow	cfm	Enter DB	°F	WB/HR	Leave DB	°F	WB/HR	Gross Total	Glass ft ²					
Main Clg	60.4	724.4	609.0	19,599	82.2	64.7	64.3	54.0	52.2	55.8			Floor	16,700					
Aux Clg	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0			Part	0					
Opt Vent	0.0	0.0	0.0	0	0.0	0.0	0.0	0.0	0.0	0.0			Int Door	0					
<i>Total</i>	<i>60.4</i>	<i>724.4</i>											ExFlr	<i>16,700</i>					
													Roof	<i>16,700</i>	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	
													Wall	<i>13,056</i>	<i>2,007</i>	<i>15</i>	<i>0</i>	<i>0</i>	
													Ext Door	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	<i>0</i>	
													<i>Total</i>	<i>-497.5</i>					
HEATING COIL SELECTION																			
Capacity	MBh	Coil Airflow	cfm	Ent °F	Lvg °F														
Main Htg	-382.5	5,880	54.0	113.1															
Aux Htg	0.0	0	0.0	0.0															
Preheat	-115.0	4,008	28.0	54.0															
Reheat	-90.5	5,880	54.0	68.0															
Humidif	0.0	0	0.0	0.0															
Opt Vent	0.0	0	0.0	0.0															

BUILDING COOL HEAT DEMAND

By P2S ENGINEERING, INC

Diversified to match trends

January	Typical Weather (°F)		Design		Weekday		Saturday		Sunday		Monday	
	OADB	OAWB	Htg (Btuh)	Clg (Tons)								
1	52.0	47.1	0	0.0	-50,942	0.0	-57,099	0.0	-150,780	0.0	-172,665	0.0
2	52.0	46.1	0	0.0	-58,174	0.0	-58,591	0.0	-159,973	0.0	-279,411	0.0
3	51.0	45.5	0	0.0	-60,813	0.0	-61,048	0.0	-167,970	0.0	-368,059	0.0
4	51.0	44.9	0	0.0	-62,087	0.0	-62,105	0.0	-177,679	0.0	-555,773	0.0
5	50.0	43.9	0	0.0	-64,528	0.0	-64,820	0.0	-260,622	0.0	-592,192	0.0
6	49.0	43.5	0	0.0	-68,260	0.0	-68,260	0.0	-460,923	0.0	-725,027	0.0
7	49.0	43.5	-4,551,945	119.1	-3,716,369	58.3	-69,260	0.0	-524,793	0.0	-5,174,180	39.0
8	49.0	43.5	-3,739,645	158.8	-3,075,568	66.8	-112,858	0.0	-570,453	0.0	-5,609,531	43.8
9	52.0	44.9	-6,620,819	191.3	-5,578,631	27.8	-85,692	0.0	-342,994	0.0	-9,094,361	32.9
10	56.0	46.8	-3,234,412	268.9	-3,138,227	80.4	-12,787	0.0	-76,552	0.0	-6,121,551	86.9
11	58.0	48.3	-1,557,266	412.6	-1,746,708	156.2	-4,167	0.0	-45,544	0.0	-5,404,493	153.8
12	60.0	49.9	-804,857	535.8	-1,362,338	231.2	0	0.0	-31,126	0.0	-4,064,611	233.8
13	62.0	51.6	-891,277	555.9	-1,863,010	234.0	0	0.0	-12,591	0.0	-3,501,278	242.6
14	64.0	53.1	-634,329	653.0	-1,051,145	333.6	0	0.0	-8,679	0.0	-1,855,952	326.2
15	65.0	53.7	-562,027	701.9	-866,716	380.8	0	0.0	-5,015	0.0	-1,114,785	371.3
16	64.0	53.1	-548,145	691.2	-817,335	353.6	0	0.0	-2,188	0.0	-1,000,481	342.4
17	63.0	52.8	-620,282	650.6	-982,225	366.2	0	0.0	0	0.0	-1,164,450	355.0
18	62.0	52.3	-797,064	558.3	-1,664,534	357.9	-3,809	0.0	-3,809	0.0	-1,742,859	353.1
19	61.0	51.9	-817,306	511.6	-1,559,650	375.8	-7,887	0.0	-7,887	0.0	-1,636,895	364.6
20	60.0	51.5	-1,131,787	499.1	-1,705,181	370.6	-10,971	0.0	-13,826	0.0	-1,773,210	365.4
21	58.0	50.5	-1,514,024	505.3	-1,779,719	376.6	-15,255	0.0	-20,603	0.0	-1,824,328	371.0
22	54.0	48.7	-9,558	0.0	-15,572	0.0	-24,298	0.0	-33,118	0.0	-15,572	0.0
23	54.0	48.3	-16,436	0.0	-32,037	0.0	-30,567	0.0	-41,740	0.0	-32,037	0.0
24	53.0	47.9	-25,918	0.0	-45,907	0.0	-61,038	0.0	-75,158	0.0	-45,907	0.0
February	Typical Weather (°F)		Design		Weekday		Saturday		Sunday		Monday	
Hour	OADB	OAWB	Htg (Btuh)	Clg (Tons)								
1	53.0	47.8	-34,621	0.0	-41,131	0.0	-50,927	0.0	-33,612	0.0	-33,612	0.0
2	53.0	43.3	-37,558	0.0	-54,252	0.0	-55,020	0.0	-71,753	0.0	-88,654	0.0
3	53.0	43.0	-40,048	0.0	-55,017	0.0	-55,428	0.0	-144,341	0.0	-144,341	0.0
4	52.0	42.4	-41,927	0.0	-57,700	0.0	-57,858	0.0	-150,899	0.0	-150,899	0.0
5	51.0	41.7	-42,972	0.0	-61,259	0.0	-61,364	0.0	-166,714	0.0	-166,714	0.0
6	51.0	41.2	-42,509	0.0	-62,536	0.0	-62,700	0.0	-173,178	0.0	-232,740	0.0
7	51.0	41.2	-3,561,349	132.9	-3,334,128	59.9	-62,682	0.0	-175,856	0.0	-4,687,844	45.5
8	51.0	41.2	-2,846,041	177.1	-2,313,537	72.0	-43,015	0.0	-145,383	0.0	-5,253,593	56.2
9	53.0	42.2	-3,662,418	282.8	-4,359,135	37.2	-20,953	0.0	-20,953	0.0	-7,990,228	47.6
10	58.0	49.4	-1,934,161	364.3	-2,340,735	129.9	-7,111	0.0	-7,111	0.0	-5,577,259	143.8
11	60.0	50.6	-858,091	555.3	-1,254,651	216.1	0	0.0	0	0.0	-4,941,617	217.2
12	62.0	52.0	-645,746	650.4	-1,088,175	289.7	0	0.0	0	0.0	-2,967,627	287.5
13	64.0	53.2	-818,002	661.9	-1,506,037	290.9	0	0.0	0	0.0	-2,626,807	296.4
14	67.0	54.9	-613,542	779.7	-833,779	423.7	0	0.0	0	0.0	-1,108,988	408.6
15	67.0	55.1	-536,746	834.6	-719,549	445.5	0	0.0	0	0.0	-841,263	426.4
16	65.0	54.5	-521,420	840.0	-735,672	391.0	0	0.0	0	0.0	-864,857	374.2
17	64.0	54.5	-587,430	783.1	-834,946	400.1	0	0.0	0	0.0	-936,857	382.6
18	63.0	54.2	-747,635	653.6	-1,425,553	384.9	0	0.0	0	0.0	-1,538,631	374.5
19	62.0	54.1	-784,695	598.1	-1,480,284	399.2	0	0.0	0	0.0	-1,484,098	382.3
20	61.0	53.7	-836,048	562.0	-1,624,826	389.2	-4,496	0.0	-4,496	0.0	-1,638,310	380.8
21	60.0	53.2	-1,247,117	559.6	-1,638,615	391.8	-8,757	0.0	-8,757	0.0	-1,694,899	384.9
22	58.0	52.5	-7,336	0.0	-11,340	0.0	-13,257	0.0	-13,257	0.0	-11,340	0.0
23	56.0	51.3	-9,909	0.0	-22,786	0.0	-17,158	0.0	-17,158	0.0	-22,786	0.0
24	55.0	50.4	-19,961	0.0	-34,822	0.0	-25,077	0.0	-25,077	0.0	-34,822	0.0
March	Typical Weather (°F)		Design		Weekday		Saturday		Sunday		Monday	
Hour	OADB	OAWB	Htg (Btuh)	Clg (Tons)								
1	54.0	50.5	-32,257	0.0	-38,528	0.0	-47,191	0.0	-19,229	0.0	-19,229	0.0
2	53.0	49.9	-37,090	0.0	-52,615	0.0	-53,969	0.0	-28,119	0.0	-28,119	0.0
3	53.0	49.2	-39,723	0.0	-55,036	0.0	-55,409	0.0	-35,812	0.0	-35,812	0.0
4	52.0	48.8	-41,922	0.0	-57,640	0.0	-57,901	0.0	-93,032	0.0	-122,527	0.0
5	51.0	47.8	-42,966	0.0	-61,291	0.0	-61,349	0.0	-154,383	0.0	-154,330	0.0
6	51.0	47.0	-42,200	0.0	-62,491	0.0	-62,688	0.0	-168,491	0.0	-168,487	0.0
7	51.0	46.2	-3,360,767	138.8	-2,986,104	60.6	-53,516	0.0	-140,415	0.0	-4,218,396	54.3
8	52.0	46.6	-2,260,465	186.5	-1,973,151	76.1	-33,583	0.0	-62,425	0.0	-4,226,307	71.1
9	53.0	47.0	-2,902,912	311.1	-3,849,129	38.9	-14,930	0.0	-14,882	0.0	-7,314,868	46.6
10	59.0	49.7	-1,539,073	388.5	-1,707,128	158.1	0	0.0	0	0.0	-4,943,933	163.7
11	61.0	51.2	-662,709	589.3	-1,041,085	268.0	0	0.0	0	0.0	-3,562,012	264.1
12	63.0	52.7	-600,661	704.3	-944,959	336.5	0	0.0	0	0.0	-2,233,314	330.3
13	65.0	53.8	-776,406	706.8	-1,192,948	335.9	0	0.0	0	0.0	-1,507,694	338.9
14	68.0	55.5	-592,171	838.6	-718,584	472.7	0	0.0	0	0.0	-770,265	456.5
15	66.0	55.0	-516,843	906.0	-702,695	429.6	0	0.0	0	0.0	-783,508	413.3
16	66.0	55.5	-502,612	917.4	-672,044	430.3	0	0.0	0	0.0	-746,074	412.3
17	65.0	55.2	-565,048	852.8	-742,537	437.1	0	0.0	0	0.0	-806,632	420.6
18	64.0	55.0	-719,882	706.3	-1,112,461	415.5	0	0.0	0	0.0	-1,219,315	407.3
19	63.0	54.9	-768,084	635.0	-1,381,145	423.5	0	0.0	0	0.0	-1,378,395	407.7
20	62.0	54.4	-817,055	591.0	-1,529,017	408.1	0	0.0	0	0.0	-1,533,996	400.8
21	61.0	54.2	-1,101,331	585.4	-1,586,631	414.2	0	0.0	0	0.0	-1,591,754	403.9
22	59.0	54.0	-6,406	0.0	-10,113	0.0	-4,433	0.0	-4,433	0.0	-10,113	0.0
23	57.0	52.8	-8,272	0.0	-19,651	0.0	-11,046	0.0	-11,046	0.0	-19,651	0.0
24	55.0	51.8	-18,991	0.0	-33,240	0.0	-14,494	0.0	-14,494	0.0	-33,240	0.0
April	Typical Weather (°F)		Design		Weekday		Saturday		Sunday		Monday	
Hour	OADB	OAWB	Htg (Btuh)	Clg (Tons)								
1	58.0	54.0	-20,462	0.0	-21,968	0.0	-29,825	0.0	-5,352	0.0	-5,352	0.0
2	57.0	53.2	-26,409	0.0	-31,624	0.0	-38,822	0.0	-7,647	0.0	-7,647	0.0
3	56.0	52.0	-29,278	0.0	-42,074	0.0	-43,959	0.0	-12,740	0.0	-12,740	0.0
4	55.0	51.3	-31,286	0.0	-47,339	0.0	-47,527	0.0	-18,084	0.0	-18,084	0.0
5	54.0	50.3	-32,270	0.0								


Hour	OADB	OAWB	Htg (Btuh)	Cig (Tons)								
1	69.8	56.1	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
2	66.8	54.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
3	65.8	53.5	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
4	63.8	52.4	0	0.0	0	0.0	0	-3,616	0	0.0	0	0.0
5	63.8	52.2	0	0.0	0	0.0	-4,331	0	0	0.0	0	0.0
6	63.8	52.2	0	0.0	0	0.0	-4,331	0	0	0.0	0	0.0
7	64.8	52.7	-334,003	200.4	-327,273	155.7	0	0.0	0	0.0	-126,642	337.6
8	65.8	53.3	-379,061	304.1	-408,013	245.6	0	0.0	0	0.0	-251,910	428.4
9	70.8	55.3	-508,157	888.2	-552,764	627.5	0	0.0	0	0.0	-404,970	703.7
10	74.8	57.0	-519,208	1,071.3	-537,860	831.6	0	0.0	0	0.0	-460,863	845.7
11	76.8	57.8	-501,143	1,174.9	-521,823	915.1	0	0.0	0	0.0	-467,790	919.7
12	77.8	58.3	-507,062	1,312.3	-528,980	965.5	0	0.0	0	0.0	-491,638	957.2
13	78.8	58.8	-603,671	1,351.9	-660,071	957.2	0	0.0	0	0.0	-611,050	960.5
14	78.8	58.9	-508,443	1,442.7	-560,707	1,002.7	0	0.0	0	0.0	-524,024	1,012.2
15	77.8	58.6	-459,968	1,505.3	-505,516	992.7	0	0.0	0	0.0	-490,987	1,010.0
16	76.8	58.3	-441,539	1,511.7	-490,716	960.3	0	0.0	0	0.0	-486,013	975.6
17	75.8	58.2	-475,531	1,358.1	-541,052	868.4	0	0.0	0	0.0	-532,938	883.8
18	75.8	58.6	-603,031	1,151.7	-673,036	750.6	0	0.0	0	0.0	-664,683	784.7
19	74.8	58.5	-665,038	855.3	-714,705	580.9	0	0.0	0	0.0	-708,834	613.0
20	74.8	58.9	-713,307	760.9	-759,879	555.3	0	0.0	0	0.0	-755,272	582.2
21	72.8	58.6	-752,314	752.8	-796,059	552.9	0	0.0	0	0.0	-789,304	572.9
22	72.8	58.7	-3,739	0.0	-3,824	0.0	0	0.0	0	0.0	-3,824	0.0
23	70.8	57.8	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
24	70.8	57.1	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0

Hour	Typical Weather (°F)		Design		Weekday		Saturday		Sunday		Monday	
	OADB	OAWB	Htg (Btuh)	Cig (Tons)								
1	70.8	58.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
2	69.8	57.4	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
3	68.8	56.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
4	67.8	56.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
5	66.8	55.5	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
6	66.8	55.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
7	67.8	55.5	-229,440	297.2	-255,751	248.1	0	0.0	0	0.0	-82,172	454.5
8	70.8	56.8	-296,419	516.7	-367,263	352.9	0	0.0	0	0.0	-248,841	568.6
9	72.8	57.6	-433,408	1,344.5	-492,863	930.8	0	0.0	0	0.0	-400,125	1,055.7
10	76.8	59.1	-484,405	1,360.4	-509,375	1,014.8	0	0.0	0	0.0	-447,459	1,165.7
11	80.8	60.6	-484,392	1,495.1	-510,113	1,134.5	0	0.0	0	0.0	-448,403	1,261.2
12	82.8	61.5	-497,347	1,674.7	-516,423	1,214.9	0	0.0	0	0.0	-473,056	1,273.5
13	83.8	61.9	-588,567	1,714.6	-617,918	1,202.2	0	0.0	0	0.0	-573,472	1,227.7
14	83.8	62.0	-488,594	1,851.1	-534,572	1,255.2	0	0.0	0	0.0	-488,789	1,251.0
15	82.8	61.8	-437,043	1,957.7	-478,746	1,267.3	0	0.0	0	0.0	-444,694	1,262.8
16	80.8	61.2	-424,502	1,984.9	-465,868	1,206.5	0	0.0	0	0.0	-449,704	1,203.1
17	79.8	61.0	-445,563	1,779.8	-513,742	1,104.6	0	0.0	0	0.0	-483,889	1,097.9
18	78.8	60.8	-564,583	1,473.7	-648,347	952.3	0	0.0	0	0.0	-623,987	1,018.1
19	76.8	60.2	-626,023	1,109.5	-690,369	714.4	0	0.0	0	0.0	-673,011	741.4
20	75.8	60.1	-678,446	922.9	-737,967	656.1	0	0.0	0	0.0	-730,487	676.5
21	74.8	60.0	-721,703	884.4	-771,767	642.4	0	0.0	0	0.0	-770,193	660.8
22	73.8	59.8	-3,609	0.0	-3,774	0.0	0	0.0	0	0.0	-3,774	0.0
23	72.8	59.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
24	71.8	58.8	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0

Hour	Typical Weather (°F)		Design		Weekday		Saturday		Sunday		Monday	
	OADB	OAWB	Htg (Btuh)	Cig (Tons)								
1	72.9	59.8	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
2	71.9	59.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
3	71.9	59.2	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
4	70.9	58.8	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
5	70.9	58.7	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
6	71.9	58.8	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
7	72.9	58.9	-206,858	425.4	-220,023	298.1	0	0.0	0	0.0	-45,130	603.2
8	74.9	59.5	-268,010	700.8	-315,099	483.2	0	0.0	0	0.0	-236,929	675.1
9	78.9	61.1	-411,447	1,720.8	-446,130	1,308.6	0	0.0	0	0.0	-391,987	1,348.9
10	82.9	62.6	-461,760	1,797.4	-476,995	1,415.9	0	0.0	0	0.0	-437,854	1,462.0
11	86.9	63.9	-460,561	1,922.8	-479,586	1,536.6	0	0.0	0	0.0	-435,377	1,583.9
12	88.9	64.7	-476,000	2,034.9	-493,873	1,600.7	0	0.0	0	0.0	-440,385	1,643.5
13	89.9	65.1	-567,486	2,098.9	-589,956	1,613.3	0	0.0	0	0.0	-549,046	1,660.5
14	88.9	64.9	-453,785	2,214.6	-499,653	1,602.8	0	0.0	0	0.0	-468,551	1,644.5
15	86.9	64.4	-365,203	2,270.5	-447,316	1,557.5	0	0.0	0	0.0	-416,742	1,598.1
16	84.9	63.8	-354,838	2,299.5	-440,713	1,498.7	0	0.0	0	0.0	-420,674	1,540.5
17	83.9	63.6	-427,196	2,133.2	-479,736	1,348.3	0	0.0	0	0.0	-451,949	1,411.2
18	82.9	63.3	-513,616	1,753.1	-612,277	1,174.0	0	0.0	0	0.0	-553,117	1,211.2
19	80.9	62.7	-600,055	1,233.1	-667,481	821.4	0	0.0	0	0.0	-642,200	904.4
20	76.9	61.4	-647,233	1,147.7	-716,917	746.3	0	0.0	0	0.0	-692,708	822.1
21	74.9	60.9	-684,377	1,071.9	-756,521	709.7	0	0.0	0	0.0	-741,952	783.6
22	74.9	61.0	-3,451	0.0	-3,751	0.0	0	0.0	0	0.0	-3,751	0.0
23	73.9	60.5	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
24	72.9	59.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0

Hour	Typical Weather (°F)		Design		Weekday		Saturday		Sunday		Monday	
	OADB	OAWB	Htg (Btuh)	Cig (Tons)								
1	73.9	60.8	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
2	72.9	60.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
3	72.9	60.1	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
4	71.9	59.5	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
5	71.9	59.4</										

5	70.9	57.5	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
6	70.9	57.3	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
7	72.9	58.3	-210,056	484.0	-230,661	337.7	0	0.0	0	0.0	-77,625	659.0
8	76.9	60.0	-283,163	706.5	-361,479	495.1	0	0.0	0	0.0	-248,696	681.1
9	80.9	61.7	-422,134	1,743.2	-488,211	1,336.3	0	0.0	0	0.0	-394,750	1,399.6
10	84.9	63.2	-454,452	1,815.4	-485,390	1,479.1	0	0.0	0	0.0	-433,532	1,515.9
11	88.9	64.8	-454,691	1,959.0	-480,922	1,611.2	0	0.0	0	0.0	-423,748	1,655.8
12	89.9	65.3	-465,252	2,106.4	-488,581	1,652.9	0	0.0	0	0.0	-430,033	1,697.0
13	90.9	65.8	-554,339	2,203.6	-585,846	1,679.6	0	0.0	0	0.0	-529,843	1,715.5
14	90.9	66.0	-405,924	2,253.3	-499,602	1,700.6	0	0.0	0	0.0	-451,336	1,728.3
15	88.9	65.6	-319,102	2,298.1	-449,239	1,676.7	0	0.0	0	0.0	-408,592	1,684.8
16	86.9	65.2	-280,354	2,311.4	-444,668	1,632.8	0	0.0	0	0.0	-419,645	1,632.0
17	85.9	64.9	-416,597	2,146.8	-488,563	1,476.1	0	0.0	0	0.0	-454,375	1,498.4
18	84.9	64.4	-549,117	1,745.1	-633,507	1,222.2	0	0.0	0	0.0	-602,652	1,275.5
19	82.9	63.8	-616,505	1,274.0	-683,701	847.5	0	0.0	0	0.0	-663,473	903.3
20	78.9	62.4	-666,004	1,139.0	-727,255	768.5	0	0.0	0	0.0	-713,085	845.4
21	76.9	61.7	-704,551	1,106.1	-758,366	745.7	0	0.0	0	0.0	-753,283	842.1
22	75.9	61.3	-3,443	0.0	-3,707	0.0	0	0.0	0	0.0	-3,707	0.0
23	74.9	60.9	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
24	72.9	60.1	0	0.0	0	0.0	0	0.0	0	0.0	0	0.0
October	Typical Weather (°F)		Design		Weekday		Saturday		Sunday		Monday	
Hour	OADB	OAWB	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)
1	62.0	57.3	0	0.0	0	0.0	-15,160	0.0	0	0.0	0	0.0
2	61.0	56.5	0	0.0	-8,332	0.0	-21,589	0.0	0	0.0	0	0.0
3	61.0	56.3	0	0.0	-17,979	0.0	-24,548	0.0	-4,255	0.0	-4,255	0.0
4	60.0	55.4	0	0.0	-24,781	0.0	-29,720	0.0	-6,100	0.0	-6,100	0.0
5	60.0	55.0	0	0.0	-28,075	0.0	-31,861	0.0	-8,978	0.0	-8,978	0.0
6	59.0	54.6	0	0.0	-33,224	0.0	-34,216	0.0	-10,668	0.0	-10,668	0.0
7	59.0	54.6	-383,573	335.2	-768,764	162.1	-27,931	0.0	-10,657	0.0	-461,546	193.4
8	62.0	56.0	-443,346	490.1	-881,933	190.2	-6,724	0.0	-4,698	0.0	-574,022	234.7
9	66.0	57.8	-595,506	902.5	-773,729	473.7	0	0.0	0	0.0	-665,440	441.8
10	70.0	59.8	-539,492	991.6	-600,080	630.5	0	0.0	0	0.0	-590,624	646.4
11	72.0	60.5	-510,251	1,145.8	-550,429	769.2	0	0.0	0	0.0	-550,878	739.5
12	74.0	61.2	-523,874	1,294.7	-575,475	855.3	0	0.0	0	0.0	-581,102	827.7
13	76.0	62.1	-644,472	1,343.2	-723,002	859.7	0	0.0	0	0.0	-744,840	834.5
14	76.0	62.3	-535,750	1,491.2	-593,394	931.7	0	0.0	0	0.0	-602,636	883.8
15	74.0	62.0	-481,106	1,679.3	-540,275	925.4	0	0.0	0	0.0	-545,586	867.0
16	72.0	61.3	-472,319	1,734.4	-532,565	863.6	0	0.0	0	0.0	-534,945	823.2
17	70.0	60.7	-521,116	1,520.9	-597,828	767.7	0	0.0	0	0.0	-603,170	719.2
18	68.0	60.0	-660,074	1,200.9	-756,478	655.9	0	0.0	0	0.0	-765,095	618.4
19	66.0	59.3	-710,189	829.8	-782,452	555.7	0	0.0	0	0.0	-783,067	548.2
20	66.0	59.3	-762,829	752.7	-859,491	516.2	0	0.0	0	0.0	-833,531	509.4
21	64.0	58.5	-795,180	750.2	-1,243,570	514.5	0	0.0	0	0.0	-1,240,604	508.4
22	64.0	58.5	-3,871	0.0	-5,461	0.0	0	0.0	0	0.0	-5,461	0.0
23	64.0	58.4	0	0.0	-5,148	0.0	0	0.0	0	0.0	-5,148	0.0
24	63.0	58.0	0	0.0	-9,103	0.0	0	0.0	0	0.0	-9,103	0.0
November	Typical Weather (°F)		Design		Weekday		Saturday		Sunday		Monday	
Hour	OADB	OAWB	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)
1	58.0	50.5	-14,793	0.0	-23,476	0.0	-31,180	0.0	-15,168	0.0	-15,168	0.0
2	57.0	49.8	-20,145	0.0	-31,527	0.0	-39,350	0.0	-19,343	0.0	-19,343	0.0
3	56.0	49.1	-24,745	0.0	-41,291	0.0	-43,736	0.0	-25,411	0.0	-25,411	0.0
4	55.0	48.1	-30,075	0.0	-47,081	0.0	-47,415	0.0	-30,855	0.0	-30,855	0.0
5	54.0	47.6	-31,931	0.0	-50,525	0.0	-50,826	0.0	-35,037	0.0	-35,037	0.0
6	54.0	47.1	-31,467	0.0	-51,782	0.0	-51,902	0.0	-41,891	0.0	-41,832	0.0
7	54.0	46.9	-1,981,137	150.0	-2,313,711	68.5	-52,122	0.0	-43,724	0.0	-3,588,659	64.1
8	56.0	48.0	-1,049,967	204.2	-1,340,520	124.7	-26,481	0.0	-24,493	0.0	-3,045,647	123.6
9	60.0	49.8	-1,077,781	462.0	-1,719,394	204.6	-8,409	0.0	-8,409	0.0	-5,127,371	190.9
10	64.0	52.0	-608,459	563.1	-923,923	299.5	0	0.0	0	0.0	-3,091,948	286.8
11	68.0	54.4	-560,599	780.6	-693,388	463.7	0	0.0	0	0.0	-1,220,345	449.3
12	69.0	55.5	-588,093	887.8	-680,499	509.4	0	0.0	0	0.0	-747,926	495.0
13	70.0	56.6	-746,652	892.9	-860,429	479.9	0	0.0	0	0.0	-908,980	474.8
14	72.0	58.4	-578,582	1,037.4	-675,318	608.6	0	0.0	0	0.0	-681,262	586.0
15	71.0	58.2	-520,530	1,144.7	-605,873	607.1	0	0.0	0	0.0	-611,745	581.4
16	70.0	58.0	-510,468	1,178.1	-590,754	583.7	0	0.0	0	0.0	-598,311	560.6
17	68.0	57.3	-574,934	1,014.0	-676,586	524.2	0	0.0	0	0.0	-677,812	502.8
18	66.0	56.5	-732,458	834.5	-889,104	473.6	0	0.0	0	0.0	-912,126	448.0
19	64.0	55.3	-776,004	658.3	-1,161,784	447.7	0	0.0	0	0.0	-1,160,498	430.9
20	62.0	54.2	-812,916	612.3	-1,327,289	425.8	0	0.0	0	0.0	-1,338,094	418.1
21	62.0	53.8	-926,920	610.0	-1,474,872	430.0	0	0.0	0	0.0	-1,483,656	424.1
22	60.0	52.5	-4,111	0.0	-8,959	0.0	-2,934	0.0	-2,934	0.0	-8,959	0.0
23	60.0	52.2	-3,141	0.0	-13,363	0.0	-7,332	0.0	-7,332	0.0	-13,363	0.0
24	58.0	51.0	-6,628	0.0	-23,467	0.0	-11,951	0.0	-11,951	0.0	-23,467	0.0
December	Typical Weather (°F)		Design		Weekday		Saturday		Sunday		Monday	
Hour	OADB	OAWB	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)	Htg (Btuh)	Clg (Tons)
1	54.0	48.3	-30,228	0.0	-38,890	0.0	-47,819	0.0	-32,046	0.0	-32,046	0.0
2	54.0	47.6	-39,032	0.0	-50,552	0.0	-51,484	0.0	-35,224	0.0	-35,224	0.0
3	53.0	46.7	-42,767	0.0	-53,766	0.0	-54,188	0.0	-79,138	0.0	-103,889	0.0
4	53.0	46.5	-45,187	0.0	-55,067	0.0	-55,191	0.0	-136,767	0.0	-136,767	0.0
5	52.0	46.0	-46,439	0.0	-57,583	0.0	-57,640	0.0	-143,156	0.0	-170,827	0.0
6	51.0	45.0	-45,673	0.0	-61,129	0.0	-61,344	0.0	-160,890	0.0	-286,741	0.0
7	50.0	44.4	-3,330,731	129.3	-3,382,920	61.1	-64,784	0.0	-169,759	0.0	-4,451,213	45.1
8	54.0	46.5	-1,896,804	168.0	-2,208,294	80.0	-44,399	0.0	-189,552	0.0	-4,748,961	68.0
9	58.0	47.7	-2,971,112	281.1	-3,643,234	131.0	-15,498	0.0	-17,780	0.0	-6,868,816	140.3
10	62.0	50.7	-1,465,182	359.9	-1,916,108	228.4	-2,987	0.0	-2,987	0.0	-5,206,103	246.0
11	66.0	52.8	-760,579	540.1	-935,920	377.6	0	0.0	0	0.0	-3,553,722	370.3
12	67.0	53.5	-652,116	670.4	-835,751	430.1	0	0.0	0	0.0	-2,382,028	426.5
13	68.0	54.4	-630,371	689.6	-1,105,243	404.0	0	0.0	0	0.0	-1,698,622	405.5
14	68.0	54.8	-619,760	826.9	-750,072	458.3	0	0.0	0	0.0	-870,793	446.6
15	68.0	55.5	-558,611	879.7	-668,373	482.4	0	0.0	0	0.0	-741,832	462.8
16	66.0	55.7	-550,435	893.5	-690,801	422.7	0	0.0	0	0.0	-769,485	409.2
17	64.0	54.0	-622,319	775.6	-788,754	396.9	0	0.0	0			



Appendix D - Economic Analysis

total kW-H

16,882

total kW-H

859.9

total kW-Hr

15,271.7

20,794.3

total kW-Hr

15,193.4

20,687.4

TYPICAL DECEMBER DAY COLLEGE LOAD PROFILE										Chillers										ALTERNATIVE #1 - EXISTING CHILLER PLANT WITH TES										ALTERNATIVE #2 - EXISTING CHILLER PLANT									
Line No.	Mode	Start Time	End Time	Percent Load	Existing Plant Load (tons)	CH-2 (750-ton)	CH-3 (750-Tons)	CH-4 (750-Tons)	CH-1 (250-ton)	CH-2 (250-ton)	TES Stored Capacity	Water-Cooled Chiller kW	CHW ΔT	CHW Flow (GPM)	Central plant Primary CHW Pump Power @ 70% & 40° TDH (kW)	Central plant secondary CHW Pump Power @ 70% & 40° TDH (kW)	Building 2 Secondary CHW Pump Power @ 70% & 40° TDH (kW)	Central Plant CW Fan kW 40Hp each & .60 Duty Factor	Bldg. 2 CW Pump Power @ 2.4GPM/ton, 30°TDH & 65%	Bldg. 2 CT Fan kW 15 Hp each & .60 Duty Factor	TES kW Demand	CH-2 (750-ton)	CH-3 (750-Tons)	CH-1 (250-ton)	CH-2 (250-ton)	Water Cooled Chiller kW	Avg.CHW ΔT	Central plant CHW Flow (GPM)	Bldg. 2 CHW Flow (GPM)	Central plant Primary CHW Pump Power @ 70% & 23° TDH (kW)	Building 2 Secondary CHW Pump Power @ 70% & 23° TDH (kW)	Central Plant CW Pump Power @ 40Hp each & .60 Duty Factor	Central Plant CT Fan kW 40Hp each & .60 Duty Factor	Bldg. 2 CW Pump Power @ 2.4GPM/ton, 30°TDH & 65%	Bldg. 2 CT Fan kW 15 Hp each & .60 Duty Factor	Existing Central Plant kW Demand			
1		0	1	0.0%	0	816	816	816	0.0	0.0	18,807.3	1,713.6	18	3,264	58	202	0	0	68	54	0	0	0	2,096	0	0	0	0	0	0	0	0	0	0	0	0			
2		1	2	0.0%	0	816	377	0	0.0	0.0	20,000.0	834.9	18	1,590	39	98	0	0	33	36	0	0	0	1,041	0	0	0	0	0	0	0	0	0	0	0	0			
3		2	3	0.0%	0	0	0	0	0.0	0.0	20,000.0	0.0	18	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0					
4	Off-Peak; TES Charging	3	4	0.0%	0	0	0	0	0.0	0.0	20,000.0	0.0	18	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0					
5		4	5	0.0%	0	0	0	0	0.0	0.0	20,000.0	0.0	18	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0					
6		5	6	0.0%	0	0	0	0	0.0	0.0	20,000.0	0.0	18	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0					
7		6	7	0.0%	0	0	0	0	0.0	0.0	20,000.0	0.0	18	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0					
8		7	8	6.5%	120.5	0	0	0	0.0	0.0	19,707.7	0.0	18	172	0	11	0	0	0	0	0	11	0	0	0	0	0	0	0	0	0	0	0	0					
9		8	9	8.4%	180.0	0.0	0.0	0.0	0.0	0.0	19,707.7	0.0	18	224	0	14	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0	0				
10		9	10	14.1%	281.1	0.0	0.0	0.0	0.0	0.0	19,421.6	0.0	18	375	0	23	0	0	0	0	0	23	0	0	0	0	0	0	0	0	0	0	0	0	0				
11		10	11	18.0%	359.9	0.0	0.0	0.0	0.0	0.0	19,061.8	0.0	18	480	0	30	0	0	0	0	0	30	0	0	0	0	0	0	0	0	0	0	0	0	0				
12		11	12	27.0%	540.1	0.0	0.0	0.0	0.0	0.0	18,521.7	0.0	18	720	0	45	0	0	0	0	0	45	0	0	0	0	0	0	0	0	0	0	0	0	0				
13		12	13	33.5%	670.4	0.0	0.0	0.0	0.0	0.0	17,851.3	0.0	18	894	0	55	0	0	0	0	0	55	0	0	0	0	0	0	0	0	0	0	0	0	0				
14	Mid-Peak; TES	13	14	34.15%	690.6	0.0	0.0	0.0	0.0	0.0	17,351.6	0.0	18	920	0	57	0	0	0	0	0	57	0	0	0	0	0	0	0	0	0	0	0	0	0				
15		14	15	41.3%	826.9	0.0	0.0	0.0	0.0	0.0	16,324.7	0.0	18	1,102	0	68	0	0	0	0	0	68	0	0	0	0	0	0	0	0	0	0	0	0	0				
16		15	16	44.0%	879.7	0.0	0.0	0.0	0.0	0.0	15,455.0	0.0	18	1,173	0	73	0	0	0	0	0	73	0	0	0	0	0	0	0	0	0	0	0	0	0				
17		16	17	44.7%	893.5	0.0	0.0	0.0	0.0	0.0	14,561.5	0.0	18	1,191	0	74	0	0	0	0	0	74	0	0	0	0	0	0	0	0	0	0	0	0	0				
18		17	18	38.8%	775.6	0.0	0.0	0.0	0.0	0.0	13,785.9	0.0	18	1,024	0	64	0	0	0	0	0	64	0	0	0	0	0	0	0	0	0	0	0	0	0				
19		18	19	32.2%	644.2	0.0	0.0	0.0	0.0	0.0	13,141.7	0.0	18	859	0	53	0	0	0	0	0	53	0	0	0	0	0	0	0	0	0	0	0	0	0				
20		19	20	29.2%	582.4	0.0	0.0	0.0	0.0	0.0	12,558.3	0.0	18	778	0	48	0	0	0	0	0	48	0	0	0	0	0	0	0	0	0	0	0	0	0				
21		20	21	27.4%	548.0	0.0	0.0	0.0	0.0	0.0	12,010.3	0.0	18	731	0	45	0	0	0	0	0	45	0	0	0	0	0	0	0	0	0	0	0	0	0				
22	Off-Peak; TES	21	22	27.4%	547.0	0.0	0.0	0.0	0.0	0.0	11,463.3	0.0	18	729	0	45	0	0	0	0	0	45	0	0	0	0	0	0	0	0	0	0	0	0	0				
23	Charging	22	23	0.0%	0	816	816	816	0.0	0.0	13,911.3	1,713.6	18	3,264	58	202	0	0	68	54	0	0	0	2,096	0	0	0	0	0	0	0	0	0	0	0	0	0		
24		23	24	0.0%	0	816	816	816	0.0	0																													

total kW-Hr 5,513.8

7,405.4 7,5

0

4

10,089

413

6,60

total kW-Hr 6,340.6

8,534.5 8,4

0

4

11,643

434

7,58

total kW-Hr

84.5

11

0

8,784

8

total kW-Hr

49.2

14

3

Typical Summer Chillers with TES Tank (88 days of Operation)							Typical Summer Existing Chillers (88 Days of Operation)						
Start Time	End Time	Cooling kW Demand	Delivery Service	Generation Charges	Total \$/kWh	Consumption Charge	Start Time	End Time	Cooling kW Demand	Delivery Service	Generation Charges	Total \$/kWh	Consumption Charge
0	1	184,404	0.01889	0.03950	0.05839	\$10,767.37	0	1	0	0.06600	0.07670	0.14270	\$0.00
1	2	184,404	0.01889	0.03950	0.05839	\$10,767.37	1	2	0	0.06600	0.07670	0.14270	\$0.00
2	3	184,404	0.01889	0.03950	0.05839	\$10,767.37	2	3	0	0.06600	0.07670	0.14270	\$0.00
3	4	164,656	0.01889	0.03950	0.05839	\$9,614.27	3	4	0	0.06600	0.07670	0.14270	\$0.00
4	5	0	0.01889	0.03950	0.05839	\$0.00	4	5	0	0.06600	0.07670	0.14270	\$0.00
5	6	0	0.01889	0.03950	0.05839	\$0.00	5	6	0	0.06600	0.07670	0.14270	\$0.00
6	7	27,371	0.01889	0.03950	0.05839	\$1,598.20	6	7	30,992	0.06600	0.07670	0.14270	\$4,422.49
7	8	41,720	0.01889	0.06483	0.08372	\$3,492.77	7	8	48,702	0.06600	0.07670	0.14270	\$6,949.73
8	9	103,349	0.01889	0.06483	0.08372	\$8,652.36	8	9	121,574	0.06600	0.07670	0.14270	\$17,348.60
9	10	106,982	0.01889	0.06483	0.08372	\$8,956.55	9	10	125,266	0.06600	0.07670	0.14270	\$17,875.53
10	11	13,335	0.01889	0.06483	0.08372	\$1,116.43	10	11	135,554	0.06600	0.07670	0.14270	\$19,343.59
11	12	14,424	0.01889	0.06483	0.08372	\$1,207.61	11	12	146,529	0.06600	0.07670	0.14270	\$20,909.64
12	13	14,882	0.01889	0.08629	0.10518	\$1,565.31	12	13	148,806	0.06600	0.07670	0.14270	\$21,234.64
13	14	15,593	0.01889	0.08629	0.10518	\$1,640.04	13	14	151,821	0.06600	0.07670	0.14270	\$21,664.82
14	15	16,020	0.01889	0.08629	0.10518	\$1,684.96	14	15	154,104	0.06600	0.07670	0.14270	\$21,990.67
15	16	16,149	0.01889	0.08629	0.10518	\$1,698.51	15	16	154,561	0.06600	0.07670	0.14270	\$22,055.84
16	17	14,887	0.01889	0.08629	0.10518	\$1,565.80	16	17	150,418	0.06600	0.07670	0.14270	\$21,464.71
17	18	12,211	0.01889	0.08629	0.10518	\$1,284.31	17	18	122,501	0.06600	0.07670	0.14270	\$17,480.84
18	19	8,881	0.01889	0.06483	0.08372	\$743.51	18	19	89,636	0.06600	0.07670	0.14270	\$12,791.07
19	20	7,914	0.01889	0.06483	0.08372	\$562.58	19	20	77,989	0.06600	0.07670	0.14270	\$11,129.04
20	21	0	0.01889	0.06483	0.08372	\$0.00	20	21	75,361	0.06600	0.07670	0.14270	\$10,753.95
21	22	184,404	0.01889	0.06483	0.08372	\$15,438.33	21	22	0	0.06600	0.07670	0.14270	\$0.00
22	23	184,404	0.01889	0.06483	0.08372	\$15,438.33	22	23	0	0.06600	0.07670	0.14270	\$0.00
23	24	180,875	0.01889	0.03950	0.05839	\$10,561.27	23	24	0	0.06600	0.07670	0.14270	\$0.00
1,681,270							\$119,223.26						
on	89,741		on	\$ 9,438.94			on	882,211		on	\$ 125,891.52		
mid	665,414		mid	\$ 55,708.46			mid	820,611		mid	\$ 117,101.16		
off	926,115		off	\$ 54,075.86			off	30,992		off	\$ 4,422.49		
		Peak Demand (kW)			Fac. Demand/kW		Fac. Rel Demand Charge		Peak Demand Summer (August 3pm)		Mid Peak Demand Summer (July 11am)		\$247,415.17
		\$119,223.26			191		\$12.31		\$18.63		\$3,552.47		
		\$2,347.34							176		\$5.22		\$917.93
		\$247,415.17			1,786		\$13.71		\$13.71		\$24,488.19		
Typical Winter Chillers with TES Tank (176 days of Operation)							Typical Winter Existing Chillers (176 days of Operation)						
Start Time	End Time	Cooling kW Demand	Delivery Service	Generation Charges	Total \$/kWh	Consumption Charge	Start Time	End Time	Cooling kW Demand	Delivery Service	Generation Charges	Total \$/kWh	Consumption Charge
0	1	362,915	0.01889	0.03542	0.05431	\$19,709.92	0	1	0	0.06600	0.07670	0.14270	\$0.00
1	2	250,642	0.01889	0.03542	0.05431	\$13,612.38	1	2	0	0.06600	0.07670	0.14270	\$0.00
2	3	162,014	0.01889	0.03542	0.05431	\$8,798.97	2	3	0	0.06600	0.07670	0.14270	\$0.00
3	4	99,356	0.01889	0.03542	0.05431	\$5,396.03	3	4	0	0.06600	0.07670	0.14270	\$0.00
4	5	52,739	0.01889	0.03542	0.05431	\$2,864.25	4	5	0	0.06600	0.07670	0.14270	\$0.00
5	6	0	0.01889	0.03542	0.05431	\$0.00	5	6	0	0.06600	0.07670	0.14270	\$0.00
6	7	0	0.01889	0.03542	0.05431	\$0.00	6	7	0	0.06600	0.07670	0.14270	\$0.00
7	8	2,457	0.01889	0.03542	0.05431	\$133.45	7	8	24,944	0.06600	0.07670	0.14270	\$3,559.47
8	9	3,437	0.01889	0.05956	0.07845	\$269.63	8	9	34,109	0.06600	0.07670	0.14270	\$4,867.32
9	10	6,816	0.01889	0.05956	0.07845	\$534.75	9	10	69,926	0.06600	0.07670	0.14270	\$9,978.49
10	11	8,305	0.01889	0.05956	0.07845	\$651.50	10	11	84,419	0.06600	0.07670	0.14270	\$12,046.53
11	12	10,757	0.01889	0.05956	0.07845	\$843.89	11	12	108,300	0.06600	0.07670	0.14270	\$15,454.41
12	13	12,538	0.01889	0.05956	0.07845	\$983.63	12	13	125,198	0.06600	0.07670	0.14270	\$17,865.75
13	14	12,848	0.01889	0.05956	0.07845	\$1,007.96	13	14	128,131	0.06600	0.07670	0.14270	\$18,284.27
14	15	14,691	0.01889	0.05956	0.07845	\$1,152.50	14	15	148,580	0.06600	0.07670	0.14270	\$21,202.31
15	16	15,975	0.01889	0.05956	0.07845	\$1,253.25	15	16	162,118	0.06600	0.07670	0.14270	\$23,134.26
16	17	17,628	0.01889	0.05956	0.07845	\$1,382.93	16	17	178,598	0.06600	0.07670	0.14270	\$25,485.89
17	18	15,618	0.01889	0.05956	0.07845	\$1,225.24	17	18	157,876	0.06600	0.07670	0.14270	\$25,258.96
18	19	12,073	0.01889	0.05956	0.07845	\$947.14	18	19	122,300	0.06600	0.07670	0.14270	\$17,452.20
19	20	9,799	0.01889	0.05956	0.07845	\$768.75	19	20	98,973	0.06600	0.07670	0.14270	\$14,123.47
20	21	9,069	0.01889	0.05956	0.07845	\$711.46	20	21	91,468	0.06600	0.07670	0.14270	\$13,052.45
21	22	8,007	0.01889	0.03542	0.05431	\$434.84	21	22	81,123	0.06600	0.07670	0.14270	\$11,576.19
22	23	368,809	0.01889	0.03542	0.05431	\$20,030.00	22	23	0	0.06600	0.07670	0.14270	\$0.00
23	24	368,809	0.01889	0.03542	0.05431	\$20,030.00	23	24	0	0.06600	0.07670	0.14270	\$0.00
1,825,303							\$102,742.45						
							1,616,061						
							\$230,611.96						
mid	149,555		mid	\$ 11,732.60			mid	1,509,995		mid	\$ 215,476.30		
off	1,675,748		off	\$ 91,009.85			off	106,066		off	\$ 15,135.66		

\$875 Incentive per kW
2,311 Tonnage Offset
\$1,415,487.50 Incentive

\$127,869.51 Winter Cost Savings
\$128,191.92 Summer Cost Savings
\$66,565.40 Summer KW Savings
\$322,626.82 Total Annual Savings

Appendix E - Probable Construction Cost Estimate

MT SAN ANTONIO COLLEGE TES ADDITION PROJECT			
Description of Item	Qty	Unit Cost	Total Cost
Thermal Energy Storage System	1	\$3,300,000	\$3,300,000
750 Ton Chiller	1	\$310,000	\$310,000
750 Ton Cooling Tower	1	\$400,000	\$400,000
Underground Chilled Water Piping	800	\$550	\$440,000
Inside Plant Chilled Water Piping	L.S.	\$100,000	\$100,000
Pumps and Accessories	L.S.	\$200,000	\$200,000
Controls	L.S.	\$250,000	\$250,000
Electrical Connections	L.S.	\$120,000	\$120,000
Structural inside plant	L.S.	\$65,000	\$65,000
Allowances DSA	L.S.	\$50,000	\$50,000
Total Costs			\$5,235,000